



DPC: 18/30378229 DC

BSI Group Headquarters

389 Chiswick High Road London W4 4AL

Tel: +44 (0)20 8996 9000

Fax: +44 (0)20 8996 7400

www.bsigroup.com

Date: 17 September 2018

Origin: International

Latest date for receipt of comments: 08 November 2018

Project No. 2018/01527

Responsible committee: JPEL/64 Electrical Installations of Buildings - Joint Committee

Interested committees:

Title: Draft BS IEC 60364-7-720 Part 7-720: Requirements for special installations or locations - DC power supply system in the data centre.

Please notify the secretary if you are aware of any keywords that might assist in classifying or identifying the standard or if the content of this standard

- i) has any issues related to 3rd party IPR, patent or copyright
- ii) affects other national standard(s)
- iii) requires additional national guidance or information

WARNING: THIS IS A DRAFT AND MUST NOT BE REGARDED OR USED AS A BRITISH STANDARD. THIS DRAFT IS NOT CURRENT BEYOND 08 November 2018

This draft is issued to allow comments from interested parties; all comments will be given consideration prior to publication. No acknowledgement will normally be sent. **See overleaf for information on the submission of comments.**

No copying is allowed, in any form, without prior written permission from BSI except as permitted under the Copyright, Designs and Patent Act 1988 or for circulation within a nominating organization for briefing purposes. Electronic circulation is limited to dissemination by e-mail within such an organization by committee members.

Further copies of this draft may be purchased from BSI Shop <http://shop.bsigroup.com> or from BSI Customer Services, Tel: +44(0) 20 8996 9001 or email cservices@bsigroup.com. British, International and foreign standards are also available from BSI Customer Services.

Information on the co-operating organizations represented on the committees referenced above may be obtained from <https://standardsdevelopment.bsigroup.com/>.

Responsible Committee Secretary: Mr Geoff Cronshaw (BSI)
Direct tel: 01438 767384
E-mail: gcronshaw@theiet.org

Full document details: 18/30378229 DC

Introduction

This draft standard is based on national and international discussions. Your comments on this draft are invited and will assist in the preparation of the consequent standard.

For international standards, comments will be reviewed by the relevant UK national committee before sending the consensus UK vote and comments to the international committee, which will then decide appropriate action. If the international standard is approved, it is usual for the text to be published as a British Standard.

For national standards, comments will be reviewed by the relevant UK national committee and the resulting standards published as a British Standard.

UK Vote

Please indicate whether you consider the UK should submit a negative (with supporting technical reasons) or positive vote on this draft. Please indicate if you are aware of any reason why this draft standard should not be published as a British Standard.

Submission of Comments

- **Annotated drafts are not acceptable and will be rejected.**
- All comments should be submitted online at <https://standardsdevelopment.bsigroup.com/>. You will need to register in order to comment.

Template for comments and secretariat observations

Date: xx/xx/20xx	Document: ISO/DIS xxxx
------------------	------------------------

1	2	(3)	4	5	(6)	7
MB	Clause No./ Subclause No./Annex (e.g. 3.1)	Paragraph/Figure/ Table/Note	Type of comment	Commend (justification for change) by the MB	Proposed change by the MB	Secretariat observations on each comment submitted
	3.1	Definition 1	ed	Definition is ambiguous and needs clarifying.	Amend to read '...so that the mains connector to which no connection...'	
	6.4	Paragraph 2	te	The use of the UV photometer as an alternative cannot be supported as serious problems have been encountered in its use in the UK.	Delete reference to UV photometer.	



64/2346/CD

COMMITTEE DRAFT (CD)

PROJECT NUMBER:
IEC 60364-7-720 ED1

DATE OF CIRCULATION:
2018-09-14

CLOSING DATE FOR COMMENTS:
2018-12-07

SUPERSEDES DOCUMENTS:
64/2246/NP, 64/2279A/RVN

IEC TC 64 : ELECTRICAL INSTALLATIONS AND PROTECTION AGAINST ELECTRIC SHOCK			
SECRETARIAT: Germany		SECRETARY: Mr Reinhard Pelta	
OF INTEREST TO THE FOLLOWING COMMITTEES: SyC LVDC		PROPOSED HORIZONTAL STANDARD: ☐ Other TC/SCs are requested to indicate their interest, if any, in this CD to the secretary.	
FUNCTIONS CONCERNED: ☐ EMC ☐ ENVIRONMENT ☐ QUALITY ASSURANCE ☐ SAFETY			

This document is still under study and subject to change. It should not be used for reference purposes.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

TITLE:

Part 7-720: Requirements for special installations or locations— DC power supply system in the data centre

NOTE FROM TC/SC OFFICERS:

Copyright © 2018 International Electrotechnical Commission, IEC. All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.



Documents

Document Sharing Hub

LOW-VOLTAGE ELECTRICAL INSTALLATION**Part 7-720: Requirements for special installations or locations —
DC power supply system in the data centre****CONTENTS**

FOREWORD	3
INTRODUCTION	5
720 DC power supply system in the data centre	6
720.1 Scope	6
720.2 Normative references	6
720.3 Terms and definitions	6
720.3.1 corrosion	7
720.31 Purposes, supplies and structure	7
720.312 Conductor arrangement and system earthing	7
720.312.2 Types of system earthing	7
720.312.2.4 DC-systems	7
720.312.2.4.5 IT-systems	7
720.313 Supplies	8
720.4 Protection for safety	8
720.41 Protection against electric shock	8
720.411 Protective measure: automatic disconnection of supply	8
720.411.4 TN system	8
720.411.5 TT system	8
720.411.6 IT system	8
720.411.6.3	8
720.411.6.3.1	8
720.411.6.4 b)	9
720.415 Additional protection	9
720.415.1 Additional protection: residual current protective devices(RCDs)	9
720.42 Protection against thermal effects	9
720.421 Protection against fire caused by electrical equipment	9
720.421.3	9
720.44 Protection against voltage disturbances and electromagnetic disturbances	9
720.442 Protection of low-voltage installations against temporary overvoltages due to earth faults in the high-voltage system and due to faults in the low-voltage system	9
720.443 Protection against overvoltages of atmospheric origin or due to switching	10
720.443.4 Required impulse withstand voltage of equipment	10
720.444 Measures against electromagnetic influences	11

43	720.444.1	General	11
44	720.444.4	Mitigation of electromagnetic interference (EMI)	11
45	720.444.4.5	IT-system	11
46	720.5	Selection and erection of electrical equipment	12
47	720.52	Wiring system	12
48	720.521	Types of wiring system	12
49	720.521.101		12
50	720.528	Proximity of wiring systems to other services	12
51	720.528.2	Proximity of communications cables	12
52	720.528.1.101		13
53	720.528.2.102		13
54	720.528.3	Proximity to non-electrical services.....	13
55	720.528.3.101		13
56	720.53	Isolation, switching and Control	13
57	720.536	Isolation and switching	13
58	720.536.2	Isolation.....	13
59	720.536.2.2	Devices for isolation	13
60	720.536.2.2.9		13
61	Bibliography	14	
62			
63	Figure 31M - IT DC. system	7	
64	Figure 44XX - IT system in building facilities.....	12	
65			
66	Table 44.B2 - Required impulse withstand voltage of equipment.....	10	
67			
68			
69			