



DPC: 21/30439415 DC

BSI Group Headquarters

389 Chiswick High Road London W4 4AL

Tel: +44 (0)20 8996 9000

Fax: +44 (0)20 8996 7400

www.bsigroup.com

Date: 04 June 2021

Origin: International

Latest date for receipt of comments: 28 July 2021

Project No. 2021/01546

Responsible committee: PEL/38 Instrument transformers

Interested committees:

Title: Draft BS EN IEC 61869-8 Instrument transformers. Part 8: Specific requirements for electronic Current Transformers.

Please notify the secretary if you are aware of any keywords that might assist in classifying or identifying the standard or if the content of this standard

- i) has any issues related to 3rd party IPR, patent or copyright
- ii) affects other national standard(s)
- iii) requires additional national guidance or information

WARNING: THIS IS A DRAFT AND MUST NOT BE REGARDED OR USED AS A BRITISH STANDARD. THIS DRAFT IS NOT CURRENT BEYOND 28 July 2021

This draft is issued to allow comments from interested parties; all comments will be given consideration prior to publication. No acknowledgement will normally be sent. **See overleaf for information on the submission of comments.**

No copying is allowed, in any form, without prior written permission from BSI except as permitted under the Copyright, Designs and Patent Act 1988 or for circulation within a nominating organization for briefing purposes. Electronic circulation is limited to dissemination by e-mail within such an organization by committee members.

Further copies of this draft may be purchased from BSI Shop <http://shop.bsigroup.com> or from BSI Customer Services, Tel: +44(0) 20 8996 9001 or email cservices@bsigroup.com. British, International and foreign standards are also available from BSI Customer Services.

Information on the co-operating organizations represented on the committees referenced above may be obtained from <https://standardsdevelopment.bsigroup.com/>.

Responsible Committee Secretary: Ms Nicola Young (BSI)

Direct tel:

E-mail: nicola.young@bsigroup.com

Full document details: 21/30439415 DC

Introduction

This draft standard is based on national and international discussions. Your comments on this draft are invited and will assist in the preparation of the consequent standard.

For international standards, comments will be reviewed by the relevant UK national committee before sending the consensus UK vote and comments to the international committee, which will then decide appropriate action. If the international standard is approved, it is usual for the text to be published as a British Standard.

For national standards, comments will be reviewed by the relevant UK national committee and the resulting standards published as a British Standard.

UK Vote

Please indicate whether you consider the UK should submit a negative (with supporting technical reasons) or positive vote on this draft. Please indicate if you are aware of any reason why this draft standard should not be published as a British Standard.

Submission of Comments

- **Annotated drafts are not acceptable and will be rejected.**
- All comments should be submitted online at <https://standardsdevelopment.bsigroup.com/>. You will need to register in order to comment.

Template for comments and secretariat observations

Date: xx/xx/20xx	Document: ISO/DIS xxxx
------------------	------------------------

1	2	(3)	4	5	(6)	7
MB	Clause No./ Subclause No./Annex (e.g. 3.1)	Paragraph/Figure/ Table/Note	Type of comment	Commend (justification for change) by the MB	Proposed change by the MB	Secretariat observations on each comment submitted
	3.1	Definition 1	ed	Definition is ambiguous and needs clarifying.	Amend to read '...so that the mains connector to which no connection...'	
	6.4	Paragraph 2	te	The use of the UV photometer as an alternative cannot be supported as serious problems have been encountered in its use in the UK.	Delete reference to UV photometer.	



38/655/CD

COMMITTEE DRAFT (CD)

PROJECT NUMBER: IEC 61869-8 ED1	
DATE OF CIRCULATION: 2021-06-04	CLOSING DATE FOR COMMENTS: 2021-08-27
SUPERSEDES DOCUMENTS: 38/616/NP, 38/624A/RVN	

IEC TC 38 : INSTRUMENT TRANSFORMERS	
SECRETARIAT: Italy	SECRETARY: Mr Filippo Frugoni
OF INTEREST TO THE FOLLOWING COMMITTEES: TC 13,TC 57,TC 85,SC 86C,TC 95	PROPOSED HORIZONTAL STANDARD: ☐ Other TC/SCs are requested to indicate their interest, if any, in this CD to the secretary.
FUNCTIONS CONCERNED: ☒ EMC ☐ ENVIRONMENT ☐ QUALITY ASSURANCE ☐ SAFETY	

This document is still under study and subject to change. It should not be used for reference purposes.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

TITLE:
Instrument transformers - Part 8: Specific requirements for electronic Current Transformers

NOTE FROM TC/SC OFFICERS:

CONTENTS

2		
3	FOREWORD.....	4
4	1 Scope.....	8
5	2 Normative reference	8
6	3 Terms and definitions	9
7	3.1 General terms and definitions	9
8	3.4 Definitions related to accuracy.....	10
9	3.7 Index of abbreviations	11
10	5 Ratings.....	11
11	5.5 Rated output	11
12	5.5.801 Rated burden (Z_{br}).....	11
13	5.6 Rated accuracy class	12
14	5.6.801 Measuring ECT	12
15	5.6.802 Protective ECT.....	13
16	5.6.803 Multipurpose ECT	14
17	5.801 Recommended values for rated primary current (I_{pr}).....	15
18	5.802 Standard values of rated secondary voltage (U_{sr}) for analog signal.....	15
19	5.803 Standard values for rated continuous thermal current (I_{cth}).....	15
20	5.804 Rated short-time thermal current (I_{th}).....	15
21	5.805 Rated dynamic current (I_{dyn})	15
22	5.806 Wake-up current (I_{wk}) and wake-up time (t_{wk}).....	16
23	5.807 Secondary voltage limit	16
24	5.808 Limits for the secondary voltage offset and noise	16
25	5.809 Test for accuracy in respect of the positioning of the primary conductor	16
26	5.809.1 General	16
27	5.809.2 Designation of accuracy class extension.....	17
28	6 Design and construction	18
29	6.4 Requirements for temperature rise of parts and components	18
30	6.4.1 General	18
31	6.11 Electromagnetic compatibility (EMC).....	18
32	6.11.801 Impact of magnetic field at rated frequency from other phases	18
33	6.13 Markings.....	19
34	6.13.801 Terminal markings – General rules	19
35	6.13.802 Method of marking	19
36	6.13.803 Markings to be used.....	19
37	6.13.804 Rating plate markings	20
38	6.602 Requirement for electrical transmitting systems and electrical wires for	
39	output link.....	21
40	6.602.1 Connectors	21
41	6.602.2 Earthing of the output cable.....	21
42	6.603 Recommended time interval for the verification of accuracy.....	22
43	7 Tests.....	22
44	7.1 General.....	22
45	7.1.2 List of tests	22
46	7.2 Type tests	22
47	7.2.2 Temperature-rise test.....	22

48	7.2.5	Electromagnetic compatibility (EMC) tests	24
49	7.2.6	Test for accuracy	24
50	7.2.801	Short time current tests	29
51	7.2.802	Tests for digital output.....	30
52	7.2.803	Test for offset	30
53	7.2.804	Test for noise.....	31
54	7.3	Routine tests.....	31
55	7.3.1	Power-frequency voltage withstand tests on primary terminals	31
56	7.3.4	Power-frequency voltage withstand tests on secondary terminals	31
57	7.3.5	Test for accuracy	31
58	7.4	Special test.....	31
59	7.4.801	Frequency response of the ECT	31
60	601	Information to be given with enquiries, tenders and orders.....	32
61	601.1	Designation.....	32
62		Bibliography	33
63			
64		Figure 801 – General block diagram of a single-phase ECT	8
65		Figure 801.2 – Illustration of the primary conductor position according to the position	
66		factor.....	18
67		Figure 803 – Markings of terminals.....	20
68		Figure 804 – Accuracy measurement test set up.....	27
69		Figure 805– test set up for impact of magnetic field from other phases.....	29
70			
71		Table 801 – Limits of error	12
72		Table 802 – Designation of protective classes	13
73		Table 803 – Limits of errors for protective ECT.....	14
74		Table 10 – List of further tests besides those in Subclause 7.1.2 of IEC 61869-6:2016	22
75		Table 807 – Burden values for analogue output at which test for accuracy shall be	
76		made.....	25
77		Table 808 – Designation of ECT	32
78			
79			

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INSTRUMENT TRANSFORMERS –

**Part 8: Additional requirements
for electronic current transformers**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61869-8 has been prepared by IEC technical committee 38: Instrument transformers.

This first edition of IEC 61869-8 cancels and replaces the IEC 60044-8, published in 2002¹.

¹ IEC 60044-7 and IEC 60044-8 will eventually be replaced by the IEC 61869 series, but until all the relevant parts will be published, these two standards are still in force.

125 The text of this standard is based on the following documents:

FDIS	Report on voting
38/XXX/FDIS	38/XXX/RVD

126
127 Full information on the voting for the approval of this standard can be found in the report on
128 voting indicated in the above table.

129 This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

130 A list of all parts in the IEC 61869 series, published under the general title *Instrument*
131 *transformers*, can be found on the IEC website.

132 This Part 8 is to be read in conjunction with, and is based on, IEC 61869-1:2007, *Part 1: General*
133 *Requirements*, and IEC 61869-6:2016, *Instrument transformers – Part 6: Additional general*
134 *requirements for low-power instrument transformers*. However, the reader is encouraged to use
135 its most recent edition.

136 This Part 8 follows the structure of IEC 61869-1:2007 and of IEC 61869-6:2016 and
137 supplements or modifies its corresponding clauses.

138 When a particular clause/subclause of Part 1 and Part 6 is not mentioned in this Part 8, that
139 clause/subclause applies. When this standard states “addition”, “modification” or “replacement”,
140 the relevant text in Part 1 and Part 6 is to be adapted accordingly.

141 For additional clauses, subclauses, figures, tables, annexes or notes, the following numbering
142 system is used:

- 143 – clauses, subclauses, tables, figures and notes that are numbered starting from 801 are
144 additional to those in Part 1 and Part 6;
145 – additional annexes are lettered 8A, 8B, etc.

146 An overview of the planned set of standards at the date of publication of this document is given
147 below. The updated list of standards issued by IEC TC 38 is available at the website:
148 www.iec.ch.

149

150

PRODUCT FAMILY STANDARDS		PRODUCT STANDARD IEC	PRODUCTS	OLD STANDARD IEC
IEC 61869-1 GENERAL REQUIREMENTS FOR INSTRUMENT TRANSFORMERS	IEC 61869-6 ADDITIONAL GENERAL REQUIREMENTS FOR LOW-POWER INSTRUMENT TRANSFORMERS	61869-2	ADDITIONAL REQUIREMENTS FOR CURRENT TRANSFORMERS	60044-1 60044-6
		61869-3	ADDITIONAL REQUIREMENTS FOR INDUCTIVE VOLTAGE TRANSFORMERS	60044-2
		61869-4	ADDITIONAL REQUIREMENTS FOR COMBINED TRANSFORMERS	60044-3
		61869-5	ADDITIONAL REQUIREMENTS FOR CAPACITOR VOLTAGE TRANSFORMERS	60044-5
		61869-7	ADDITIONAL REQUIREMENTS FOR ELECTRONIC VOLTAGE TRANSFORMERS	60044-7
		61869-8	ADDITIONAL REQUIREMENTS FOR ELECTRONIC CURRENT TRANSFORMERS	60044-8
		61869-9	DIGITAL INTERFACE FOR INSTRUMENT TRANSFORMERS	
		61869-10	ADDITIONAL REQUIREMENTS FOR LOW-POWER PASSIVE CURRENT TRANSFORMERS	
		61869-11	ADDITIONAL REQUIREMENTS FOR LOW-POWER PASSIVE VOLTAGE TRANSFORMERS	60044-7
		61869-12	ADDITIONAL REQUIREMENTS FOR COMBINED ELECTRONIC INSTRUMENT TRANSFORMER OR COMBINED PASSIVE TRANSFORMERS	
		61869-13	STAND ALONE MERGING UNIT	
		61869-14	ADDITIONAL REQUIREMENTS FOR CURRENT TRANSFORMERS FOR DC APPLICATIONS	
		61869-15	ADDITIONAL REQUIREMENTS FOR DC VOLTAGE TRANSFORMERS FOR DC APPLICATIONS	

151

152

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INSTRUMENT TRANSFORMERS –

Part 8: Additional requirements for electronic current transformers

1 Scope

This part of IEC 61869 is a product standard and covers additional requirements for electronic current transformers (ECT) used for AC applications having rated frequencies from 15 Hz to 400 Hz and system voltage above 1 kV. The product standard for ECT is composed by the IEC 61869-1:2007, in addition with IEC 61869-6:20126, and this standard with specific requirements.

The ECT may include any arrangement of electrical, optical, magnetic technologies provided it contains electronic devices.

Note: CT including passive overvoltage protective devices are not considered to be ECT.

For analogue secondary signal, this standard specifies rated secondary voltage.

For digital secondary signal, this standard refers to IEC 61969-9.

The general block diagram of single-phase ECT is given in Figure 801. According to the technology, it is not necessary that all parts described in Figure 801 are included in the ECT.




Figure 801 – General block diagram of a single-phase ECT

2 Normative reference

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61869-1:2007, *Instrument transformers – Part 1: General requirements*

IEC 61869-2 Ed. 1.0 b:2012, *Instrument Transformers - Part 2: Additional requirements for current transformers*

IEC 61869-6:2016, *Instrument transformers – Part 6: Additional general requirements for low-power instrument transformers*

196 IEC 61869-9:2016, *Instrument transformers – Part 9: Digital interface for instrument*
197 *transformers*

198 *IEC 61000-4-17 Ed. 1.2 b:2009, Electromagnetic Compatibility (EMC) - Part 4-17: Testing and*
199 *measurement techniques - ripple on d.c. Input power port immunity test*

200 IEC 60059 Ed. 2.1 b:2009, IEC Standard Current Ratings

201 **3 Terms and definitions**

202 For the purposes of this document, the terms and definitions from IEC 61869-1:2007 and
203 IEC 61869-6:2016 apply, with the following modifications and additions.

204 **3.1 General terms and definitions**

205 **3.1.607**

206 **electronic IT**

207 **EIT**

208 LPIT in which signal processing is performed by active electronic components

209 **3.1.801**

210 **electronic current transformer**

211 **ECT**

212 EIT for current measurements

213 **3.1.802**

214 **bushing type ECT**

215 electronic current transformer without primary conductor and primary insulation of its own
216 which can be fitted directly over an insulated bushing or conductor

217 Note to entry: Bushing type ECT is a generic definition that includes the cable type current transformer as defined in
218 IEC 321-02-04.

219 [SOURCE: IEC 321-02-02:1986]

220

221 **3.1.803**

222 **step response time**

223 duration between the instant when the measurand (or quantity supplied) is subjected to a
224 specified abrupt change and the instant when the indication (or quantity supplied) reaches, and
225 remains within specified limits of, its final steady-state value.

226 [SOURCE: IEC 311-06-04]

227 **3.1.627**

228 **wake-up current**

229 I_{wk}

230 In case of ECT with source of power given by the primary current, the wake-up current is the
231 minimum primary current which assure a full operation of the ECT.

232 **3.1.628**

233 **wake-up time**

234 t_{wk}

235 In case of ECT with source of power given by the primary current, the wake-up time is the time
236 occurrence between the instant the current starts passing through the primary terminals and
237 the time in which the ECT reaches a full operation.