



DPC: 23 / 30469012 DC

BSI Group Headquarters

389 Chiswick High Road London W4 4AL

Tel: +44 (0)20 8996 9000

Fax: +44 (0)20 8996 7400

www.bsigroup.com

Date: 02 February 2023

Origin: International

Latest date for receipt of comments: 22 March 2023

Project No. 2023/00229

Responsible committee: NCE/8 Instrumentation, Control & Electrical Systems of Nuclear Facilities

Interested committees:

Title: BS EN IEC 61225 Nuclear power plants - Instrumentation, control and electrical power systems - Requirements for static uninterruptible DC and AC power supply systems

Please notify the secretary if you are aware of any keywords that might assist in classifying or identifying the standard or if the content of this standard

- i) has any issues related to 3rd party IPR, patent or copyright
- ii) affects other national standard(s)
- iii) requires additional national guidance or information

**WARNING: THIS IS A DRAFT AND MUST NOT BE REGARDED OR USED AS A BRITISH STANDARD.
THIS DRAFT IS NOT CURRENT BEYOND 22 March 2023**

This draft is issued to allow comments from interested parties; all comments will be given consideration prior to publication. No acknowledgement will normally be sent. **See overleaf for information on the submission of comments.**

No copying is allowed, in any form, without prior written permission from BSI except as permitted under the Copyright, Designs and Patent Act 1988 or for circulation within a nominating organization for briefing purposes. Electronic circulation is limited to dissemination by e-mail within such an organization by committee members.

Further copies of this draft may be purchased from BSI Shop <http://shop.bsigroup.com> or from BSI Customer Services, Tel: +44(0) 20 8996 9001 or email cservices@bsigroup.com. British, International and foreign standards are also available from BSI Customer Services.

Information on the co-operating organizations represented on the committees referenced above may be obtained from <http://standardsdevelopment.bsigroup.com>

Responsible Committee Secretary: **Mr Andranik Ohanian (BSI)**

Direct tel:

E-mail: andranik.ohanian@bsigroup.com

Introduction

This draft standard is based on national and international discussions. Your comments on this draft are invited and will assist in the preparation of the consequent standard.

For international standards, comments will be reviewed by the relevant UK national committee before sending the consensus UK vote and comments to the international committee, which will then decide appropriate action. If the international standard is approved, it is usual for the text to be published as a British Standard.

For national standards, comments will be reviewed by the relevant UK national committee and the resulting standards published as a British Standard.

UK Vote

Please indicate whether you consider the UK should submit a negative (with supporting technical reasons) or positive vote on this draft. Please indicate if you are aware of any reason why this draft standard should not be published as a British Standard.

Submission of Comments

- **Annotated drafts are not acceptable and will be rejected.**
- All comments should be submitted online at <https://standardsdevelopment.bsigroup.com/>. You will need to register in order to comment.

Template for comments and secretariat observations

Date: xx/xx/20xx	Document: ISO/DIS xxxx
------------------	------------------------

1	2	(3)	4	5	(6)	7
MB	Clause No./ Subclause No./Annex (e.g. 3.1)	Paragraph/Figure/ Table/Note	Type of comment	Commend (justification for change) by the MB	Proposed change by the MB	Secretariat observations on each comment submitted
	3.1	Definition 1	ed	Definition is ambiguous and needs clarifying.	Amend to read '...so that the mains connector to which no connection...'	
	6.4	Paragraph 2	te	The use of the UV photometer as an alternative cannot be supported as serious problems have been encountered in its use in the UK.	Delete reference to UV photometer.	

PROJECT NUMBER: IEC 61225 ED4	
DATE OF CIRCULATION: 2023-01-27	CLOSING DATE FOR COMMENTS: 2023-04-21
SUPERSEDES DOCUMENTS: 45A/1464/RR	

IEC SC 45A : INSTRUMENTATION, CONTROL AND ELECTRICAL POWER SYSTEMS OF NUCLEAR FACILITIES	
SECRETARIAT: France	SECRETARY: Mr Jean-Paul Bouard
OF INTEREST TO THE FOLLOWING COMMITTEES:	PROPOSED HORIZONTAL STANDARD: ☐ Other TC/SCs are requested to indicate their interest, if any, in this CD to the secretary.
FUNCTIONS CONCERNED: ☐ EMC ☐ ENVIRONMENT ☐ QUALITY ASSURANCE ☒ SAFETY	

This document is still under study and subject to change. It should not be used for reference purposes.

Recipients of this document are invited to submit, with their comments, notification of

- any relevant patent rights of which they are aware and to provide supporting documentation,
- any local regulations or technical reasons that may exist and should be considered should this proposal proceed, recognizing that failure to address such requirements could result in the need for new or existing "in some countries" clauses. See AC/22/2007.

TITLE:

Nuclear power plants – Instrumentation, control and electrical power systems – Requirements for static uninterruptible DC and AC power supply systems

NOTE FROM TC/SC OFFICERS:

Copyright © 2023 International Electrotechnical Commission, IEC. All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.

CONTENTS

CONTENTS	1
FOREWORD	4
INTRODUCTION	6
1. Scope	8
2. Normative references	8
3. Terms and definitions	9
4. Abbreviated terms	11
5. System requirements	11
5.1 General	11
5.2 Function and description	12
5.2.1 Preamble	12
5.2.2 Designations	14
5.2.3 Direct current systems	14
5.2.4 Alternating current systems	14
5.3 System divisions	15
5.4 System boundaries	15
6. Functional requirements for static uninterruptible power supplies	15
6.1 Static uninterruptible power supplies for systems important to safety	15
6.2 Batteries and battery chargers	16
6.3 Inverters and bypass switches	17
6.4 UPS	18
6.5 Converters used for voltage stabilization	18
6.6 I&C power supply using DC/DC-converters and AC/DC-converters	18
7. Requirements for distribution systems	19
7.1 System aspects	19
7.2 Load allocation	19
7.3 Electrical aspects	21
7.4 Earthing	22
8. Effects of loads on supply quality	22
8.1 General	22
8.2 Electromagnetic interference	22
8.3 Transients	22
8.4 Load current	23
8.5 Power supplies to loads of lower safety classification	23
9. Monitoring and protection	23
9.1 General	23
9.2 Monitoring	24
9.3 Electrical protection	24
10. Qualification of equipment	25
11. Design to cope with ageing	25
12. Testing	25
13. Maintenance	26
Annex A (informative) Examples of voltage input variations	27
Annex B (informative) Examples of specifications	29

B.1	Example 1: Specification for an DC power supply for equipment requiring a non-interruptible supply.....	29
B.2	Example 2: Specification for AC power supply for equipment requiring a non-interruptible supply	30
B.3	Example 3: Specification for DC power supply with DC/DC converter for equipment.....	31
B.4	Human factor engineering programme	31
Annex C (normative)	Uninterruptible power supplies and distribution systems for SMRs and passive designs.....	33
C.1	Introduction.....	33
C.2	Requirements	34
C.3	Safety assessment.....	35
Bibliography		36
Figure 1	– System boundary	13
Figure 2	– Example of one division of an uninterruptible power supply system.....	20
Figure 3	– Example of I&C uninterruptible AC power supply system.....	21
Figure A.1	– Example of voltage variations on the on-site AC power system during clearing of a transmission system fault	27
Figure A.2	– Example of on-site voltage profile after loss of load (transfer to house load operation).....	27
Figure A.3	– Example of simulated safety bus voltages, double open phase condition in the 400 kV line to the unit transformer	28
Table B.1	– Example 1.....	29
Table B.2	– Example 2.....	30
Table B.3	– Example 3.....	31

INTERNATIONAL ELECTROTECHNICAL COMMISSION

NUCLEAR POWER PLANTS – INSTRUMENTATION, CONTROL AND ELECTRICAL POWER SYSTEMS – REQUIREMENTS FOR STATIC UNINTERRUPTIBLE DC AND AC POWER SUPPLY SYSTEMS

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61225 has been prepared by subcommittee 45A: Instrumentation, control and electrical power systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation.

This fourth edition cancels and replaces the third edition published in 2019. This edition constitutes a technical revision.

The third edition included the following significant technical changes with respect to the previous edition:

- a) the principal objective of this edition is to address the requirements on the static uninterruptible power supplies in nuclear power plants;
- b) in addition to Instrumentation and Control (I&C) power supplies include all static uninterruptible power supplies;
- c) emphasize that the static uninterruptible power supplies shall protect the connected equipment (loads) from transients on the on-site AC distribution system (the immunity concept);

- d) in accordance with the defence-in-depth concept, this standard applies to static uninterruptible power supplies for all equipment, not only for equipment important to safety, with a graded approach to verification and validation;
- e) addition of the requirement that, when batteries are connected in parallel under abnormal operating conditions, they shall be properly protected with isolation devices to avoid any failure that may impair more than one division of the uninterruptible power supply.

The fourth edition expands and clarifies the requirements for static uninterruptible DC and AC power supply systems to ease the application in SMRs and passive designs.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
45A/1235/FDIS	45A/1250/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

a) Technical background, main issues and organization of the standard

The 1993 issue of IEC 61225 was developed for specifying the requirements relevant to the design of electrical supplies for I&C systems in nuclear power plants. Considering the experience gathered worldwide on this subject, in 2003 working group A2 recommended a revision to this standard so that a new revision, IEC 61225 Ed. 2 (2005), could be consistently integrated into the SC 45A standard series. In 2015, working group A11 recommended a revision to this standard following the publication of the revision of IAEA SSG-34 and that the scope of the standard should cover static uninterruptible power supplies for all types of connected equipment. In 2022, working group A11 recommended a revision to this standard to ease the application to SMRs.

International operating experience with electrical supply systems in nuclear power plants has highlighted a number of supply voltage variations and malfunctions, such as:

- voltage perturbations due to disturbances on the internal AC distribution system (with origin off-site or on-site);
- voltage overshoot on loss of grid;
- open phase conditions (one or two phases);
- asymmetrical faults.

These types of perturbations can degrade the performance of static uninterruptible power supplies and ultimately result in failure of connected equipment.

One of the objectives of the uninterruptible power supplies is to protect the connected equipment from voltage variations on the on-site AC distribution system (the immunity concept). The power supplies shall also guarantee an output voltage with specified magnitude and waveform (in case of AC) to connected loads. The power supplies shall have the capacity to supply the relevant loads during a specified time regardless of any voltage variations on the on-site AC distribution system.

Examples of voltage and frequency variations in the incoming feeder to the supplies can be found in informative Annex A. Examples of specifications for static uninterruptible power supplies can be found in informative Annex B. Requirements for SMRs and passive designs can be found in Annex C.

This standard is applicable to the design of static uninterruptible electrical power supplies in new nuclear power plants (including SMRs and other passive designs) when design work is initiated after the publication of this standard. It also serves as a reference for upgrading and modernizing existing nuclear power plants.

b) Situation of the current standard in the structure of the SC 45A standard series

IEC 61225 is a second level document specifically addressing the particular topic of requirements for electrical supplies.

For more details on the structure of the SC 45A standard series, see item d) of this introduction.

c) Recommendations and limitations regarding the application of this standard

This standard is to be applied in conjunction with IEC 61513, IEC 60709, IEC 60880, IEC 62138, IEC 62855 and IEC 63046 (to be published).

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

The top-level documents of the IEC SC 45A standard series are IEC 61513 and IEC 63046. IEC 61513 provides general requirements for I&C systems and equipment that are used to perform functions important to safety in NPPs. IEC 63046 provides general requirements for electrical power systems of NPPs; it covers power supply systems including the supply systems of the I&C systems. IEC 61513 and IEC 63046 are to be considered in conjunction and at the same level. IEC 61513 and IEC 63046 structure the IEC SC 45A standard series and shape a complete framework establishing general requirements for instrumentation, control and electrical systems for nuclear power plants.

IEC 61513 and IEC 63046 refer directly to other IEC SC 45A standards for general topics related to categorization of functions and classification of systems, qualification, separation, defence against common cause failure, control room design, electromagnetic compatibility, cybersecurity, software and hardware aspects for programmable digital systems, coordination of safety and security requirements and management of ageing. The standards referenced directly at this second level should be considered together with IEC 61513 and IEC 63046 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 or by IEC 63046 are standards related to specific equipment, technical methods, or specific activities. Usually these documents, which make reference to second-level documents for general topics, can be used on their own.

A fourth level extending the IEC SC 45 standard series, corresponds to the Technical Reports which are not normative.

The IEC SC 45A standards series consistently implements and details the safety and security principles and basic aspects provided in the relevant IAEA safety standards and in the relevant documents of the IAEA nuclear security series (NSS). In particular this includes the IAEA requirements SSR-2/1, establishing safety requirements related to the design of nuclear power plants (NPPs), the IAEA safety guide SSG-30 dealing with the safety classification of structures, systems and components in NPPs, the IAEA safety guide SSG-39 dealing with the design of instrumentation and control systems for NPPs, the IAEA safety guide SSG-34 dealing with the design of electrical power systems for NPPs and the implementing guide NSS17 for computer security at nuclear facilities. The safety and security terminology and definitions used by SC 45A standards are consistent with those used by the IAEA.

IEC 61513 and IEC 63046 have adopted a presentation format similar to the basic safety publication IEC 61508 with an overall life-cycle framework and a system life-cycle framework. Regarding nuclear safety, IEC 61513 and IEC 63046 provide the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector. In this framework IEC 60880, IEC 62138 and IEC 62566 correspond to IEC 61508-3 for the nuclear application sector. IEC 61513 and IEC 63046 refer to ISO as well as to IAEA GS-R part 2 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA). At level 2, regarding nuclear security, IEC 62645 is the entry document for the IEC/SC 45A security standards. It builds upon the valid high level principles and main concepts of the generic security standards, in particular ISO/IEC 27001 and ISO/IEC 27002; it adapts them and completes them to fit the nuclear context and coordinates with the IEC 62443 series. At level 2, IEC 60964 is the entry document for the IEC/SC 45A control rooms standards and IEC 62342 is the entry document for the ageing management standards.

NOTE 1 It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, process energy hazards) international or national standards would be applied.

NUCLEAR POWER PLANTS – INSTRUMENTATION, CONTROL AND ELECTRICAL POWER SYSTEMS – REQUIREMENTS FOR STATIC UNINTERRUPTIBLE DC AND AC POWER SUPPLY SYSTEMS

1.Scope

This document specifies the performance and the functional characteristics of the low voltage static uninterruptible power supply (SUPS) systems in a nuclear power plant and, for applicable parts, in general for nuclear facilities. An uninterruptible power supply is an electrical equipment which draws electrical energy from a source, stores it and maintains supply in a specified form by means inside the equipment to output terminals. A static uninterruptible power supply (SUPS) has no rotating parts to perform its functions.

The specific design requirements for the components of the power supply system are covered by IEC standards and standards listed in the normative references and are otherwise outside the scope of this document.

2. Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60146-1-1, *Semiconductor converters – General requirements and line commutated converters – Part 1-1: Specification of basic requirements*

IEC 60146-2, *Semiconductor converters – Part 2: Self-commutated semiconductor converters including direct d.c. converters*

IEC 60364-4-41, *Low voltage electrical installations – Part 4.41: Protection for safety – Protection against electric shock*

IEC 60709, *Nuclear power plants – Instrumentation, control and electrical power systems important to safety – Separation*

IEC/IEEE 60780-323, *Nuclear power plants – Electrical equipment important to safety – Qualification*

IEC 60880, *Nuclear power plants – Instrumentation and control systems important to safety – Software aspects for computer-based systems performing category A functions*

IEC 60980, *Recommended practices for seismic qualification of electrical equipment of the safety system for nuclear generating stations*

IEC 61000 (all parts), *Electromagnetic compatibility (EMC)*

IEC 61508 (all parts), *Functional safety of electrical/electronic/programmable electronic safety-related systems*

IEC 61513, *Nuclear power plants – Instrumentation and control important to safety – General requirements for systems*

IEC 62003, *Nuclear power plants – Instrumentation and control important to safety – Requirements for electromagnetic compatibility testing*

IEC 62040 (all parts), *Uninterruptible power systems (UPS)*

IEC 62138, *Nuclear power plants – Instrumentation and control systems important to safety – Software aspects for computer-based systems performing category B or C functions*

IEC 62566, *Nuclear power plants – Instrumentation and control important to safety – Development of HDL-programmed integrated circuits for systems performing category A functions*

IEC 62566-2, *Nuclear power plants – Instrumentation and control important to safety – Development of HDL-programmed integrated circuits – Part 2: HDL-programmed integrated circuits for systems performing category B or C functions* (to be published)

3. Terms and definitions

For the purposes of this document, the following terms and definitions apply.

NOTE Other terms not defined below are defined in IAEA Safety Guides SSG-34 and SSG-39.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 anticipated operational occurrence

AOO

deviation of an operational process from normal operation that is expected to occur at least once during the operating lifetime of a facility but which, in view of appropriate design provisions, does not cause any significant damage to items important to safety or lead to accident conditions

[SOURCE: Source IAEA Safety Glossary, 2018 edition]

3.2 battery charger

electrical item used to convert AC into DC to charge batteries and to supply power to DC loads during normal operation

Note 1 to entry: The battery charger provides transformer isolation of the DC output from the AC input and is equipped with regulation and monitoring.

[SOURCE: IEEE 946, 2004]

3.3 common cause failure

CCF

failures of two or more structures, systems and components due to a single specific event or cause

[SOURCE: IAEA Safety Glossary, 2018 edition]

3.4

diversity

the presence of two or more independent (redundant) systems or components to perform an identified function, where the different systems or components have different attributes so as to reduce the possibility of common cause failure, including common mode failure

[SOURCE: IAEA Safety Glossary, 2018 edition]

3.5

division

collection of items, including their interconnections, that form one redundancy of a redundant system or safety group

Note 1 to entry: Divisions may include multiple channels.

Note 2 to entry: Designation that enables the establishment and maintenance of physical, electrical, and functional independence from other redundant sets of items.

[SOURCE: IAEA SSG-39, 2016]

3.6

Important to safety

an item that is part of a *safety group* and/or whose malfunction or *failure* could lead to *radiation exposure* of the *site personnel* or *members of the public*.

[SOURCE: IAEA SSG-39, 2018]

3.7

plant states

Operational states		Accident conditions		
Normal operation	Anticipated operational occurrences	Design basis accidents	Design extension conditions	
			Without significant fuel degradation	With core melting

[SOURCE: IAEA Safety Glossary, 2018 edition]

3.8

redundancy

provision of alternative (identical or diverse) structures, systems and components, so that any one can perform the required function regardless of the state of operation or failure of any other

[SOURCE: IAEA Safety Glossary, 2018 edition]

3.9

safety related system

system important to safety that is not part of a safety system

[SOURCE: IAEA Safety Glossary, 2018 edition]

3.10

safety system

system important to safety, provided to ensure the safe shutdown of the reactor or residual heat removal from the core, or to limit the consequences of anticipated operational occurrences and design basis accidents

[SOURCE: IAEA Safety Glossary, 2018 edition]