



DPC: 24 / 30493170 DC

BSI Group Headquarters

389 Chiswick High Road London W4 4AL

Tel: +44 (0)20 8996 9000

Fax: +44 (0)20 8996 7400

www.bsigroup.com

Date: 14 May 2024

Origin: International

Latest date for receipt of comments: 3 July 2024

Project No. 2024/01473

Responsible committee: CPL/72 Electrical control devices for household equipment and appliances

Interested committees:

Title: Draft BS EN 60730-2-5 Ed. 5.0 Automatic electrical controls -

Part 2-5: Particular requirements for automatic electrical burner control systems

Please notify the secretary if you are aware of any keywords that might assist in classifying or identifying the standard or if the content of this standard

- i) has any issues related to 3rd party IPR, patent or copyright
- ii) affects other national standard(s)
- iii) requires additional national guidance or information

**WARNING: THIS IS A DRAFT AND MUST NOT BE REGARDED OR USED AS A BRITISH STANDARD.
THIS DRAFT IS NOT CURRENT BEYOND 3 July 2024**

This draft is issued to allow comments from interested parties; all comments will be given consideration prior to publication. No acknowledgement will normally be sent. **See overleaf for information on the submission of comments.**

No copying is allowed, in any form, without prior written permission from BSI except as permitted under the Copyright, Designs and Patent Act 1988 or for circulation within a nominating organization for briefing purposes. Electronic circulation is limited to dissemination by e-mail within such an organization by committee members.

Further copies of this draft may be purchased from BSI Shop <http://shop.bsigroup.com> or from BSI Customer Services, Tel: +44(0) 20 8996 9001 or email cservices@bsigroup.com. British, International and foreign standards are also available from BSI Customer Services.

Information on the co-operating organizations represented on the committees referenced above may be obtained from <http://standardsdevelopment.bsigroup.com>

Responsible Committee Secretary: **Mr Simon Bounds (BSI)**Direct tel: **0208 996 7281**E-mail: simon.bounds@bsigroup.com

Introduction

This draft standard is based on national and international discussions. Your comments on this draft are invited and will assist in the preparation of the consequent standard.

For international standards, comments will be reviewed by the relevant UK national committee before sending the consensus UK vote and comments to the international committee, which will then decide appropriate action. If the international standard is approved, it is usual for the text to be published as a British Standard.

For national standards, comments will be reviewed by the relevant UK national committee and the resulting standards published as a British Standard.

UK Vote

Please indicate whether you consider the UK should submit a negative (with supporting technical reasons) or positive vote on this draft. Please indicate if you are aware of any reason why this draft standard should not be published as a British Standard.

Submission of Comments

- **Annotated drafts are not acceptable and will be rejected.**
- All comments should be submitted online at <https://standardsdevelopment.bsigroup.com/>. You will need to register in order to comment.

Template for comments and secretariat observations

Date: xx/xx/20xx	Document: ISO/DIS xxxx
------------------	------------------------

1	2	(3)	4	5	(6)	7
MB	Clause No./ Subclause No./Annex (e.g. 3.1)	Paragraph/Figure/ Table/Note	Type of comment	Commend (justification for change) by the MB	Proposed change by the MB	Secretariat observations on each comment submitted
	3.1	Definition 1	ed	Definition is ambiguous and needs clarifying.	Amend to read '...so that the mains connector to which no connection...'	
	6.4	Paragraph 2	te	The use of the UV photometer as an alternative cannot be supported as serious problems have been encountered in its use in the UK.	Delete reference to UV photometer.	



72/1444/CD

COMMITTEE DRAFT (CD)

PROJECT NUMBER:

IEC 60730-2-5 ED5

DATE OF CIRCULATION:

2024-05-10

CLOSING DATE FOR COMMENTS:

2024-08-02

SUPERSEDES DOCUMENTS:

IEC TC 72 : AUTOMATIC ELECTRICAL CONTROLS

SECRETARIAT:

United States of America

SECRETARY:

Ms Grace Roh

OF INTEREST TO THE FOLLOWING COMMITTEES:

PROPOSED HORIZONTAL STANDARD:



Other TC/SCs are requested to indicate their interest, if any, in this CD to the secretary.

FUNCTIONS CONCERNED:

☐ EMC

☐ ENVIRONMENT

☐ QUALITY ASSURANCE

☐ SAFETY

This document is still under study and subject to change. It should not be used for reference purposes.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Recipients of this document are invited to submit, with their comments, notification of any local regulations or technical reasons that may exist and should be considered should this proposal proceed, recognizing that failure to address such requirements could result in the need for new or existing "In Some Countries" clauses. (SEE [AC/22/2007](#) OR [NEW GUIDANCE DOC](#)).

TITLE:

Automatic electrical controls - Part 2-5: Particular requirements for automatic electrical burner control systems

NOTE FROM TC/SC OFFICERS:

Copyright © 2024 International Electrotechnical Commission, IEC. All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.

CONTENTS

1	CONTENTS	1
2	1 Scope	7
3	2 Normative references	8
4	3 Terms and definitions	9
5	3.2 Definitions of types of control according to purpose	9
6	3.3 Definitions relating to the function of controls	10
7	3.5 Definitions of types of control according to construction	14
8	3.101 Definitions relating to the type of burner	14
9	4 General	15
10	4.3 General notes on tests	15
11	5 Required technical information	16
12	5.2 Methods of providing technical information	16
13	6 Protection against electric shock	18
14	6.1 General requirements	18
15	6.3 Capacitors	19
16	7 Provision for protective earthing	19
17	8 Terminals and terminations	19
18	8.2 Terminals and terminations for internal conductors	19
19	9 Constructional requirements	20
20	9.3 Actuation and operation	20
21	9.4 Actions	22
22	9.10 Equipment inlets and socket-outlets	24
23	9.11 Requirements during mounting, use, maintenance and servicing	24
24	9.13 Protective controls and components of protective control systems	24
25	9.101 Flame detector constructional requirements	24
26	9.102 Reset from lock-out function	25
27	9.103 Application requirements for the use of Type 2.AL burner control systems in warm air heating appliances (furnaces)	26
28	10 Threaded parts and connections	27
29	11 Creepage distances, clearances and distances through solid insulation	27
30	11.1 General	27
31	12 Components	27
32	13 Fault assessment on electronic circuits	27
33	13.1 Fault assessment for inherent safety	27
34	14 Moisture and dust resistance	28
35	15 Electric strength and insulation resistance	28
36	15.1 Insulation resistance	28
37	15.2 Electric strength	28
38	16 Heating	29
39	16.3 Not applicable	29
40	16.4 <i>Modficiation:</i>	29
41	16.6 <i>Modification:</i>	29
42	16.7 <i>Modification:</i>	29
43	17 Manufacturing deviation and drift	29
44	18 Environmental stress	29
45	18.2 Environmental stress of temperature	29

48	19	Endurance	29
49	19.1	General requirements	30
50	19.3	Thermal conditions for the tests	30
51	19.4	Manual and mechanical conditions for the tests	30
52	19.5	Dielectric strength requirements	30
53	19.6	Ageing test	30
54	19.7	Overvoltage test or overload test in all countries using an overload test of automatic action at accelerated rate	30
56	19.8	Test of automatic action at accelerated rate	30
57	19.9	Test of automatic action at slow rate	31
58	19.10	Overvoltage test or overload test in all countries that use the overload test of manual action at accelerated speed	31
60	19.11	Test of manual action at slow speed	31
61	19.12	Test of manual action at high speed which has multiple poles, and where polarity reversal occurs during the action	31
63	19.13	Test of manual action at accelerated speed	31
64	19.14	Evaluation of compliance	31
65	19.15	Test for particular purpose controls	31
66	20	Mechanical strength	33
67	20.2	Impact resistance	33
68	20.3	Free-standing controls	33
69	20.4	In-line cord controls	33
70	20.5	Pull-cord actuated controls	33
71	20.6	Foot actuated controls	33
72	20.8	Flexing - test	33
73	21	Resistance to heat, fire and tracking	33
74	22	Resistance to corrosion	33
75	23	Electromagnetic compatibility (EMC) requirements – Emission	33
76	24	Normal operation	33
77	25	Electromagnetic compatibility (EMC) requirements – Immunity	34
78	26	Abnormal operation tests	34
79	Annex H (normative)	Requirements related to functional safety	35
80	H.3	Terms and definitions	35
81	H.5	Information	35
82	H.13	Fault assessment on electronic circuits	35
83	H.17	Manufacturing deviation and drift	36
84	H.19	Endurance	38
85	H.25	Electromagnetic compatibility (EMC) requirements – Immunity	38
86	Annex J (normative)	Requirements for thermistor elements and controls using thermistors ..	45
87	Annex Q (informative)	Regional differences relevant for the member countries of Cenelec ..	46
88	Annex R (informative)	National differences relevant in the United States of America	47
89	R.2	Normative references	47
90	Annex S (informative)	National differences relevant in Japan	48
91	S.2	Normative references	48
92	Annex T (informative)	National differences relevant in Canada	49
93	T.2	Normative references	49
94	Annex AA (informative)	Functional characteristics of burner control systems to be specified by the relevant appliance standards, as applicable	50
96	Bibliography		51

97		
98	Figure 101 – Pulse spark generation.....	19
99	Figure 102 – Typical installation of the independent combustion air supply for room	
100	independent operation	26
101	Figure H.101 – Voltage variation test	40
102		
103	Table 1 – Required technical information and methods of providing these information	16
104	Table H.1 – Additional items to Table 1.....	35
105	Table H.101 – Timing of short-term supply voltage variations	39
106	Table H.102 – Test levels for electrostatic discharge	42
107	Table AA.1 – Functional characteristics of burner control systems to be specified by the	
108	relevant appliance standards, as applicable	50
109		

INTERNATIONAL ELECTROTECHNICAL COMMISSION

AUTOMATIC ELECTRICAL CONTROLS –

Part 2-5: Particular requirements for
automatic electrical burner control systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60730-2-5 has been prepared by IEC technical committee 72: AUTOMATIC ELECTRICAL CONTROLS. It is an International Standard.

This 5.0 edition cancels and replaces the 4.2 edition published in 2013, Amendment 1:2017 and Amendment 2:2020. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

Adoption to IEC 60730-1 Ed.6.0 with all of its significant changes to IEC 60730-1 fifth edition:2013, including Amendment 1:2015 and Amendment 2:2020.

The text of this International Standard is based on the following documents:

Draft	Report on voting
XX/XX/FDIS	XX/XX/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

160 The language used for the development of this International Standard is English.

161 This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in
162 accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at
163 www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in
164 greater detail at www.iec.ch/publications.

165 A list of all parts of the IEC 60730 series, under the general title: AUTOMATIC ELECTRICAL CONTROL,
166 can be found on the IEC website.

167 This part 2-5 is intended to be used in conjunction with IEC 60730-1. It was established on the basis
168 of the sixth edition of that standard. Consideration may be given to future editions of, or amendments
169 to, IEC 60730-1.

170 This part 2-5 supplements or modifies the corresponding clauses in IEC 60730-1, so as to convert
171 that publication into the IEC standard: Particular requirements for electric actuators.

172 Where this part 2-5 states "addition", "modification" or "replacement", the relevant requirement, test
173 specification or explanatory matter in part 1 should be adapted accordingly.

174 Where no change is necessary part 2-5 indicates that the relevant clause or subclause applies.

175 In the development of a fully international standard it has been necessary to take into consideration
176 the differing requirements resulting from practical experience in various parts of the world and to
177 recognize the variation in national electrical systems and wiring rules.

178 The reader's attention is drawn to the fact that Q, Annex R, Annex S and Annex T list all of the "in-
179 some-country" clauses on differing practices of a less permanent nature relating to the subject of this
180 document.

181 In this publication:

182 1) The following print types are used:

- 183 – requirements proper: in roman type;
- 184 – *test specifications: in italic type*;
- 185 – explanatory matter: in smaller roman type.
- 186 – Defined terms: **bold type**.

187 2) Subclauses, notes or items which are additional to those in Part 1 are numbered starting from
188 101, additional annexes are lettered AA, BB, etc.

189 The committee has decided that the contents of this document will remain unchanged until the stability
190 date indicated on the IEC website under webstore.iec.ch in the data related to the specific document.
191 At this date, the document will be

- 192 • reconfirmed,
 - 193 • withdrawn,
 - 194 • replaced by a revised edition, or
 - 195 • amended.
- 196

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

197

AUTOMATIC ELECTRICAL CONTROLS –

Part 2-5: Particular requirements for automatic electrical burner control systems

1 Scope

This clause of Part 1 is replaced by the following:

This document applies to automatic electrical **burner control systems** for the **automatic control** of burners for oil, gas, coal or other combustibles intended to be used

- for household and similar use,
- in shops, offices, hospitals, farms and commercial and industrial applications.

NOTE 1 Throughout this document, where it can be used unambiguously, the word "system" means "burner control system" and "systems" means "burner control systems".

- for equipment that is used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications;

NOTE 2 Throughout this document, the word "equipment" means "appliance and equipment."

EXAMPLE 2 Controls for commercial catering, heating and air-conditioning equipment.

- that are **smart enabled controls**;

EXAMPLE 3 Remote interfaces/control of burner operations.

- that are AC or DC powered controls with a rated voltage not exceeding 690 V AC or 600 V DC;
- used in, on, or in association with equipment that use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof;
- utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs;
- using NTC or **PTC thermistors** and to discrete **thermistors**, requirements for which are contained in Annex J;
- that are mechanically or electrically operated, responsive to or controlling such characteristics as temperature, pressure, passage of time, humidity, light, electrostatic effects, flow, or liquid level, current, voltage, acceleration, or combinations thereof;
- as well as manual controls when such are electrically and/or mechanically integral with automatic controls.

NOTE 3 Requirements for manually actuated mechanical switches not forming part of an automatic control are contained in IEC 61058-1-1.

This document is applicable

- to a complete **burner control system**,
- to a separate **programming unit**,
- to a separate electronic high-voltage **ignition source**,
- to a separate **flame detector** and
- to a separate **high-temperature operation (HTO) detector**.
- to a **burner control system** intended to be used in warm air heating appliances (furnaces) where the appliance is equipped with an electromechanical differential pressure control to monitor the difference of the combustion air pressure (Type 2.AL). This pressure control provides a switch as an alternative to one of the two switching elements to directly de-energize the safety relevant terminals.

This document does not apply to thermoelectric flame supervision controls; thermoelectric flame supervision controls are covered by ISO 23551-6.

This document also applies to electrical **burner control systems** intended exclusively for industrial process applications e.g. those applications covered by ISO TC 244 (ISO 13577).

This document applies to controls powered by primary or secondary batteries, requirements for which are contained within the standard.

This document applies to

- the inherent safety of automatic electrical **burner control systems**, and
- functional safety of automatic electrical **burner control systems**,
- automatic electrical **burner control systems** where the performance (for example the effect of EMC phenomena) of the product can impair the overall safety and performance of the controlled system,
- the operating values, operating times, and operating sequences where such are associated with burner safety and to the testing of automatic electrical **burner control systems** used in, on, or in association with, burners.

NOTE 4 Requirements for specific **operating values**, **operating times** and **operating sequences** are given in the standards for appliances and equipment.

This document specifies the requirements for construction, operation and testing of automatic electrical **burner control systems** used in, on, or in association with an equipment.

This document applies also to systems

- incorporating electronic devices
- using NTC or PTC thermistors, additional requirements for which are contained in Annex J.
- to the electrical and functional safety of controls capable of receiving and responding to communications signals. The signals may be transmitted to or received from external units, connected wired or wireless, that may or may not be part of the burner control system.

This document does not

- take into account the response value of an automatic action of a control, if such a response value is dependent upon the method of mounting the control in the equipment. Where a response value is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer will apply.
- address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the control system.

2 Normative references

This clause of Part 1 is applicable except as follows:

Addition:

IEC 60068-2-6, *Environmental testing – Part 2: Tests – Test Fc: Vibration (sinusoidal)*

ISO/IEC 80079-20-1:2017, Explosive atmospheres – Part 20-1: Material characteristics for gas and vapour classification – Test methods and data

ISO 23551-6:2021, *Safety and control devices for gas burners and gas-burning appliances – Part 6: Thermoelectric flame supervision controls*

3 Terms and definitions

This clause of Part 1 is applicable except as follows:

3.2 Definitions of types of control according to purpose

3.2.19 Not applicable

Additional definitions:

3.2.101

burner control system

system which includes a programming unit, a flame detector or, if applicable, an HTO detector and may include an ignition source and/or ignition device and which monitors the operation of fuel burners

Note 1 to entry: The various functions of the system may be in one or more housings.

3.2.102

flame detector

device which provides the **programming unit** with a signal indicating the presence or absence of flame

Note 1 to entry: It includes the **flame sensor** and may include an amplifier and a relay for signal **transmission**. The amplifier and relay may be in its own housing or combined with the **programming unit**.

3.2.103

flame sensor

device which senses the flame and provides the input signal to the **flame detector** amplifier

Note 1 to entry: Examples are optical sensors and flame electrodes (flame rods).

3.2.104

ignition source

electrical or electronic system component which provides energy to an **ignition device**

Note 1 to entry: It may be separated from or incorporated in the **programming unit**. Examples are ignition transformers and electronic high-voltage generators.

3.2.105

ignition device

device mounted on or adjacent to a burner for igniting fuel at the burner

Note 1 to entry: Examples are **pilot** burners, spark electrodes and hot surface igniters.

3.2.106

programming unit

device which controls the burner **operation** in a declared sequence from start-up to shut-down within declared timings and in response to signals from regulating, limiting and monitoring devices

3.2.107

multitry system

system that allows more than one **valve open period** during its declared **operating sequence**

3.2.108

HTO detector

device which provides the **programming unit** with a signal indicating presence or absence of HTO

Note 1 to entry: It includes the **HTO-sensor** and may include an amplifier and a relay for signal **transmission**. The amplifier and relay may be in its own housing or combined with the **programming unit**.

3.2.109**HTO-sensor**

device which senses the temperature of a surface or a medium within the combustion chamber which is in direct contact with a flammable fuel-air mixture and provides a signal indicating presence or absence of **HTO**

3.2.110**auto-ignition temperature****AIT**

lowest temperature (of a surface) at which under specified test conditions an ignition of a flammable gas or vapour in mixture with air or air-inert gas occurs

[SOURCE: ISO/IEC 80079-20-1:2017,3.3]

"Note 1 to entry: Lowest temperature that ignites flammable gas without an additional external source of ignition like spark or arc"

3.2.111**high-temperature operation****HTO**

operation on the basis of **auto-ignition temperature** which assures ignition and burning of fuel

Note 1 to entry: **High-temperature operation** is used e.g. in fuel cells (IEC 62282-3-100) and in industrial furnaces and associated processing equipment (ISO 13577) where ignition and burning is detected by means of sensing the temperature.

3.3 Definitions relating to the function of controls**3.3.30****maximum temperature****T_{max}**

Modification: *Replace "switch head" by "burner control system."*

3.3.31 safety shut-down*Replacement:*

de-energization of the main fuel flow means as the result of the action of a limiter, a cut-out or the detection of an internal **fault** of the system

Note 1 to entry: **Safety shut-down** may include additional actions by the system.

*Add the following definitions***3.3.101****automatic recycle**

automatic repetition of the start-up procedure, without manual intervention, following loss of the supervised flame and subsequent fuel supply shutoff

3.3.102**controlled shut-down**

de-energization of the fuel flow means as a result of the opening of a control loop by a control device such as a **thermostat** leading the system to return to the **start position**

Note 1 to entry: **Controlled shut-down** may include additional actions by the system.

3.3.103**flame detector response time**

period of time between the loss of the sensed flame and the signal indicating the absence of flame

3.3.104**flame detector operating characteristics**

that function of the **flame detector** which indicates absence or presence of flame as the output signal of the **flame detector** relating to the input signal

Note 1 to entry: Normally the input signal is provided by a **flame sensor**.

3.3.104.1**signal for presence of flame****S₁**

minimum signal which indicates the presence of flame when there was previously no flame

3.3.104.2**signal for absence of flame****S₂**

maximum signal which indicates the loss of flame

Note 1 to entry: **S₂** is less than **S₁**.

3.3.104.3**maximum flame signal****S_{max}**

maximum signal which does not affect the timings or the sequence

3.3.104.4**signal for visible light flame simulation****S₃**

minimum signal which indicates the presence of flame during the visible light **flame simulation** test

Note 1 to entry: **S₃** is less than **S₂**.

3.3.105**self-checking flame detector**

flame detector which checks for correct **operation** of the **flame detector** and its associated electronic circuitry while the burner is in the **running position**

3.3.106**flame detector self-checking rate**

frequency of the self-checking function of the **flame detector** (in number of **operations** per unit of time)

3.3.107**flame failure lock-out time****flame failure response time**

period of time between the signal indicating absence of flame and **lock-out**

3.3.108**flame failure re-ignition time****relight time**

period of time between the signal indicating absence of flame and the signal to energize the **ignition device**, during which the fuel supply is not shut off

3.3.109**flame signal**

output signal of the **flame detector**

3.3.110**flame simulation**

condition which occurs when the **flame detector** indicates the presence of flame when in reality no flame is present

3.3.111**ignition time**

period of time during which the **ignition device** is energized

3.3.112**lock-out**

process in which the system goes into one of the following **lock-out** conditions, following **safety shut-down**

3.3.112.1**non-volatile lock-out**

condition such that a restart can only be accomplished by a manual **reset** of the system and by no other cause

3.3.112.2**volatile lock-out**

condition such that a restart can be accomplished by either a manual **reset** of the system or by an interruption of the power supply and its subsequent restoration

3.3.113**main flame establishing period**

period of time between the signal to energize the main fuel flow means and the signal indicating presence of the main burner flame

3.3.114**pilot flame establishing period**

period of time between the signal to energize the **pilot** fuel flow means and the signal indicating presence of the **pilot** flame

3.3.115**post-ignition time**

period of the **ignition time** between the signal indicating presence of flame and the signal to de-energize the **ignition device**

3.3.116**pre-ignition time**

period of the **ignition time** between the signal to ignite and the signal to energize the fuel flow means

3.3.117**proved igniter****proved igniter system**

system in which the fuel flow means is energized only after the availability of sufficient energy to ignite the fuel has been verified

Note 1 to entry: Examples are systems using spark supervision and those using proved hot surface igniters.

3.3.117.1**proved igniter operating value**

signal which indicates that the **proved igniter** has the energy to ignite the fuel

3.3.117.2**igniter proving time**

period of time between the signal to energize the **proved igniter** and the signal to energize the fuel flow means

3.3.117.3**igniter failure response time**

period of time between loss of the supervised **proved igniter** and the signal to de-energize the fuel flow means

3.3.118**purge time**

period during which air is introduced to displace any remaining air/fuel mixtures or products of combustion from the combustion zone and flue ways

Note 1 to entry: No fuel is admitted during this period.

3.3.118.1**post-purge time**

purge time that takes place immediately following the shutting off of the fuel supply

3.3.118.2**pre-purge time**

purge time that takes place between **initiation** of a burner control sequence and the admission of fuel to the burner

3.3.119**re-ignition****relight**

process by which, following loss of the **flame signal**, the **ignition device** will be re-energized without interruption of the fuel flow means

3.3.120**recycle time**

period of time between the signal to de-energize the fuel flow means following the loss of flame and the signal to begin a new start-up procedure

3.3.121**running position**

position denoting that the main burner flame is established and supervised, or the burner is in **HTO** and supervised

3.3.122**start position**

position which denotes that the system is not in the **lock-out** condition and has not yet received the **start signal**, but can proceed with the start-up sequence if required

3.3.123**start signal**

signal, for example, from a **thermostat**, which releases the system from its **start position**

3.3.124**start-up lock-out time**

period of time between the signal to energize the fuel flow means and **lock-out**

Note 1 to entry: For systems which control two separate fuel flow means, two different **start-up lock-out times** are possible (first and second **start-up lock-out times**).

3.3.125**waiting time**

period between the **start signal** and the signal to energize the **ignition device**

Note 1 to entry: For burners without fans, natural ventilation of the combustion chamber and the flue passages normally takes place during this time.

3.3.126**valve open period**

for **multitry systems**, the period of time between the signal to energize the fuel flow means, and the signal to de-energize the fuel flow means, if proof of the supervised burner flame is not established

Note 1 to entry: In the USA and Canada, this period is referred to as the "trial-for-ignition period."

3.3.127**valve sequence period**

for **multitry systems**, the sum of all valve opening periods prior to **lock-out**, if proof of the supervised burner flame is not established

3.3.128**system restart**

process by which, after a **safety shut-down**, a full start-up procedure is automatically repeated

3.3.129**reset from lock-out function**

function that provides **reset** from **lock-out** allowing the system to attempt a restart

Note 1 to entry: The **reset** function may be performed by various electric/electronic (mobile) devices.

3.3.130**HTO detector response time**

period of time between the temperature falling below the defined temperature limit for **HTO** and the signal indicating the absence of **HTO**

3.3.131**HTO detector operating characteristics**

that function of the **HTO detector** which indicates absence or presence of **HTO** as the output signal of the **HTO detector** relating to the input signal

Note 1 to entry: Normally the input signal is provided by a **HTO-sensor**.

3.3.132**HTO response time**

period of time between the signal indicating absence of **HTO** and proceeding to **safety shut-down** or to switch over to flame supervision

3.3.133**HTO signal**

output signal of the **HTO detector**

3.5 Definitions of types of control according to construction

Additional definitions:

3.5.101**system for permanent operation**

system which is intended to remain in the **running position** for longer than 24 h without interruption

3.5.102**system for non-permanent operation**

system which is intended to remain in the **running position** for less than 24 h

Additional definitions:

3.101 Definitions relating to the type of burner**3.101.1****continuous ignition**

type of ignition which, once placed in **operation**, is intended to remain energized continuously until it is manually interrupted