

Addenda to the Third Edition
ANSI Z21.69-2009 • CSA 6.16-2009

**American National Standard/
CSA Standard for
Connectors for movable
gas appliances**

*ANSI Z21.69a-2012
CSA 6.16a-2012*

Part I: Construction

1.7 Instructions

1.7.2

The instructions shall include, as a minimum, statements to the effect that:

- a. The gas outlet must be in the same room as the gas-fired equipment and the connector must not be concealed within or run through any wall, floor or partition.
- b. All parts of the union supplied with the connector must be used, and no attempt shall be made to assemble union nuts directly to pipe threads.
- c. The connector must not be kinked, twisted or torqued.

NOTE: Changes, other than editorial, are denoted by a vertical line in the margin.

Approved February 23, 2012 by American National Standards Institute, Inc. Approved February 6, 2012 by the Interprovincial Gas Advisory Council. Effective in Canada August 1, 2013.

Standard Developers

CSA America, Inc.
(operating as CSA Group)
8501 East Pleasant Valley Road
Cleveland, Ohio 44131

Canadian Standards Association
(operating as CSA Group)
5060 Spectrum Way, Suite 100
Mississauga, Ontario, Canada L4W 5N6

June 2012

Page 1 of 2

© 2012 CSA Group

To purchase standards and related publications, visit our Online Store at shop.csa.ca or call toll-free 1-800-463-6727 or 416-747-4044.

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

- d. Connectors are for use only on piping systems having fuel gas pressures not in excess of $1\frac{1}{2}$ psi (3.5 kPa).
 - e. For movable appliance installation (e.g., appliances factory-equipped with casters), flexing and bending should be limited to the needs of pulling and pushing the appliance in and out for cleaning, maintenance or installation.
 - f. Contact with foreign objects or substances must be avoided.
 - g. An accessible manual shutoff valve must be installed at the outlet of the gas supply piping system upstream of the connector.
 - h. The final assembly must be tested for leaks. CAUTION: Matches, candles, open flame or other sources of ignition shall not be used for this purpose. Leak test solutions may cause corrosion. Water-rinse tested connections after leak test. To check gas supply piping system for leakage, see the *National Fuel Gas Code, ANSI Z223.1/NFPA 54*, or *Natural Gas and Propane Installation Code, CSA B149.1*.
 - i. The connector complies with the *Standard for Connectors for Movable Gas Appliances, ANSI Z21.69 • CSA 6.16*.
 - j. The following warning in a 10-point font: "Connector is for use on the original appliance at the original location only. DO NOT REUSE connector when an appliance is being replaced or moved to a different location." Moving the appliance within the same kitchen footprint is acceptable for using the same connector.
- «Le connecteur convient uniquement à l'appareil d'origine, et à l'emplacement d'origine. NE PAS UTILISER le connecteur avec un appareil de remplacement ou si l'appareil est installé ailleurs.»

To purchase standards and related publications, visit our Online Store at shop.csa.ca or call toll-free 1-800-463-6727 or 416-747-4044.

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.