

Addenda to the Second Edition
ANSI Z83.20-2008 • CSA 2.34-2008 and
ANSI Z83.20a-2010 • CSA 2.34a-2010

**American National Standard/
CSA Standard for
Gas-Fired Low Intensity
Infrared Heaters**

ANSI Z83.20b-2011
CSA 2.34b-2011

Part I: Construction

1.26 MARKING

1.26.8

Each heater shall bear one of the following markings on Class IIIA marking material, as applicable:

- a. "For indoor installation only. Not for use in residential dwellings."
- b. "For outdoor installation only. Not for use in residential dwellings."
- c. "For either indoor or outdoor installation. Not for use in residential dwellings."
- d. "For outdoor portable use only. Not for use in residential dwellings."

NOTE: Changes, other than editorial, are denoted by a vertical line in the margin.

Approved September 10, 2010 by American National Standards Institute, Inc.
Approved February 8, 2011 by Interprovincial Advisory Council Effective in Canada August 1, 2012

Standards Developer

CSA America, Inc.
8501 East Pleasant Valley Road
Cleveland, Ohio 44131

Canadian Standards Association
5060 Spectrum Way, Suite 100
Mississauga, Ontario, Canada L4W 5N6

Published - March 2011

Page 1 of 2

Copyright © 2011

Canadian Standards Association

Permission is granted to republish material herein in laws or ordinances, and in regulations, administrative orders, or similar documents issued by public authorities. Those desiring permission for other republication should consult Canadian Standards Association at 5060 Spectrum Way, Suite 100, Mississauga, Ontario, Canada L4W 5N6.

Copyright © 2011

CSA America, Inc.

Permission is granted to republish material herein in laws or ordinances, and in regulations, administrative orders, or similar documents issued by public authorities. Those desiring permission for other republication should consult CSA America, Inc. at 8501 East Pleasant Valley Road, Cleveland, Ohio 44131.

Exhibit B

Items Unique To Canada

B.1 Bilingual Instructions And Marking

B.5.1

The units of measure required on printed instructions and marking shall include the SI (metric) values as a minimum.

B.5.2

All instructions and marking provisions specified in the standard shall be provided in a form that is easily understood in both English and French. The following clauses make reference to specific Instructions and Markings and are listed below in both English and French:

1.27.9-a	"For indoor installation only. Not for use in residential dwellings."	«Installation à l'intérieur seulement. Ne pas installer dans un logement.»
1.27.9-b	"For outdoor installation only. Not for use in residential dwellings."	«Installation à l'extérieur seulement. Ne pas installer dans un logement.»
1.27.9-c	"For either indoor or outdoor installation. Not for use in residential dwellings."	«Installation à l'intérieur ou à l'extérieur. Ne pas installer dans un logement.»
1.27.9-d	"For outdoor portable use only. Not for use in residential dwellings."	«Installation portable à l'extérieur seulement. Ne pas installer dans un logement»

Permission is granted to republish material herein in laws or ordinances, and in regulations, administrative orders, or similar documents issued by public authorities. Those desiring permission for other republication should consult Canadian Standards Association at 5060 Spectrum Way, Suite 100, Mississauga, Ontario, Canada L4W 5N6.

Permission is granted to republish material herein in laws or ordinances, and in regulations, administrative orders, or similar documents issued by public authorities. Those desiring permission for other republication should consult CSA America, Inc. at 8501 East Pleasant Valley Road, Cleveland, Ohio 44131.