ANSI/AHRI Standard 1200 (I-P)

2013 Standard for

Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets

Approved American National Standard
ANSI

AHRI
AIR-CONDITIONING, HEATING, & REFRIGERATION INSTITUTE
we make life better™

2111 Wilson Boulevard, Suite 500
Arlington, VA 22201, USA
www.ahrinet.org
PH 703.524.8800
FX 703.562.1942

Approved by ANSI on October 1, 2013

AVA Documents
Document Sharing Hub

Full document details: AHRI Standard 1200-2013 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets

IMPORTANT

SAFETY DISCLAIMER

AHRI does not set safety standards and does not certify or guarantee the safety of any products, components or systems designed, tested, rated, installed or operated in accordance with this standard/guideline. It is strongly recommended that products be designed, constructed, assembled, installed and operated in accordance with nationally recognized safety standards and code requirements appropriate for products covered by this standard/guideline.

AHRI uses its best efforts to develop standards/guidelines employing state-of-the-art and accepted industry practices. AHRI does not certify or guarantee that any tests conducted under its standards/guidelines will be non-hazardous or free from risk.

Note:

This standard supersedes ANSI/AHRI Standard 1200-2010.
For SI ratings, see ANSI/AHRI Standard 1201 (SI) – 2013.

The following certification program ratings are verified by test:

- Total Daily Energy Consumption or Calculated Daily Energy Consumption (kW·h per day)

Price $10.00 (Members) $20.00 (Non-Members)
Printed in U. S.A.

©Copyright 2013, by Air-Conditioning, Heating and Refrigeration Institute
Registered United States Patent and Trademark Office

Documents Document Sharing Hub
Full document details: AHRI Standard 1200-2013 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets

TABLE OF CONTENTS

SECTION		PAGE
Section 1.	Purpose	1
Section 2.	Scope	1
Section 3.	Definitions	1
Section 4.	Test Requirements	4
Section 5.	Rating Requirements for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets	4
Section 6.	Rating Requirements for Self-contained Commercial Refrigerated Display Merchandisers and Storage Cabinets	8
Section 7.	Symbols and Subscripts	9
Section 8.	Minimum Data Requirements for Published Ratings	10
Section 9.	Marking and Nameplate Data	10
Section 10.	Conformance Conditions	10

TABLES

Table 1.	EER for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets	6
Table 2.	Presentation of Data for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets	11
Table 3.	Presentation of Data for Self-contained Commercial Refrigerated Display Merchandisers and Storage Cabinets	11

Documents
Document Sharing Hub
Full document details: AHRI Standard 1200-2013 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets

APPENDICES

Appendix A. References - Normative 12

Appendix B. References - Informative 12

Appendix C. Commercial Refrigerated Display Merchandiser and Storage Cabinet Load Line Volume Calculation - Normative 13

Appendix D. Commercial Refrigerated Display Merchandiser Total Display Area (TDA) Calculation - Normative 16

Appendix E. Example – Energy Performance Representation for a Remote Commercial Refrigerated Display Merchandiser or Storage Cabinet - Informative 22

Appendix F. Example – Energy Performance Representation for a Self-contained Commercial Refrigerated Display Merchandiser or Storage Cabinet - Informative 25

TABLES FOR APPENDICES

Table E1. Sample Presentation of Data for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets 24

Table F1. Sample Presentation of Data for Self-contained Commercial Refrigerated Display Merchandisers and Storage Cabinets 26

FIGURES FOR APPENDICES

Figure C1.1. Sample Isometric View of Commercial Refrigerated Display Merchandisers for Illustrating Length of Refrigerated Space 13

Figure C1.2. Sample Cross Sections of Commercial Refrigerated Display Merchandisers for Load Line Volume Calculation 14

Figure C2. Sample Cross Section of Commercial Refrigerated Storage Cabinets for Volume Calculation 15

Figure D1. Vertical Open Multi-deck 16

Figure D2. Vertical Open Multi-deck with Transparent Front 16

Figure D3. Semi-vertical Open Multi-deck 17

Figure D4. Semi-vertical Open Multi-deck with Transparent Front 17

AVA Documents
Document Sharing Hub

Full document details: AHRI Standard 1200-2013 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets

Figure D5. Horizontal Open Single-deck 17
Figure D6. Horizontal Open Single-deck with Transparent Front 17
Figure D7. Service Over Counter with Flat Transparent Front 18
Figure D8. Service Over Counter with Curved Transparent Front....18
Figure D9. Horizontal Open Single-deck Island 18
Figure D10. Horizontal Open Single-deck Island with Transparent Wall 18
Figure D11. Horizontal Open Single-deck Island with Transparent Walls....19
Figure D12. Vertical Closed Multi-deck with Transparent Doors 19
Figure D13. Vertical End Wall with Transparent Section....19
Figure D14. Semi-vertical End Wall with Transparent Section 19
Figure D15. Horizontal Single-deck and Single-deck Island End Wall with Transparent Section....20
Figure D16. Service Over Counter End Wall with Transparent Section....20
Figure D17. Example TDA for Unique Geometries....20
Figure D18. Radius Cases with Transparent Sides....21

Documents
Document Sharing Hub
Full document details: AHRI Standard 1200-2013 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets

PERFORMANCE RATING OF COMMERCIAL REFRIGERATED DISPLAY MERCHANDISERS AND STORAGE CABINETS

Section 1. Purpose

1.1 *Purpose*. The purpose of this standard is to establish for Commercial Refrigerated Display Merchandisers and Storage Cabinets: definitions; test requirements; rating requirements; symbols and subscripts; minimum data requirements for Published Ratings; marking and nameplate data and conformance conditions.

1.1.1 *Intent*. This standard is intended for the guidance of the industry, including manufacturers, engineers, installers, contractors and users. The values reported using this standard allow comparison of energy consumption within each of the following product categories: Remote Commercial Refrigerated Display Merchandisers, Remote Commercial Refrigerated Storage Cabinets, Self-contained Commercial Refrigerated Display Merchandisers and Self-contained Commercial Refrigerated Storage Cabinets.

1.1.2 *Review and Amendment*. This standard is subject to review and amendment as technology advances.

Section 2. Scope

2.1 *Scope*. This standard applies to the following manufacturers' standard catalog Commercial Refrigerated Display Merchandisers and Storage Cabinets, provided that the cases are equipped and designed to work with electrically driven, direct expansion type systems:

2.1.1 Self-contained and Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets
2.1.2 Open and Closed Commercial Refrigerated Display Merchandisers

2.2 *Exclusions.* This standard does not apply to the following:

2.2.1 Refrigerated vending machines
2.2.2 Ice makers
2.2.3 Soft serve extruders
2.2.4 Secondary coolant applications

Section 3. Definitions

All terms in this document will follow the standard industry definitions in the ASHRAE Wikipedia website (http://wiki.ashrae.org/index.php/ASHRAEwiki) unless otherwise defined in this section.

3.1 *Anti-condensate Energy Consumption (AEC).* The Total Daily Energy Consumption used in condensate removal on the outside of the Commercial Refrigerated Display Merchandiser or Storage Cabinet, which typically includes fan and condensate heater energy expressed in kW·h per day.

3.2 *Calculated Daily Energy Consumption (CDEC).* This is a value for Remote Commercial Refrigerated Display Merchandisers or Storage Cabinets based upon the requirements of this standard expressed in kW·h per day.

3.3 *Commercial Refrigerated Display Merchandiser*. A cabinet cooled by a refrigerating system for displaying chilled and/or frozen food to be maintained within prescribed temperature limits.

3.3.1 *Closed Commercial Refrigerated Display Merchandiser*. A refrigerated display merchandiser where food is accessible for removal by opening or moving doors or panels.

Documents
Document Sharing Hub
Full document details: AHRI Standard 1200-2013 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets

3.3.2 *Open Commercial Refrigerated Display Merchandiser*. A refrigerated display merchandiser where food is accessible for removal without opening or moving doors or panels.

3.3.3 *Remote Commercial Refrigerated Display Merchandiser*. A refrigerated display merchandiser that has a remote condensing unit.

3.3.4 *Self-contained Commercial Refrigerated Display Merchandiser*. A refrigerated display merchandiser that has a completely factory assembled and factory tested refrigerating system in which all of the refrigerant-containing parts are permanently connected at the factory.

3.3.5 *Service Over the Counter (SOC).* A commercial refrigerator or freezer equipped with sliding or hinged doors in the back intended for use by sales personnel, and with glass or other transparent material in the front for displaying merchandise. The equipment has a height no greater than 66 inches and is intended to serve as a counter for transactions between sales personnel and customers.

3.4 *Commercial Refrigerated Storage Cabinet.* A closed cabinet cooled by a refrigerating system for storing chilled and/or frozen food to be maintained within prescribed temperature limits.

3.4.1 *Remote Commercial Refrigerated Storage Cabinet*. A refrigerated storage cabinet that has a remote condensing unit.

3.4.2 *Self-contained Commercial Refrigerated Storage Cabinet.* A refrigerated storage cabinet that has a completely factory assembled and factory tested refrigerating system in which all of the refrigerant-containing parts are permanently connected at the factory.

3.5 *Compressor Energy Consumption (CEC).* The energy consumed by the compressor expressed in kW·h per day.

3.6 *Condensate Evaporator Pan Energy Consumption (PEC).* The amount of heat energy required to change condensate from liquid to a vapor in the evaporator pan expressed in kW·h per day.

3.7 *Defrost Energy Consumption (DEC).* The energy consumed during defrost cycles expressed in kW·h per day.

3.8 *Dew Point.* Refrigerant vapor saturation temperature at a specified pressure expressed in °F .

3.8.1 *Adjusted Dew Point.* An adjusted temperature lower than actual Dew Point temperature expressed in °F , resulting from suction line pressure losses, equal to saturated suction temperature at the compressor.

3.9 *Energy Efficiency Ratio (EER).* A ratio of the cooling capacity in Btu/h to the power input values in watts at any given set of Rating Conditions expressed in Btu/(W·h).

3.10 *Fan Energy Consumption (FEC).* The energy consumed by fan motors expressed in kW·h per day.

3.11 *Integrated Average Temperature.* The average of all test package measurements taken during the test expressed in °F .

3.12 *Lighting Energy Consumption (LEC).* The energy consumed by lighted shelves and lighting internal to the refrigerated display merchandiser or storage cabinet expressed in kW·h per day.

3.13 *Product Temperature*. Commercial Refrigerated Display Merchandisers or Storage Cabinets shall be tested with one or more of the following Integrated Average Temperatures:

3.13.1 *Ice Cream Applications.* Commercial Refrigerated Display Merchandisers and Storage Cabinets intended specifically for the storage, display or dispensing of ice cream and so labeled by the manufacturer shall have an Integrated Average Product Temperature of -15.0°F ± 2.0°F.

Documents
Document Sharing Hub
Full document details: AHRI Standard 1200-2013 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets

3.13.2 *Low Temperature Applications.* Commercial Refrigerated Display Merchandisers and Storage Cabinets intended for Low Temperature Applications to include storing and displaying frozen foods, as well as ice cream products, shall have an Integrated Average Product Temperature of 0.0°F ± 2.0°F.

3.13.3 *Medium Temperature Applications.* Commercial Refrigerated Display Merchandisers and Storage Cabinets intended for Medium Temperature Applications, shall have an Integrated Average Temperature of 38°F ± 2.0°F.

3.13.4 *Application Product Temperature*. This test allows Integrated Average Temperatures other than 3.13.1, 3.13.2 and 3.13.3.

Note: Requirement 3.13.1 is defined to address products designed and labeled explicitly for Ice Cream Applications as defined in the United States Code of Federal Regulations 10 CFR Part 431 Section IV.B.5. Freezer display merchandisers and storage cabinets that are designed for use in both low temperature (frozen food) and Ice Cream Applications by making set point adjustments will be rated as a low temperature application (3.13.2).

3.14 *Published Rating.* A statement of the assigned values of those performance characteristics, under stated Rating Conditions, by which a unit may be chosen for its application. The term Published Rating includes the rating of all performance characteristics shown on the unit or published in specifications, advertising or other literature controlled by the manufacturer, at stated Rating Conditions.

3.14.1 *Application Rating*. A rating based on tests performed at application Rating Conditions (other than Standard Rating Conditions).

3.14.2 *Standard Rating*. A rating based on tests performed at Standard Rating Conditions.

3.15 *Rating Conditions.* Any set of operating conditions under which a single level of performance results and which causes only that level of performance to occur.

3.15.1 *Standard Rating Conditions.* Rating Conditions used as the basis of comparison for performance characteristics.

3.16 *"Shall"* or "*Should"*. "Shall" or "should" shall be interpreted as follows:

3.16.1 *Shall*. Where "shall" or "shall not" is used for a provision specified, that provision is mandatory if compliance with the standard is claimed.

3.16.2 *Should*. "Should" is used to indicate provisions which are not mandatory but which are desirable as good practice.

3.17 *Total Daily Energy Consumption (TDEC).* A calculated energy consumption value for Self-contained Commercial Refrigerated Display Merchandisers and Storage Cabinets based upon the requirements of this standard expressed in kW·h per day.

3.18 *Total Display Area (TDA).* The sum of the projected area(s) for visible product expressed in ft^2.

3.18.1 *Transparent Surface*. A transparent surface shall have a minimum of 65% light transmission or 65% clear surface. For example, silk-screened glass may or may not be transparent depending on the amount of silkscreen applied."

3. 19 *Volume.* Two methods are defined for determining refrigerated volume.

3.19.1 *AHAM Volume Method.* The interior volume of a refrigerator as calculated by AHAM HRF-1.

3.19. 2 *Load Line Volume Method*. The gross interior volume of the refrigerator contained within the load limit lines. This gross volume shall be calculated without display devices installed.

Documents
Document Sharing Hub
Full document details: AHRI Standard 1200-2013 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets

Section 4. Test Requirements

4.1 *Test Requirements.* The tests required for this standard shall be conducted in accordance with ANSI/ASHRAE Standard 72.

4.1.1 *Dry-Bulb Temperature***.** The average test-room dry-bulb temperature shall be 75.2ºF ± 1.8ºF, when measured in accordance with ANSI/ASHRAE Standard 72.

4.1.2 *Wet-Bulb Temperature*. The average test-room wet-bulb temperature shall be 64.4ºF ± 1.8ºF, when measured in accordance with ANSI/ASHRAE Standard 72.

4.1.3 *Electrical Conditions.* Nameplate voltages for 60 Hertz systems are shown in Table 1 of AHRI Standard 110. Nameplate voltages for 50 Hertz systems shall include one or more of the utilization voltages shown in Table 1 of IEC Standard 60038. Tests shall be performed at the nameplate rated voltage and frequency unless otherwise specified in this standard. For all dual nameplate voltage equipment covered by this standard, tests shall be performed at both voltages or at the lower voltage if only a single rating is to be published.

Section 5. Rating Requirements for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets

5.1 *General*. This section identifies the necessary data required to calculate the CDEC for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets.

5.2 *CDEC for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets*. The total electrical load shall be measured and adjusted to determine CDEC. The electrical load categories shall include compressors, evaporator fan motors, lighting, surface anti-condensate load including fans and heaters, defrost heaters, condensate evaporator pans and any other suitable electrical loads when they are part of the unit. If measured electrical loads are not available, the following calculations shall be done to determine the CDEC.

$$CDEC = CEC + FEC + LEC + AEC + DEC + PEC \quad (1)$$

Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets shall report the individual loads in the calculation of CDEC. Shown below are formulae for the required individual loads.

5.2.1 *Calculation of CEC*. The EER values in Table 1 shall be used to calculate CEC for a 24 hour period.

Note: The EER values in Table 1 are based on an evaporator temperature and the Commercial Refrigerated Display Merchandiser or Storage Cabinet classification. Commercial Refrigerated Display Merchandisers and Storage Cabinets for Medium Temperature Applications shall use a temperature that is 2.0°F lower than the Commercial Refrigerated Display Merchandiser or Storage Cabinet Dew Point.

Commercial Refrigerated Display Merchandisers and Storage Cabinets for Low Temperature/Ice Cream Applications shall use a temperature that is 3.0°F lower than the Commercial Refrigerated Display Merchandiser or Storage Cabinet Dew Point. Table 1 shall be used for consistency, understanding that other compressor selections can lead to a different efficiency.

$$CEC = [(Q_{rt}) \cdot (t - t_{dt})] / (EER \cdot 1000) \quad (2)$$

5.2.2 *Calculation of FEC.* The FEC shall be measured data for all fan motors or calculated data using the motor efficiency:

$$FEC = (P_f \cdot t_f) / (1000) \quad (3)$$

Where:

$P_f = (P_{fi} \cdot n)$ (measured)

$P_f = (P_{fo} \cdot n) / (\eta_m)$ (calculated)

Documents
Document Sharing Hub
Full document details: AHRI Standard 1200-2013 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets

5.2.3 *Calculation of LEC.*

$$LEC = (P_{li} \cdot t_l) / (1000) \quad (4)$$

5.2.4 *Calculation of AEC.*

$$AEC = (P_{ai} \cdot t_a) / (1000) \quad (5)$$

5.2.5 *Calculation of DEC.*

$$DEC = (P_d \cdot t_d) / (1000) \quad (6)$$

5.2.6 *Calculation of PEC.*

$$PEC = (P_c \cdot t_c) / (1000) \quad (7)$$

5.2.7 *Other Electric Energy Consumption.* If there are additional options that decrease or increase the electrical usage, they shall be noted under "Other Loads" (Section 8) with an appropriate calculation for energy consumption expressed in kW·h per day.

5.3 *Alternate Components - Direct Effects.* The energy consumption of substituted or alternate components shall be measured or calculated from the component's nameplate rating. The energy usage of the substituted or alternate components shall be used to recalculate the CDEC in Section 5.2. The energy consumption of the substituted or alternate components and the recalculated CDEC shall be reported as shown in Section 8.

5.3.1 *FEC.* When removing or substituting a fan motor, the fan energy shall be measured or calculated according to Section 5.2.2. The energy usage of the substituted or alternate components shall be used to recalculate the CDEC according to Section 5.2. The energy consumption of the substituted or alternate components and the recalculated CDEC shall be reported according to Section 8. When calculating the fan motor energy for substituting a fan motor, the airflow rate produced from the assembly shall be equal to the original configuration.

5.3.2 *LEC.* When removing or substituting lighting, the lighting energy shall be measured or calculated according to Section 5.2.3. The energy usage of the substituted or alternate components shall be used to recalculate the CDEC according to Section 5.2. The energy consumption of the substituted or alternate components and the recalculated CDEC shall be reported according to Section 8.

5.3.3 *AEC.* When removing or substituting an anti-condensate heater, the heater energy shall be measured or calculated according to Section 5.2.4. The energy usage of the substituted or alternate components shall be used to recalculate the CDEC according to Section 5.2. The energy consumption of the substituted or alternate components and the recalculated CDEC shall be reported according to Section 8.

5.3.4 *DEC.* When removing or substituting a defrost heater, the heater energy shall be measured or calculated according to Section 5.2.5. The energy usage of the substituted or alternate components shall be used to recalculate the CDEC according to Section 5.2. The energy consumption of the substituted or alternate components and the recalculated CDEC shall be reported according to Section 8.

5.3.5 *PEC.* When removing or substituting a condensate evaporator pan, the pan energy shall be measured or calculated according to Section 5.2.6. The energy usage of the substituted or alternate components shall be used to recalculate the CDEC according to Section 5.2. The energy consumption of the substituted or alternate components and the recalculated CDEC shall be reported according to Section 8.

Documents
Document Sharing Hub
Full document details: AHRI Standard 1200-2013 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets