AHRI Standard 1241-2017 (R2023) (SI)

2017 (R2023) Standard for

Performance Rating of Active Chilled Beams

AIR-CONDITIONING, HEATING, & REFRIGERATION INSTITUTE

we make life better®

2311 Wilson Boulevard, Suite 400
Arlington, VA 22201, USA
www.ahrinet.org
PH 703.524.8800
FX 703.562.1942

Documents
Document Sharing Hub

Full document details: AHRI Standard 1241-2017 (SI) R2023 - Performance Rating of Active Chilled Beams

©Copyright 2023, by Air-Conditioning, Heating, and Refrigeration Institute
Registered United States Patent and Trademark Office
Printed in U.S.A.

IMPORTANT
SAFETY DISCLAIMER

AHRI does not set safety standards and does not certify or guarantee the safety of any products, components or systems designed, tested, rated, installed or operated in accordance with this standard/guideline. It is strongly recommended that products be designed, constructed, assembled, installed and operated in accordance with nationally recognized safety standards and code requirements appropriate for products covered by this standard/guideline.

AHRI uses its best efforts to develop standards/guidelines employing state-of-the-art and accepted industry practices. AHRI does not certify or guarantee that any tests conducted under its standards/guidelines will be non-hazardous or free from risk.

ICS Code: 27.200

Note:

This standard supersedes AHRI Standard 1241 (SI)-2016.
This standard was reaffirmed May 2023.
For I-P ratings, see AHRI Standard 1240-2017 (R2023) (I-P).

Documents
Document Sharing Hub

Full document details: AHRI Standard 1241-2017 (SI) R2023 - Performance Rating of Active Chilled Beams

TABLE OF CONTENTS

SECTION		PAGE
Section 1.	Purpose	1
Section 2.	Scope	1
Section 3.	Definitions	1
Section 4.	Classifications	3
Section 5.	Standard Equipment	3
Section 6.	Test Requirements	3
Section 7.	Rating Requirements	3
Section 8.	Minimum Data Requirements for Published Ratings	4
Section 9.	Marking and Nameplate Data	7
Section 10.	Conformance Conditions	7

TABLES

Table 1.	Sound Power Level Rating Tolerances	4

APPENDICES

Appendix A.	References – Normative	8
Appendix B.	References – Informative	8

Documents
Document Sharing Hub

Full document details: AHRI Standard 1241-2017 (SI) R2023 - Performance Rating of Active Chilled Beams

PERFORMANCE RATING OF ACTIVE CHILLED BEAMS

Section 1. Purpose

1.1 *Purpose.* The purpose of this standard is to provide, for Active Chilled Beams: definitions; classifications; standard equipment; testing requirements; rating requirements; minimum data requirements for published ratings; marking and nameplate data; and voluntary conformance conditions.

Section 2. Scope

2.1 This standard applies to Active Chilled Beams as defined in Section 3, including Multi-service Active Chilled Beams and Room Air Induction Units.

2.2 *Exclusions.*

2.2.1 This standard does not apply to Active Chilled Beams employing volatile-refrigerant coils, condensing coils, or steam coils.

2.2.2 This standard does not apply to Passive Chilled Beams.

Section 3. Definitions

All terms in this document will follow the standard industry definitions in the ASHRAE Terminology website (https://www.ashrae.org/resources--publications/free-resources/ashrae-terminology), unless otherwise defined in this section.

3.1 *Active Chilled Beam*. An air induction and diffusion device which introduces conditioned air for the purposes of temperature and/or humidity control. Primary Air is delivered through a series of Nozzles, which induces and conditions Secondary Air through a unit mounted coil.

3.1.1 *Multi-service Active Chilled Beam*. A chilled beam that incorporates space services other than cooling such as lighting. This type of Active Chilled Beam is usually customized to meet specific project requirements.

3.1.2 *Room Air Induction Unit*. A type of Active Chilled Beam that requires more than 375 Pa of inlet static pressure to operate.

3.2 *Air-induction Process.* The process by which a jet of Primary Air induces Secondary Air through the coil.

3.2.1 *Primary Air*. Air delivered through the Nozzle(s) of an Active Chilled Beam.

3.2.2 *Secondary Air*. Air induced through the coil of an Active Chilled Beam.

3.2.3 *Supply Air*. The mixture of Primary Air and Secondary Air that is discharged to the space by the Active Chilled Beam.

3.2.4 *Nozzle.* An air flow opening in the Plenum which discharges a jet of Primary Air via the Air-induction Process.

3.2.5 *Plenum.* An air compartment under positive pressure, and consisting of inlet(s) and Nozzle(s) for Primary Air. Also referred to as a *Plenum Chamber*.

3.2.6 *Induction Ratio.* The ratio of the volumetric flow rate of Secondary Air to Primary Air.

3.2.7 *Air Outlet(s) and Inlet(s).* Openings for the delivery or induction of air.

3.2.7.1 *Supply Air Outlet*. An opening for the delivery of Supply Air from the active chilled beam unit.

AVA Documents Document Sharing Hub

Full document details: AHRI Standard 1241-2017 (SI) R2023 - Performance Rating of Active Chilled Beams