ANSI/AHRI Standard 1320 (I-P)

2011 Standard for

Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use With Secondary Refrigerants

Approved American National Standard
ANSI

Approved by ANSI on April 17, 2012

AHRI Air-Conditioning, Heating, and Refrigeration Institute

2111 Wilson Boulevard, Suite 500
Arlington, VA 22201, USA
www.ahrinet.org

PH 703.524.8800
FX 703.562.1942

AVA Documents
Document Sharing Hub

Full document details: AHRI Standard 1320-2011 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use...

IMPORTANT

SAFETY DISCLAIMER

AHRI does not set safety standards and does not certify or guarantee the safety of any products, components or systems designed, tested, rated, installed or operated in accordance with this standard/guideline. It is strongly recommended that products be designed, constructed, assembled, installed and operated in accordance with nationally recognized safety standards and code requirements appropriate for products covered by this standard/guideline.

AHRI uses its best efforts to develop standards/guidelines employing state-of-the-art and accepted industry practices. AHRI does not certify or guarantee that any tests conducted under its standards/guidelines will be non-hazardous or free from risk.

Note:

This standard is a new standard.
For SI ratings, see ANSI/AHRI Standard 1321 (SI) – 2011.

Price $10.00 (Members) $20.00 (Non-Members)
Printed in U. S.A.

©Copyright 2011, by Air-Conditioning, Heating and Refrigeration Institute
Registered United States Patent and Trademark Office

Documents
Document Sharing Hub
Full document details: AHRI Standard 1320-2011 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use...

TABLE OF CONTENTS

SECTION		PAGE
Section 1.	Purpose	1
Section 2.	Scope	1
Section 3.	Definitions	1
Section 4.	Test Requirements	3
Section 5.	Rating Requirements	3
Section 6.	Symbols and Subscripts	8
Section 7.	Minimum Data Requirements for Published Ratings	9
Section 8.	Marking and Nameplate Data	9
Section 9.	Conformance Conditions	9

TABLES

Table 1.	EER for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use With Secondary Refrigerants	6
Table 2.	Presentation of Data for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use With Secondary Refrigerants	10

Documents
Document Sharing Hub
Full document details: AHRI Standard 1320-2011 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use...

APPENDICES

Appendix A. References - Normative 11

Appendix B. References - Informative 11

Appendix C. Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use with Secondary Refrigerants Load Line Volume Calculation - Normative 12

Appendix D. Commercial Refrigerated Display Merchandisers for Use with Secondary Refrigerants Total Display Area (TDA) Calculation - Normative 15

Appendix E. Example – Energy Performance Representation for Remote Commercial Refrigerated Display Merchandisers or Storage Cabinets for Use with Secondary Refrigerants - Informative 20

TABLES FOR APPENDICES

Table E1. Sample Presentation of Data for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use with Secondary Refrigerants 22

FIGURES FOR APPENDICES

Figure C1.1. Sample Isometric View of Commercial Refrigerated Display Merchandisers for Illustrating Length of Refrigerated Space 12

Figure C1.2. Sample Cross Sections of Commercial Refrigerated Display Merchandisers for Load Line Volume Calculation 13

Figure C2. Sample Cross Section of Commercial Refrigerated Storage Cabinets for Volume Calculation 14

Figure D1. Vertical Open Multi-deck 15

Figure D2. Vertical Open Multi-deck with Transparent Front 15

Figure D3. Semi-vertical Open Multi-deck 16

Figure D4. Semi-vertical Open Multi-deck with Transparent Front 16

Figure D5. Horizontal Open Single-deck 16

Documents
Document Sharing Hub

Full document details: AHRI Standard 1320-2011 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use...

Figure D6. Horizontal Open Single-deck with Transparent Front 16
Figure D7. Service Over Counter with Flat Transparent Front 17
Figure D8. Service Over Counter with Curved Transparent Front.....17
Figure D9. Horizontal Open Single-deck Island 17
Figure D10. Horizontal Open Single-deck Island with Transparent Wall 17
Figure D11. Horizontal Open Single-deck Island with Transparent Walls.....17
Figure D12. Vertical Closed Multi-deck with Transparent Doors 17
Figure D13. Vertical End Wall with Transparent Section.....18
Figure D14. Semi-vertical End Wall with Transparent Section 18
Figure D15. Horizontal Single-deck and Single-deck Island End Wall with Transparent Section.....18
Figure D16. Service Over Counter End Wall with Transparent Section.....18
Figure D17. Example TDA for Unique Geometries.....19

Documents
Document Sharing Hub
Full document details: AHRI Standard 1320-2011 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use...

PERFORMANCE RATING OF COMMERCIAL REFRIGERATED DISPLAY MERCHANDISERS AND STORAGE CABINETS FOR USE WITH SECONDARY REFRIGERANTS

Section 1. Purpose

1.1 *Purpose*. The purpose of this standard is to establish for Commercial Refrigerated Display Merchandisers and Storage Cabinets that use secondary refrigerants: definitions; test requirements; rating requirements; symbols and subscripts; minimum data requirements for Published Ratings; marking and nameplate data and conformance conditions.

1.1.1 *Intent*. This standard is intended for the guidance of the industry, including manufacturers, engineers, installers, contractors and users. The values reported using this standard allow comparison of energy consumption within each of the following product categories: Remote Commercial Refrigerated Display Merchandisers, Remote Commercial Refrigerated Storage Cabinets and Self-contained Commercial Refrigerated Display Merchandisers.

1.1.2 *Review and Amendment*. This standard is subject to review and amendment as technology advances.

Section 2. Scope

2.1 *Scope*. This standard applies to the following Commercial Refrigerated Display Merchandisers and Storage Cabinets, provided that the cases are equipped and designed to work with electrically driven, medium-temperature, single-phase secondary coolant systems:

2.1.1 Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets
2.1.2 Open and Closed Commercial Refrigerated Display Merchandisers

2.2 *Exclusions.* This standard does not apply to the following:

2.2.1 Refrigerated vending machines
2.2.2 Ice makers
2.2.3 Soft serve extruders
2.2.4 Low-temperature applications
2.2.5 Secondary coolants involving a change of phase (e.g. ice slurries, CO_2)
2.2.6 Self-contained Commercial Refrigerated Display Merchandisers and storage cabinets

Section 3. Definitions

All terms in this document shall follow the standard industry definitions in the current edition of *ASHRAE Terminology of Heating, Ventilation, Air Conditioning and Refrigeration* unless otherwise defined in this section.

3.1 *Anti-condensate Energy Consumption (AEC).* The Total Daily Energy Consumption used in condensate removal on the outside of the Commercial Refrigerated Display Merchandiser or Storage Cabinet, which typically includes fan and condensate heater energy expressed in kW·h per day.

3.2 *Calculated Daily Energy Consumption (CDEC).* This is a value for Remote Commercial Refrigerated Display Merchandisers or Storage Cabinets based upon the requirements of this standard expressed in kW·h per day.

3.3 *Circulation Pump Energy Consumption (CPEC).* The energy consumed by the pump used to circulate secondary coolant expressed in kW·h per day.

Documents
Document Sharing Hub
Full document details: AHRI Standard 1320-2011 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use...

3.4 *Circulation Pump Heat Input ($Q_{CP.}$)* The energy transferred to the secondary coolant as a result of the work done on the coolant by the circulation pump expressed in Btu/h.

3.5 *Commercial Refrigerated Display Merchandiser*. A cabinet cooled by a refrigerating system for displaying chilled and/or frozen food to be maintained within prescribed temperature limits.

3.5.1 *Closed Commercial Refrigerated Display Merchandiser*. A refrigerated display merchandiser where food is accessible for removal by opening or moving doors or panels.

3.5.2 *Open Commercial Refrigerated Display Merchandiser*. A refrigerated display merchandiser where food is accessible for removal without opening or moving doors or panels.

3.5.3 *Remote Commercial Refrigerated Display Merchandiser*. A refrigerated display merchandiser that has a remote condensing unit.

3.5.4 *Service Over the Counter (SOC).* A commercial refrigerator or freezer equipped with sliding or hinged doors in the back intended for use by sales personnel, and with glass or other transparent material in the front for displaying merchandise. The equipment has a height no greater than 66 inches and is intended to serve as a counter for transactions between sales personnel and customers.

3.6 *Commercial Refrigerated Storage Cabinet.* A closed cabinet cooled by a refrigerating system for storing chilled and/or frozen food to be maintained within prescribed temperature limits.

3.6.1 *Remote Commercial Refrigerated Storage Cabinet*. A refrigerated storage cabinet that has a remote condensing unit.

3.7 *Compressor Energy Consumption (CEC).* The energy consumed by the compressor expressed in kW·h per day.

3.8 *Condensate Evaporator Pan Energy Consumption (PEC).* The amount of heat energy required to change condensate from liquid to a vapor in the evaporator pan expressed in kW·h per day.

3.9 *Defrost Energy Consumption (DEC).* The energy consumed during defrost cycles expressed in kW·h per day.

3.10 *Dew Point.* Refrigerant vapor saturation temperature at a specified pressure expressed in °F.

3.10.1 *Adjusted Dew Point.* An adjusted temperature lower than actual Dew Point temperature expressed in °F, resulting from suction line pressure losses, equal to saturated suction temperature at the compressor.

3.11 *Energy Efficiency Ratio (EER).* A ratio of the cooling capacity in Btu/h to the power input values in watts at any given set of Rating Conditions expressed in Btu/(W·h).

3.12 *Fan Energy Consumption (FEC).* The energy consumed by fan motors expressed in kW·h per day.

3.13 *Integrated Average Temperature.* The average of all test package measurements taken during the test expressed in °F.

3.14 *Lighting Energy Consumption (LEC).* The energy consumed by lighted shelves and lighting internal to the refrigerated display merchandiser or storage cabinet expressed in kW·h per day.

3.15 *Product Temperature*. Commercial Refrigerated Display Merchandisers or Storage Cabinets shall be tested with one or more of the following Integrated Average Temperatures:

3.15.1 *Medium Temperature Applications.* Commercial Refrigerated Display Merchandisers and Storage Cabinets **i**ntended for Medium Temperature Applications, shall have an Integrated Average Temperature of 3.3°C ± 1.1°C.

3.15.2 *Application Product Temperature*. This test allows Integrated Average Temperatures other than Section 3.15.1.

Documents
Document Sharing Hub
Full document details: AHRI Standard 1320-2011 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use...

3.16 *Published Rating.* A statement of the assigned values of those performance characteristics, under stated Rating Conditions, by which a unit may be chosen for its application. The term Published Rating includes the rating of all performance characteristics shown on the unit or published in specifications, advertising or other literature controlled by the manufacturer, at stated Rating Conditions.

3.16.1 *Application Rating*. A rating based on tests performed at application Rating Conditions (other than Standard Rating Conditions).

3.16.2 *Standard Rating*. A rating based on tests performed at Standard Rating Conditions.

3.17 *Rating Conditions*. Any set of operating conditions under which a single level of performance results and which causes only that level of performance to occur.

3.17.1 *Standard Rating Conditions.* Rating Conditions used as the basis of comparison for performance characteristics.

3.18 *Secondary Coolant.* Fluid used for the transmission of heat without a complete or partial change of phase within the cabinet. This standard applies to single-phase applications where the fluid is 35% propylene glycol or a fluid with similar viscosity and heat transfer properties.

3.19 *"Shall" or "Should"*. "Shall" or "should" shall be interpreted as follows:

3.19.1 *Shall*. Where "shall" or "shall not" is used for a provision specified, that provision is mandatory if compliance with the standard is claimed.

3.19.2 *Should*. "Should" is used to indicate provisions which are not mandatory but which are desirable as good practice.

3.20 *Total Display Area (TDA).* The sum of the projected area(s) for visible product expressed in ft^2.

3.21 *Volume.* Two methods are defined for determining refrigerated volume.

3.21.1 *AHAM Volume Method.* The interior volume of a refrigerator as calculated by AHAM HRF-1.

3.21.2 *Load Line Volume Method*. The gross interior volume of the refrigerator contained within the load limit lines. This gross volume shall be calculated without display devices installed.

Section 4. Test Requirements

4.1 *Test Requirements.* The tests required for this standard shall be conducted in accordance with ANSI/ASHRAE Standard 72.

4.1.1 *Dry-Bulb Temperature***.** The average test-room dry-bulb temperature shall be 75.2ºF ± 1.8ºF, when measured in accordance with ANSI/ASHRAE Standard 72.

4.1.2 *Wet-Bulb Temperature*. The average test-room wet-bulb temperature shall be 64.4ºF ± 1.8ºF, when measured in accordance with ANSI/ASHRAE Standard 72.

Section 5. Rating Requirements

5.1 *General*. This section identifies the necessary data required to calculate the CDEC for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets for use with secondary refrigerants.

Documents
Document Sharing Hub
Full document details: AHRI Standard 1320-2011 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use...

5.2 *CDEC for Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets.* The total electrical load shall be measured and adjusted to determine CDEC. The electrical load categories shall include compressors, evaporator fan motors, lighting, surface anti-condensate load including fans and heaters, defrost heaters, condensate evaporator pans, secondary coolant circulation pumps and any other suitable electrical loads when they are part of the unit. If measured electrical loads are not available, the following calculations shall be done to determine the CDEC.

$$CDEC = CEC + FEC + LEC + AEC + DEC + PEC + CPEC \quad (1)$$

Remote Commercial Refrigerated Display Merchandisers and Storage Cabinets shall report the individual loads in the calculation of CDEC. Shown below are formulae for the required individual loads.

5.2.1 *Calculation of CEC.* The EER values in Table 1 shall be used to calculate CEC for a 24 hour period.

Note: The EER values in Table 1 are based on an evaporator temperature and the Commercial Refrigerated Display Merchandiser or Storage Cabinet classification. Commercial Refrigerated Display Merchandisers and Storage Cabinets for Medium Temperature Secondary Applications shall use a temperature that is 6.0°F lower than the Commercial Refrigerated Display Merchandiser or Storage Cabinet secondary coolant cabinet inlet temperature.

$$CEC = [(Q_{rt} + Q_{CP}) \cdot (t - t_{dt})] / (EER \cdot 1000) \quad (2)$$

5.2.2 *Calculation of FEC.* The FEC shall be measured data for all fan motors or calculated data using the motor efficiency:

$$FEC = (P_f \cdot t_f) / (1000) \quad (3)$$

Where:

$P_f = (P_{fi} \cdot n)$ (measured)
$P_f = (P_{fo} \cdot n) / (\eta_m)$ (calculated)

5.2.3 *Calculation of LEC.*

$$LEC = (P_{li} \cdot t_l) / (1000) \quad (4)$$

5.2.4 *Calculation of AEC.*

$$AEC = (P_{ai} \cdot t_a) / (1000) \quad (5)$$

5.2.5 *Calculation of DEC.*

$$DEC = (P_d \cdot t_d) / (1000) \quad (6)$$

5.2.6 *Calculation of PEC.*

$$PEC = (P_c \cdot t_c) / (1000) \quad (7)$$

5.2.7 *Calculation of CPEC.*

5.2.7.1 *Off-Cycle Defrost.*

For cabinets with secondary coolant pressure drop values equal to or less than 6.5 PSI, use the formula

$$CPEC = M \bullet K_1 \bullet (t\text{-}t_{dt})/1000 \quad (8)$$

Where:

Documents
Document Sharing Hub
Full document details: AHRI Standard 1320-2011 (I-P) - Performance Rating of Commercial Refrigerated Display Merchandisers and Storage Cabinets for Use...