AHRI Standard 270

2015 Standard for

Sound Performance Rating of Outdoor Unitary Equipment

AIR-CONDITIONING, HEATING, & REFRIGERATION INSTITUTE

we make life better™

2111 Wilson Boulevard, Suite 500
Arlington, VA 22201, USA
www.ahrinet.org
PH 703.524.8800
FX 703.562.1942

Documents
Document Sharing Hub

Full document details: AHRI Standard 270-2015 - Sound Performance Rating of Outdoor Unitary Equipment

IMPORTANT

SAFETY DISCLAIMER

AHRI does not set safety standards and does not certify or guarantee the safety of any products, components or systems designed, tested, rated, installed or operated in accordance with this standard/guideline. It is strongly recommended that products be designed, constructed, assembled, installed and operated in accordance with nationally recognized safety standards and code requirements appropriate for products covered by this standard/guideline.

AHRI uses its best efforts to develop standards/guidelines employing state-of-the-art and accepted industry practices. AHRI does not certify or guarantee that any tests conducted under its standards/guidelines will be non-hazardous or free from risk.

Note:

This standard supersedes AHRI Standard 270-2008.

Foreword

This standard references the sound intensity test method defined in ANSI/AHRI Standard 230, as an alternate method of test to the reverberation room test method defined in ANSI/AHRI Standard 220 for determination of sound power ratings.

Price $10.00 (M) $20.00 (NM)
Printed in U.S.A.

©Copyright 2015, by Air-Conditioning, Heating, and Refrigeration Institute
Registered United States Patent and Trademark Office

Documents
Document Sharing Hub

Full document details: AHRI Standard 270-2015 - Sound Performance Rating of Outdoor Unitary Equipment

TABLE OF CONTENTS

SECTION		PAGE
Section 1.	Purpose	1
Section 2.	Scope	1
Section 3.	Definitions	1
Section 4.	Test Requirements	3
Section 5.	Rating Requirements	5
Section 6.	Minimum Data Requirements for Published Ratings	6
Section 7.	Marking and Nameplate Data	7
Section 8.	Conformance Conditions	7

TABLES

Table 1. Reproducibility in the Determination of Non-ducted Equipment Sound Power Levels……5

APPENDICES

Appendix A. References – Normative 8

Appendix B. References – Informative 10

Documents
Document Sharing Hub

Full document details: AHRI Standard 270-2015 - Sound Performance Rating of Outdoor Unitary Equipment

SOUND PERFORMANCE RATING OF OUTDOOR UNITARY EQUIPMENT

Section 1. Purpose

1.1 *Purpose.* The purpose of this standard is to establish for outdoor unitary equipment: definitions; test requirements; rating requirements; minimum data requirements for Published Ratings; marking and nameplate data; and conformance conditions.

1.1.1 *Intent*. This standard is intended for the guidance of the industry, including manufacturers, engineers, installers, contractors and users.

1.1.2 *Review and Amendment*. This standard is subject to review and amendment as technology advances.

Section 2. Scope

2.1 *Scope.* This standard applies to the outdoor sections of factory-made air-conditioning and heat pump equipment as defined in ANSI/AHRI Standard 210/240, ANSI/AHRI Standard 340/360 (cooling capacity ratings of equal to or less than 40.0 kW), ANSI/AHRI Standard 1230, ANSI/AHRI Standard 1160 (I-P), and ANSI/AHRI Standard 1161 (SI). Products covered include: Air-source Unitary Heat Pumps, Heat Pump Pool Heaters, Unitary Air-conditioners and Variable Refrigerant Flow (VRF) Systems.

Section 3. Definitions

All terms in this document will follow the standard industry definitions in the ASHRAE Terminology website (https://www.ashrae.org/resources--publications/free-resources/ashrae-terminology) unless otherwise defined in this section.

3.1 *Air-source Unitary Heat Pump*. One or more factory-made assemblies which normally include an indoor conditioning coil(s), compressor(s), and outdoor coil(s), including means to provide a heating function. They shall provide the function of air heating with controlled temperature and may include the functions of air-cooling, air-circulating, air-cleaning, dehumidifying or humidifying. When such equipment is provided in more than one assembly, the separated assemblies shall be designed to be used together, and the requirements of rating outlined in the standard are based upon the use of matched assemblies.

3.2 *Heat Pump Pool Heater*. A factory-made assembly, which contains the air moving device, compressor, refrigerant-to-water heat exchanger and air-to-refrigerant heat exchanger using ambient air as the heat source. They shall provide the function of heating pool water to achieve a controlled temperature, but may include the functions of pool water cooling, air-heating, air cooling, air-circulating, air-cleaning, or dehumidifying. Models may consist of more than one assembly to be used together for the purpose of cooling and heating air. Models with separated assemblies shall be designed to be used together, and the requirements of rating outlined in this standard are based upon the use of matched assemblies.

3.3 *Hertz (Hz).* A unit of frequency equal to one cycle per second.

3.4 *Octave Band*. A band of sound covering a range of frequencies such that the highest is twice the lowest. The Octave Bands used in this standard are those defined in ANSI/ASA Standard S1.11.

3.5 *One-third Octave Band.* A band of sound covering a range of frequencies such that the highest frequency is the cube root of two times the lowest. The One-third Octave Bands used in this standard are those defined in ANSI/ASA Standard S1.11.

3.6 *Published Rating.* A statement of the assigned values of those performance characteristics, under stated rating conditions, by which a unit may be chosen to fit its application. These values apply to all units of like nominal size and type

AVA Documents Document Sharing Hub

Full document details: AHRI Standard 270-2015 - Sound Performance Rating of Outdoor Unitary Equipment