ANSI/AHRI Standard 760 (I-P)

2014 Standard for

Performance Rating of Solenoid Valves for Use with Volatile Refrigerants

Approved American National Standard

ANSI

Approved by ANSI on May 15, 2015

AHRI Air-Conditioning, Heating, and Refrigeration Institute

2111 Wilson Boulevard, Suite 500
Arlington, VA 22201, USA
www.ahrinet.org

PH 703.524.8800
FX 703.562.1942

AVA Documents
Document Sharing Hub

Copyright Air-Conditioning, Heating and Refrigeration Institute
Provided by IHS
No reproduction or networking permitted without license from IHS

Licensee=Southern Company Service/5929653100, User=alexa, joe
Not for Resale, 04/10/2016 02:09:31 MDT

Full document details: AHRI Standard 760-2014 (I-P) - Performance Rating of Solenoid Valves for Use with Volatile Refrigerants

IMPORTANT

SAFETY DISCLAIMER

AHRI does not set safety standards and does not certify or guarantee the safety of any products, components or systems designed, tested, rated, installed or operated in accordance with this standard/guideline. It is strongly recommended that products be designed, constructed, assembled, installed and operated in accordance with nationally recognized safety standards and code requirements appropriate for products covered by this standard/guideline.

AHRI uses its best efforts to develop standards/guidelines employing state-of-the-art and accepted industry practices. AHRI does not certify or guarantee that any tests conducted under the standards/guidelines will not be non-hazardous or free from risk.

Note:

This standard supersedes AHRI Standard 760-2007.

For SI ratings, see ANSI/AHRI Standard 761 (SI)-2014.

Price $10.00 (M) $20.00 (NM)
Printed in U.S.A.

©Copyright 2014, by Air-Conditioning, Heating, and Refrigeration Institute
Registered United States Patent and Trademark Office

Documents
Document Sharing Hub

Copyright Air-Conditioning, Heating and Refrigeration Institute
Provided by IHS
No reproduction or networking permitted without license from IHS
Licensee=Southern Company Service/5929653100, User=alexa, joe
Not for Resale, 04/10/2016 02:09:31 MDT
Full document details: AHRI Standard 760-2014 (I-P) - Performance Rating of Solenoid Valves for Use with Volatile Refrigerants

TABLE OF CONTENTS

SECTION		PAGE
Section 1.	Purpose	1
Section 2.	Scope	1
Section 3.	Definitions	1
Section 4.	Test Requirements	2
Section 5.	Rating Requirements	2
Section 6.	Minimum Data Requirements for Published Ratings	4
Section 7.	Marking and Nameplate Data	4
Section 8.	Conformance Conditions	4

TABLES

Table 1.	Standard Rating Conditions	2
Table 2.	Published Application Ratings for Discharge Gas Service	4

APPENDICES

Appendix A.	References - Normative	5
Appendix B.	References - Informative	5
Appendix C.	Method of Testing for Rating Solenoid Valves for Maximum Operating Pressure Differential (MOPD) - Normative	6
Appendix D.	Recommended Standard Connection Sizes - Informative	13

TABLES FOR APPENDICES

Table C1.	Pressure-tap Hole Diameters and Lengths	8
Table D1.	Recommended Standard Connection Sizes	13

Documents
Document Sharing Hub

Copyright Air-Conditioning, Heating and Refrigeration Institute
Provided by IHS
No reproduction or networking permitted without license from IHS
Licensee=Southern Company Service/5929653100, User=alexa, joe
Not for Resale, 04/10/2016 02:09:31 MDT
Full document details: AHRI Standard 760-2014 (I-P) - Performance Rating of Solenoid Valves for Use with Volatile Refrigerants

FIGURES FOR APPENDICES

Figure C1. Typical System Piping for Solenoid Valve MOPD Test with Gas or Liquid 7

Figure C2. Typical Electrical Test Apparatus for an Alternating Current Solenoid Valve.....9

Figure C3. Typical Electrical Test Apparatus for a Direct Current Solenoid Valve.....10

Documents
Document Sharing Hub

Copyright Air-Conditioning, Heating and Refrigeration Institute
Provided by IHS
No reproduction or networking permitted without license from IHS
Licensee=Southern Company Service/5929653100, User=alexa, joe
Not for Resale, 04/10/2016 02:09:31 MDT
Full document details: AHRI Standard 760-2014 (I-P) - Performance Rating of Solenoid Valves for Use with Volatile Refrigerants

PERFORMANCE RATING OF SOLENOID VALVES FOR USE WITH VOLATILE REFRIGERANTS

Section 1. Purpose

1.1 *Purpose.* The purpose of this standard is to establish for Solenoid Valves for use with volatile refrigerants: definitions; test requirements; rating requirements; minimum data requirements for Published Ratings; marking and nameplate data; and conformance conditions.

1.1.1 *Intent*. This standard is intended for the guidance of the industry, including manufacturers, engineers, installers, contractors and users.

1.1.2 *Review and Amendment.* This standard is subject to review and amendment as technology advances.

Section 2. Scope

2.1 *Scope.* This standard applies to Solenoid Valves for use with volatile refrigerants as defined in Section 3.

Section 3. Definitions

All terms in this document follow the standard industry definitions in the *ASHRAE Terminology* website (https://www.ashrae.org/resources--publications/free-resources/ashrae-terminology) unless otherwise defined in this section.

3.1 *Bubble Point.* Refrigerant liquid saturation temperature at a specified pressure.

3.2 *Dew Point.* Refrigerant vapor saturation temperature at a specified pressure.

3.3 *Main*. Tubing or piping by which the Solenoid Valve is connected to the apparatus.

3.4 *Maximum Operating Pressure Differential (MOPD).* The maximum pressure difference between the solenoid valve inlet and the solenoid valve outlet at which the Solenoid Valve will operate, psi.

3.5 *Pressure Drop.* The pressure difference between the solenoid valve inlet and the solenoid valve outlet with the main port (orifice) open, psi.

3.6 *Published Rating*. A statement of the assigned values of those performance characteristics, under stated Rating Conditions, by which a unit may be chosen to fit its application. These values apply to all units of like nominal size and type (identification) produced by the same manufacturer. The term Published Rating includes the rating of all performance characteristics shown on the unit or published in specifications, advertising or other literature controlled by the manufacturer, at stated Rating Conditions.

3.6.1 *Application Rating*. A rating based on tests performed at application Rating Conditions (other than Standard Rating Conditions).

3.6.2 *Standard Rating*. A rating based on tests performed at Standard Rating Conditions.

3.7 *Rating Conditions.* Any set of operating conditions under which a single level of performance results and which causes only that level of performance to occur.

3.7.1 *Standard Rating Conditions*. Rating Conditions used as the basis of comparison for performance characteristics.

Documents
Document Sharing Hub
Copyright Air-Conditioning, Heating and Refrigeration Institute
Provided by IHS
No reproduction or networking permitted without license from IHS
Licensee=Southern Company Service/5929653100, User=alexa, joe
Not for Resale, 04/10/2016 02:09:31 MDT
Full document details: AHRI Standard 760-2014 (I-P) - Performance Rating of Solenoid Valves for Use with Volatile Refrigerants

3.8 *"Shall" or "Should."* "Shall" or "should" shall be interpreted as follows:

3.8.1 *Shall.* Where "shall" or "shall not" is used for a provision specified, that provision is mandatory if compliance with the standard is claimed.

3.8.2 *Should.* "Should" is used to indicate provisions which are not mandatory but which are desirable as good practice.

3.9 *Solenoid Valve.* A valve which is actuated by the magnetic action of an electrically energized coil. The opposite action is accomplished by gravity, pressure or spring action.

3.9.1 *Direct-action Solenoid Valve.* A valve in which the magnetic power of an electrically energized coil moves the main port (orifice) closure member.

3.9.2 *Normally Closed Solenoid Valve.* A valve which is closed when de-energized. When the coil is electrically energized, the closure member is moved away from and off the port (orifice) to cause the opening action.

3.9.3 *Normally Open Solenoid Valve.* A valve which is open when de-energized. When the coil is electrically energized, the closure member is moved toward and onto the port (orifice) to cause the closing action.

3.9.4 *Pilot-operated Solenoid Valve.* A valve in which the motion of a direct-acting member allows a pressure difference to occur across the main port (orifice) closure member, causing it to move.

3.10 *Solenoid Valve Capacity.* The mass flow rate of a fluid through the Solenoid Valve, equated to tons of refrigeration at the specified conditions.

3.11 *Volatile Refrigerants.* A refrigerant that changes from the liquid to the vapor state in the process of absorbing heat.

Section 4. Test Requirements

4.1 *Capacity Tests.* All capacity tests shall be in accordance with the test procedure defined in ANSI/ASHRAE Standard 158.1.

4.2 *MOPD Tests.* All MOPD tests shall be in accordance with the test procedure in Appendix C.

4.2.1 If the Solenoid Valve MOPD depends on the valve position, the valve shall be tested in all positions for which the ratings apply.

Section 5. Rating Requirements

5.1 *Rating Requirements.* Published capacity ratings shall consist of Standard Ratings and may include Application Ratings. The AHRI Standard Ratings of Solenoid Valve Capacity for Volatile Refrigerants shall be stated in tons of refrigeration and at the conditions specified in Table 1.

5.2 *Standard Rating Conditions.* Standard ratings shall be for liquid service applications of solenoid valves per Table 1.

5.2.1 *Liquid Service Solenoid Valve Entrance Conditions.*

Table 1. Standard Rating Conditions

Liquid Service Solenoid Valve Rating Condition	
Saturated Condenser (Dew Point) Temperature, °F	110.0
Liquid Service Temperature Entering the Valve, °F	100.0
Saturated Evaporating (Bubble Point) Temperature, °F	40.0

Documents
Document Sharing Hub
Copyright Air-Conditioning, Heating and Refrigeration Institute
Provided by IHS
No reproduction or networking permitted without license from IHS
Licensee=Southern Company Service/5929653100, User=alexa, joe
Not for Resale, 04/10/2016 02:09:31 MDT
Full document details: AHRI Standard 760-2014 (I-P) - Performance Rating of Solenoid Valves for Use with Volatile Refrigerants