

American Nuclear Society




lubricating oil systems for safety-related emergency diesel generators

an American National Standard

This standard has been reviewed and reaffirmed by the ANS Nuclear Facilities Standards Committee (NFSC) with the recognition that it may reference other standards and documents that may have been superseded or withdrawn. The requirements of this document will be met by using the version of the standards and documents referenced herein. It is the responsibility of the user to review each of the references and to determine whether the use of the original references or more recent versions is appropriate for the facility. Variations from the standards and documents referenced in this standard should be evaluated and documented.

This standard does not necessarily reflect recent industry initiatives for risk informed decision-making or a graded approach to quality assurance. Users should consider the use of these industry initiatives in the application of this standard.



published by the
American Nuclear Society
 555 North Kensington Avenue
 La Grange Park, Illinois 60525 USA



Documents

Document Sharing Hub

ANSI/ANS-59.52-1998

**American National Standard
Lubricating Oil Systems for Safety-Related
Emergency Diesel Generators**

Secretariat
American Nuclear Society

Prepared by the
**American Nuclear Society
Standards Committee
Working Group ANS-59.5x**

Published by the
**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Approved October 23, 1998
by the
American National Standards Institute, Inc.

American National Standard

Designation of this document as an American National Standard attests that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standard has been achieved.

This standard was developed under procedures of the Standards Committee of the American Nuclear Society; these procedures are accredited by the American National Standards Institute, Inc., as meeting the criteria for American National Standards. The consensus committee that approved the standard was balanced to ensure that competent, concerned, and varied interests have had an opportunity to participate.

An American National Standard is intended to aid industry, consumers, governmental agencies, and general interest groups. Its use is entirely voluntary. The existence of an American National Standard, in and of itself, does not preclude anyone from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard.

By publication of this standard, the American Nuclear Society does not insure anyone utilizing the standard against liability allegedly arising from or after its use. The content of this standard reflects acceptable practice at the time of its approval and publication. Changes, if any, occurring through developments in the state of the art, may be considered at the time that the standard is subjected to periodic review. It may be reaffirmed, revised, or withdrawn at any time in accordance with established procedures. Users of this standard are cautioned to determine the validity of copies in their possession and to establish that they are of the latest issue.

The American Nuclear Society accepts no responsibility for interpretations of this standard made by any individual or by any ad hoc group of individuals. Requests for interpretation should be sent to the Standards Department at Society Headquarters. Action will be taken to provide appropriate response in accordance with established procedures that ensure consensus on the interpretation.

Comments on this standard are encouraged and should be sent to Society Headquarters.

Published by

**American Nuclear Society
555 North Kensington Avenue
La Grange Park, Illinois 60526 USA**

Copyright © 2000 by American Nuclear Society. All rights reserved.

Any part of this standard may be quoted. Credit lines should read "Extracted from American National Standard ANSI/ANS-59.52-1998 with permission of the publisher, the American Nuclear Society." Reproduction prohibited under copyright convention unless written permission is granted by the American Nuclear Society.

Printed in the United States of America



Documents
Document Sharing Hub

Foreword

(This Foreword is not a part of American National Standard for Lubricating Oil Systems for Safety-Related Emergency Diesel Generators, ANSI/ANS-59.52-1998.)

This standard is applicable to light water reactor nuclear power plants and is one of a series of standards, sponsored by the LWR Criteria Management Subcommittee (MC-1), intended to cover the design of auxiliary systems that support the operation of emergency diesel generator units. Other standards in this series that have been or are being developed by this working group are listed below:

Proposed Standard	Subject
ANS-59.51	Fuel Oil Systems
ANS-59.53	Starting Air Systems
ANS-59.54	Combustion Air Systems
ANS-59.55	Coolant Systems

This standard interfaces with American National Standard Criteria for Diesel-Generator Units Applied as Standby Power Supplies for Nuclear Power Generating Stations, ANSI/IEEE 387-1995. That standard does not address fluid system or component performance or design criteria. To address these fluid system requirements, this standard includes in its scope the pumps, tanks, piping and piping components, and instrumentation and control functions, as described herein. Based on discussions with the working group chairman for ANSI/IEEE 387, it was agreed that the intent of that standard is to address only the overall qualifications and boundaries of the diesel generator auxiliary systems and not the specific performance or design criteria, which are addressed in ANS-59.52.

The purpose of this standard, and the related standards under development, is to provide guidance to nuclear plant owners, designers, manufacturers, regulatory authorities, and operators, in the design of reliable, safety-related, onsite power systems for light water reactors. The reliability of lubricating oil systems must be considered when satisfying the overall reliability requirements of the diesel generator units. This is particularly important if lubricating oil systems have components that are shared between reactor units, and if the single failure criterion is applied.

This standard can also be used for non-safety-related onsite power systems, with several changes to eliminate those requirements which would not normally apply to such equipment. For example, non-safety-related equipment would not normally have to meet American National Standard Single Failure Criteria for Light Water Reactor Safety-Related Fluid Systems, ANSI/ANS-58.9-1981 (R1987), the Class 1E Power Systems requirements of American National Standard Criteria for Class 1E Power Systems for Nuclear Power Generating Stations, ANSI/IEEE 308-1992, and several of the requirements described in American National Standard Nuclear Safety Criteria for Design of Stationary Pressurized Water Reactor Plants, ANSI/ANS-51.1-1983 (R1988) and American National Standard Nuclear Safety Criteria for Design of Stationary Boiling Water Reactor Plants, ANSI/ANS-52.1-1983 (R1988), for safety-related equipment, such as Seismic Category I. Other requirements, such as American National Standard ASME Boiler and Pressure Vessel Code-1995, Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components," and American National Standard Quality Assurance Program Requirements for Nuclear Facilities, ANSI/ASME NQA-1-1994, which normally apply to safety-related equipment but which are considered to enhance reliability, could be optional or modified to suit a particular application.

This revision to the standard has been prepared by Working Group ANS-59.5x of the Standards Committee of the American Nuclear Society, which had the following membership.

S. A. Shuman, Chairman, *Individual*
J. M. Horne, *Cooper Cameron Corporation*
W. J. McFarland, *PECO Energy Company*
T. O'Brien, *Commonwealth Edison Company*
E. B. Tomlinson, *U.S. Nuclear Regulatory Commission*
N. A. Traeger, *Coltec Industries*

MC-1, LWR Criteria Management Committee, had the following membership at the time of its approval of the standard:

S. B. Bargerstock, *CYGNA Group, Inc.*
J. C. Dempsey, Jr., *Pacific Nuclear*
L. A. Ettlinger, *Defense Nuclear Facilities Safety Board*
J. C. Glynn, *U.S. Nuclear Regulatory Commission*
P. H. Hepner, *ABB / Combustion Engineering Nuclear Power*
R. A. Hill, *GE Nuclear Energy*
M. P. Horrell, *Ebasco Services*
L. A. Klosowski, *Niagara Mohawk Power Corporation*
G. B. Locklear, *Carolina Power & Light Company*
J. T. Luke, *Florida Power & Light Company*
C. G. Morrell, *Stone & Webster Engineering Corporation*
S. A. Nass, *Duquesne Light Company*
N. Prillaman, *Babcock & Wilcox*
H. C. Shaffer, *Yankee Atomic Electric Company*
S. A. Shuman, *Individual*
M. D. Smith, *Bechtel Corporation*
R. C. Surman, *Westinghouse Electric Corporation*

The American Nuclear Society's Nuclear Power Plant Standards Committee (NUPPSCO) had the following membership at the time of its approval of the standard.

W. H. D'Ardenne, Chairman

M. D. Weber, Secretary

R. E. Allen	UE&C Nuclear (for the Institute of Electrical and Electronics Engineers, Inc.)
P. L. Ballinger	Nebraska Public Power District
F. Boorboor	Nuclear Placement Services, Inc.
J. C. Bradford	Bechtel Power Corporation
R. H. Bryan, Jr.	Tennessee Valley Authority
T. W. T. Burnett	Westinghouse Electric Corporation
J. D. Cohen	Westinghouse Savannah River Company
J. B. Cotton	Philadelphia Electric Company
W. H. D'Ardenne	DAE Enterprises (for the American Nuclear Society)
L. E. Davis	Commonwealth Edison Company
M. Drouin	U.S. Nuclear Regulatory Commission
P. H. Hepner	ABB/Combustion Engineering, Inc.
R. A. Hill	G.E. Nuclear Energy
C. E. Johnson, Jr.	U.S. Nuclear Regulatory Commission
J. T. Luke	Florida Power & Light Company
J. F. Mallay	Liberty Consulting Group
C. H. Moseley, Jr.	Performance Development Corporation
J. A. Nevshemal	Raytheon UE&C
W. N. Prillaman	Babcock & Wilcox Company
W. C. Ramsey, Jr.	Southern Company Services, Inc.
W. B. Reuland	Mollerus Engineering Corporation
R. F. Sacramo	Halliburton NUS Corporation
J. C. Saldarini	Raytheon Engineers & Constructors
J. Savy	Lawrence Livermore National Laboratory
R. E. Scott	Scott Enterprises
D. J. Spellman	Oak Ridge National Laboratories
S. L. Stamm	Stone & Webster Engineering Corporation
J. D. Stevenson	Stevenson & Associates
C. D. Thomas, Jr.	Yankee Atomic Electric Company
G. P. Wagner	Commonwealth Edison Company
N. Weber	Consultant
G. J. Wrobel	Rochester Gas & Electric Corporation