

ANSI/AWWA

C606-22

(Revision of *ANSI/AWWA C606-15*)

AWWA Standard

Grooved and Shouldered Joints

Effective date: April 1, 2023.

First edition approved by Board of Directors Jan. 28, 1978.

This edition approved Oct. 24, 2022.

Approved by American National Standards Institute Sept. 15, 2022.



American Water Works
Association



AVA

Documents

Document Sharing Hub


AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; 212.642.4900, or emailing info@ansi.org.



ISBN-13, print: 978-1-64717-112-4

ISBN, electronic: 978-1-61300-645-0

DOI: <http://dx.doi.org/10.12999/AWWA.C606.22>

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher. Please send any requests or questions to permissions@awwa.org.

Copyright © 2022 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Grooved and Shouldered Joints, which reviewed and approved this standard, had the following personnel at the time of approval:

Justin C. Reeves, *Chair*

Wayne Biery, *Vice-Chair*

General Interest Members

T.J. Charles, CDM Smith, Denver, Colo.

R.L. Coffey, Consultant, Omaha, Neb.

J.W. Green (*liaison, nonvoting*), Standards Council Liaison, Lockwood, Andrews & Newnam Inc., Oakbrook Terrace, Ill.

A. Gruber, CP&Y Inc., San Antonio, Tex.

J.A. Hrdlicka (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.

D. Kronebusch, McElhanney, Prince George, B.C.

J.C. Reeves, Lockwood, Andrews & Newnam Inc., Fort Worth, Tex.

Producer Members

W. Biery, Victaulic Company, Center Valley, Pa.

D.W. Dunker, Thompson Pipe Group, Rialto, Calif.

J.A. Fancher, ACIPCO, Birmingham, Ala.

M. Horton (*alternate*), U.S. Pipe & Foundry Company, Birmingham, Ala.

D.A. Hughes, U.S. Pipe & Foundry Company, Birmingham, Ala.

S. Madara (*alternate*), Victaulic Company, Center Valley, Pa.

J.S. Palombo, Everett J. Prescott, Inc., Gardiner, Maine

User Members

M. Acosta, Kitson & Partners, Port Charlotte, Fla.

B.E. Kennedy, Pasco County Utilities, New Port Richey, Fla.

J. Okumu, City Utilities of Springfield, Springfield, Mo.

N. Perez-Jacome, Miami-Dade County, Miami, Fla.

P.J. Pfister, Minneapolis Water Works, Minneapolis, Minn.

K.L. Thompson, Metropolitan Utilities District, Omaha, Neb.

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		4.3	General Design..... 5
I	Introduction..... vii	5 Verification	
I.A	Background..... vii	5.1	Inspection 14
I.B	History..... vii	5.2	Testing 15
I.C	Acceptance viii	5.3	Basis for Nonconformance 19
II	Special Issues. ix	6 Deliver	
II.A	Advisory Information on Product Application. ix	6.1	Marking 19
II.B	Chlorine and Chloramine Degradation of Elastomers ix	6.2	Affidavit of Compliance 19
III	Use of This Standard x	Appendix	
III.A	Purchaser Options and Alternatives x	A	Guidelines for Grooved and Shouldered Piping Spacing, Support, Anchorage, and Guidance 21
III.B	Modification to Standard xi	Figures	
IV	Major Revisions..... xi	1	General Coupling and Joint Configurations 5
V	Comments xi	2	Shouldered Ends 14
Standard		3	Test to Determine Pressure Capacity of Coupling..... 17
1 General		4	Hydrostatic Test for Deflected Flexible Joints..... 18
1.1	Scope..... 1	Tables	
1.2	Purpose 1	1	Gasket Material Grade and Physical Properties—1a for DIP, 1b for IPS/C200 4
1.3	Application..... 2	2	Cut Grooving Dimensions for Flexible Joints—Ductile-Iron Pressure Pipe 7
2 References	2	3	Cut Grooving Dimensions For Rigid Joints—Ductile-Iron Pressure Pipe 8
3 Definitions	2		
4 Requirements			
4.1	Information to Be Provided by Manufacturer 3		
4.2	Materials 3		

Foreword

This foreword is for information only and is not a part of ANSI /AWWA C606.*

I. Introduction.

I.A. *Background.* Grooved and shouldered joints have been used since the early 1900s. To ensure continued quality of this type of joint, this standard has been developed for its manufacture.

In 1971, the AWWA Standards Council received a request to develop a standard for a type of pipe jointing that employs the principle of clamping together grooved or shouldered ends of pipe and fittings with a flexible gasket for closure. Because of this request, the AWWA Standards Council formed an exploratory ad hoc committee “to consider grooved and shouldered type joints and fittings, and to determine how best to arrive at an appropriate AWWA standard for such joints and fittings.”

The ad hoc committee recommended “that the AWWA Standards Council establish a standards committee for the development of a standard in one document for grooved and shouldered type joints and fittings for steel, gray-iron, and ductile-iron pipe for water and other liquids as appropriate.” On June 7, 1972, the council established the AWWA Standards Committee on Grooved and Shouldered Type Joints, and the committee held its first meeting on that date.

I.B. *History.* The first edition of this standard, designated [ANSI/AWWA C606-78](#)—Grooved and Shouldered Type Joints, was published in 1978. The second edition of the standard, designated as [ANSI/AWWA C606-81](#), was approved by AWWA on Jan. 25, 1981, by ANSI on May 12, 1981, and was accepted by the Department of Defense on Apr. 5, 1982.

The third edition, designated [ANSI/AWWA C606-87](#), was approved by the AWWA Board of Directors on Jan. 25, 1987, and by ANSI on Apr. 15, 1987. The major revisions contained in the 1987 edition were the deletion of all information on and references to gray cast-iron pipe. Tables relating to gray cast-iron pipe were eliminated, tables showing metric dimensions were eliminated, and metric conversion factors were added as footnotes; tables were renumbered. The fourth edition was approved on June 15, 1997. Major revisions contained in the 1997 edition included the following: the format was changed to the AWWA standard style, Table 1 was added, the figure above Table 5 was revised, a requirement that field grooves be identified by the groover’s

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

unique mark was added, definitions were revised and the term *fabricator* was retained, the applied load for the hydrostatic deflected joint test was moved from the midpoint of the coupling to the pipe on either side of the coupling, and machining of the inside diameter of the pipe was approved for the hydrostatic joint test. The fifth edition was approved on Jan. 18, 2004. Major revisions contained in the 2004 edition included the following: the definition of dimension *T* in Tables 2 and 3 was revised, nominal metric conversions were changed from soft to hard values, and the tolerance values were corrected in Table 2. The sixth edition was approved on June 11, 2006. Revisions contained in the 2006 edition included minor format changes to the foreword. The seventh edition was approved on June 12, 2011. Major revisions in the 2011 edition included expanded scope to include 30- and 36-in. pipe; nominal dimensions were converted to soft metric units, 1 in. = 25 mm; gasket material grade changes were added in Table 1; and nominal wall thickness changes were made to pipe sizes 18 in. and larger in Tables 2 and 3. The last edition was approved on Jan. 24, 2015. This edition was approved on Oct. 24, 2022.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. Specific policies of the state or local agency.
2. Two standards developed under the direction of NSF[†]: NSF/ANSI/CAN[‡] 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects.

* Persons outside the United States should contact the appropriate authority having jurisdiction.

[†] NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48113.

[‡] Standards Council of Canada, 55 Metcalfe Street, Suite 600, Ottawa, ON K1P 6L5 Canada.

3. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,[§] and other standards considered appropriate by the state, provincial, or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI/CAN 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdictions. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI/CAN 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final Maximum Contaminant Level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C606 does not address additives requirements. Users of this standard should consult the appropriate state, provincial, or local agency having jurisdiction to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues.

II.A. Advisory Information on Product Application.

1. This standard includes definitions for both the manufacturer and the fabricator. For the purpose of this standard, the manufacturer is the party that produces the coupling. The fabricator is the party that grooves or fabricates special ends for the pipe, fittings, valves, or other components.

II.B. Chlorine and Chloramine Degradation of Elastomers

The selection of materials is critical for water service and distribution piping in locations where there is a possibility that elastomers will be in contact with chlorine or chloramines. Documented research has shown that elastomers such as gaskets, seals, valve seats, and encapsulations may be degraded when exposed to chlorine or chloramines. The impact of degradation is a function of the type of elastomeric material, chemical concentration, contact surface area, elastomer cross section, and environmental conditions, including temperature. Careful selection of and specifications

[§] Both publications available from National Academy of Sciences, 500 Fifth Street, NW, Washington, DC 20001.

for elastomeric materials and the specifics of their application for each water system component should be considered to provide long-term usefulness and minimum degradation (swelling, loss of elasticity, or softening) of the elastomer specified.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the application being considered.

III.A. *Purchaser Options and Alternatives.* The following information should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA C606, Grooved and Shouldered Joints, of latest revision.
2. Pipe class or thickness, grade, and nominal outside diameter.
3. Type of coupling—grooved or shouldered, flexible or rigid.
4. Type of pipe end—cut groove (DIP - flexible or rigid) or cut groove, roll groove, shoulder (type of shoulder).
5. The pH or temperature of water, if unusual.
6. Internal working pressure.
7. Type of protective coating, if other than the standard of the coupling and pipe manufacturer.
8. Whether catalog data and certified shop drawings shall be provided (Sec. 4.1.2).
9. Whether test records shall be provided (Sec. 4.1.3).
10. Whether compliance with federal, state, or local requirements is not required (Sec. 4.2.1).
11. Whether the type of material required for housings is other than ductile or malleable iron (Sec. 4.2.3).
12. Whether the type of material required for bolts and nuts is other than carbon steel (Sec. 4.2.4).
13. Whether the type of material required for gaskets is other than what is required in Table 1 (Sec. 4.2.5.1).
14. Whether flexible joints for shouldered-end pipe shall be other than that indicated in Table 6 (Sec. 4.3.1.5.5).
15. Whether dimensions for cut grooves shall be other than those found in Table 4 (Sec. 4.3.3.1.1).
16. Whether dimensions for rolled grooves shall be other than those found in Table 5 (Sec. 4.3.3.2.1).

17. Whether dimensions for mechanical shoulders shall be other than those found in Table 6 (Sec. 4.3.5).

18. Whether the purchaser desires to inspect the couplings at the manufacturer's plant, or to inspect the end preparations at the fabricator's location, or both. (Sec. 5.1.3).

19. Whether cap OD shall be other than that required in Tables 2 through 6 (Sec. 4.3).

20. Whether dimension C shall be other than as required in Tables 2 through 6 (Sec. 4.3).

21. Whether dimensions A and B shall be other than as required in Tables 2 through 6 (Sec. 4.3).

22. Requirements for repairs, replacement, and retesting under (Sec. 5.3) Basis for Nonconformance.

23. Whether manufacturer shall provide an affidavit of compliance (Sec. 6.2).

III.B. *Modification to Standard.* Any modification of the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Revisions made to the standard in this edition include the following:

1. Addition of permeation material requirements in Sec. 4.2.2.
2. Clarifications to several design requirements in Sec. 4.3.
3. Addition of thrust restraint design requirements in Sec. 4.3.1.5.
4. Clarifications to pressure testing requirements in Sec. 5.2.
5. Clarifications to nonconformance requirements in Sec. 5.3.

V. Comments. If you have any comments or questions about this standard, please contact AWWA Engineering and Technical Services at 303.794.7711, FAX at 303.795.7603; write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098; or email at standards@awwa.org.

This page intentionally blank.



**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA C606-22
(Revision of [ANSI/AWWA C606-15](#))

AWWA Standard

Grooved and Shouldered Joints

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes grooved and shouldered joints for ductile-iron pipe (DIP), metallic pressure pipe of iron pipe size (IPS), fittings, and other components for water, wastewater, reclaimed water, and other services. The standard describes 4-in. through 36-in. (100-mm through 900-mm) diameter grooved ductile-iron pipe; ¾-in. through 24-in. (19-mm through 600-mm) diameter grooved steel, aluminum, brass, and other metallic pipe of IPS dimensions; and 4-in. through 64-in. (100-mm through 1,600-mm) nominal diameter shouldered ends for ductile-iron pipe and metallic pipe. Joint sizes other than those listed are outside the scope of this product standard.

Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for grooved and shouldered joints, including materials, dimensions, tolerances, inspection, proof of design procedures, markings, and production testing. Grooved and shouldered joints outside of Tables 2–6 shall comply with all the minimum requirements of the general design, materials, inspection, proof of design procedures, markings, and production testing.

Sec. 1.3 Application

This standard can be referenced for purchasing and receiving pressure pipe, fittings, and other components composed of ductile-iron, steel, and nonferrous metals for water supply, wastewater, reclaimed wastewater, and other services.

SECTION 2: REFERENCES

This standard references the following documents. In their latest editions, they form a part of this standard to the extent specified within the standard. In any case of conflict, the requirements of this standard shall prevail.

[ANSI*/AWWA C151/A21.51](#)—Ductile-Iron Pipe, Centrifugally Cast.

[ANSI/AWWA C200](#)—Steel Water Pipe, ½in. (12 mm) and Larger.

[ANSI/AWWA C604](#)—Installation of Buried Steel Water Pipe—4in. (100mm) and Larger.

[AWWA Manual M11](#)—Steel Pipe-A Guide for Design and Installation.

ASME B31—Standards for Pressure Piping.

[ASTM[†] A47](#)—Standard Specification for Ferritic Malleable Iron Castings.

[ASTM A183](#)—Standard Specification for Carbon Steel Track Bolts and Nuts.

[ASTM A449](#)—Standard Specification for Hex Cap Screws, Bolts, and Studs, Steel, Heat Treated, 120/105/90 kpsi Minimum Tensile Strength, General Use.

[ASTM A536](#)—Standard Specification for Ductile Iron Castings.

[ASTM D2000](#)—Standard Classification System for Rubber Products in Automotive Applications.

NFPA[‡] 13—Standard for the Installation of Sprinkler Systems.

NSF[§]/ANSI/CAN[¶] 61—Drinking Water System Components—Health Effects.

SECTION 3: DEFINITIONS

The following definitions shall apply in this standard:

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

† ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428.

‡ National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169.

§ NSF International, 789 North Dixboro Road, Ann Arbor, MI 48113.

¶ Standards Council of Canada, 55 Metcalfe Street, Suite 600, Ottawa, ON K1P 6L5 Canada.