

ANSI/AWWA **C652-19**
(Revision of *ANSI/AWWA C652-11*)

AWWA Standard

Disinfection of Water-Storage Facilities

Effective date: April 1, 2020.

First edition approved by Board of Directors June 15, 1980.

This edition approved Oct. 28, 2019.

Approved by American National Standards Institute Nov. 12, 2019.



American Water Works
Association



Documents

Document Sharing Hub


AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or code of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; 212.642.4900, or e-mailing info@ansi.org.



ISBN-13, print: 978-1-62576-373-0

ISBN-13, electronic: 978-1-61300-541-5

DOI: <http://dx.doi.org/10.12999/AWWA.C652.19>

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher.

Copyright © 2020 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Disinfection of Facilities, which reviewed and approved this standard, had the following personnel at the time of approval:

Betsy Reilley, *Chair*

General Interest Members

G. Boyd (*liaison, nonvoting*), Standards Council Liaison, The Cadmus Group, Seattle, Wash.

K.C. Choquette, Iowa Department of Public Health, Des Moines, Iowa

J.M. Henderson, West Linn, Ore.

E. Meek (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.

A.A. Rosenblatt, Gordon & Rosenblatt LLC, New York, N.Y.

S. Vidika, Dixon Engineering Inc., Medina, Ohio

J.S. Wailes, Black Hawk, Colo.

M.L. Wentink, Nebraska DHHS DPH, North Platte, Neb.

Producer Members

R.J. Gordhamer, Measurement Technologies Inc., Redmond, Wash.

M.P. Parker, Statewide Aquastore Inc., East Syracuse, N.Y.

P.L. Smith, Smith LaSalle Inc., Western Springs, Ill.

User Members

Z. Bukhari, American Water, Voorhees, N.J.

R.C. Lorenz, Westerville Water Plant, Westerville, Ohio

P.M. Marchand, Providence Water Supply Board, Providence, R.I.

J.A. Nilson, Seattle Public Utilities, Seattle, Wash.

D. O'Connor, Philadelphia Water Department, Philadelphia, Penn.

B. Reilley, Massachusetts Water Resources Authority, Boston, Mass.

G.J.R. Rhoads, Metro Water District of Southern California, La Verne, Calif.

E.D. Schwartz, New Jersey American Water, Hillsborough, N.J.

This page intentionally blank.



Documents

Document Sharing Hub

Copyright © 2020 American Water Works Association. All Rights Reserved

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		4 Requirements	
I	Introduction..... vii	4.1	Materials and Cleaning..... 4
I.A	Background..... vii	4.2	Forms of Chlorine for Disinfection 5
I.B	History..... vii	4.3	Methods of Chlorination..... 6
I.C	Acceptance vii	4.4	Disinfection Procedures When Conducting Underwater Inspection and/or Cleaning of Potable-Water-Storage Facilities ... 9
II	Special Issues. viii	5 Verification	
II.A	Information on Application of This Standard..... viii	5.1	Water Quality Sampling and Testing 13
III	Use of This Standard xi	6 Delivery..... 14	
III.A	Purchaser Options and Alternatives xii	Appendices	
III.B	Modification to Standard xiii	A	Chlorine Residual Testing..... 15
IV	Major Revisions..... xiii	B	Chlorine Dosages 17
V	Comments xiii	Tables	
Standard			
1 General			
1.1	Scope..... 1	B.1	Amounts of Chemical Required to Give Various Chlorine Concentrations in 100,000 gal (378.5 m ³) of Water 17
1.2	Purpose 2	B.2	Amounts of Chemical Required to Give a Chlorine Concentration of 200 mg/L in Various Volumes of Water 17
1.3	Application..... 2		
2	References 2		
3	Definitions 3		

This page intentionally blank.



Foreword

This foreword is for information only and is not a part of ANSI/AWWA C652.*

I. Introduction.

I.A. *Background.* This standard describes methods of disinfecting water-storage tanks. The disinfecting agents discussed in this standard are chlorine solutions, and several combinations of free chlorine residual and contact time (CT) are provided. The chlorine solutions may be derived from liquid chlorine (Cl_2), calcium hypochlorite ($\text{Ca}(\text{OCl})_2$), or sodium hypochlorite (NaOCl).

I.B. *History.* This standard was first approved on June 15, 1980, under the designation [ANSI/AWWA D105](#), Standard for Disinfection of Water-Storage Facilities. The 1980 edition was developed from information originally contained in [AWWA D102-64](#), modified to include disinfection of water-storage facilities constructed of steel or other materials. The standard was redesignated ANSI/AWWA C652 with the 1986 edition. It was later revised in 1992 and again in 2002. The 2011 edition was approved by the AWWA Board of Directors on June 12, 2011. This edition was approved on Oct. 28, 2019.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF[†] International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). AWWA and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.[‡] Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. Specific policies of the state or local agency.

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

[†] NSF International, 789 North Dixboro Road, Ann Arbor, MI 48105.

[‡] Persons outside the United States should contact the appropriate authority having jurisdiction.

2. Two standards developed under the direction of NSF, NSF/ANSI/CAN* 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects.

3. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,[†] and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI/CAN 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI/CAN 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C652 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues.

II.A. *Information on Application of This Standard.* Utilities are increasingly focusing on water-storage reservoir management and maintenance as part of preserving distribution system water quality. Disinfection of water-storage tanks presents special challenges because of the quantity of water that must be dealt with, the conditions of the water supplied to the tank, and the ability to collect representative samples of the water in the tank.

Disinfection of tanks and other facilities used for drinking water relies on high levels of free chlorine to ensure bacteria and other potential pathogens are inactivated. It should be noted that pH and temperature are two important factors affecting

* Standards Council of Canada, 55 Metcalfe Street, Suite 600, Ottawa, ON K1P 6L5 Canada.

[†] Both publications available from National Academy of Sciences, 500 Fifth Street, NW, Washington, DC 20001.

the disinfection process. Hypochlorous acid and hypochlorite are the two forms of chlorine present in water at pH greater than 3. Hypochlorous acid has been shown to be significantly more effective than hypochlorite for disinfection. Above pH 9, there is essentially no hypochlorous acid, only hypochlorite. Temperature also affects the effectiveness of disinfection; low temperatures are not as effective as high temperatures for chlorine disinfection. The high chlorine dosages required in this standard are necessary to provide effective disinfection under varying conditions of pH, temperature, and other factors.

In addition, systems using chloramines in their water supply will need to consider the impacts of chloramines and free chlorine mixing within the tank to be disinfected. Higher chlorine doses will be required to achieve the specified free chlorine residuals listed in this standard (to pass through breakpoint chlorination). Depending on the method selected, if a free chlorine residual is present in the tank to be activated into the water system, it could result in depressed residuals in the service area it supplies.

Following disinfection and before activating the tank for use, water in the storage tank should be tested to determine that it meets expected parameters typical in the system. Consider especially the work done in the tank and appropriate parameters to measure. Test results should confirm that the water quality is appropriate for distribution. Although this assessment is unique for each system, suggested test parameters include pH, alkalinity, turbidity, odor, and specific conductance. If the tank was painted or if epoxy was applied, measuring levels of volatile organic compounds (VOCs) or other components of the coating material (such as zinc) may be necessary, noting that the trihalomethanes (THMs) chloroform, bromodichloromethane, dibromochloromethane, and bromoform, which are part of the VOC test, are a result of disinfection, not coating materials, and would be expected to be present. Satisfactory chlorine residual and coliform results are also required.

When collecting samples for analysis of coliform or other parameters, it is important that the sample represent the water quality in the tank. Sample taps need to be clean and sanitary. In some cases, samples may need to be collected from the top of the tank or hatch. When sampling from the top of the tank or hatch, use of a depth sampler may be beneficial to best represent the quality of water that will enter the system.

For bacteriological tests, the results of testing must show no coliform. Given the different test procedures available for coliform analysis, results should be expressed as “confirmed coliform” and should be <1 cfu/100 mL, < 1 MPN/100 mL, or “Absent.”

While bacteriological testing in accordance with Section 5 is used to verify the absence of coliform organisms and is generally accepted as verification that acceptable

disinfection has been accomplished, following sanitary procedures during the course of all work is necessary to ensure the disinfected tank will be ready for activation.

Disinfectants other than chlorine may be appropriate to use. While this standard describes only the use of liquid chlorine (gas), sodium hypochlorite solutions, and calcium hypochlorite, the applicability of other disinfectants should be evaluated. Ozone, chlorine dioxide, and chemical cleaners have been used, and these warrant further investigation. Whichever disinfectant or method is selected, approval from the local regulatory agency may be required.

Depending upon the nature of the work in the water-storage facility, disinfection may or may not be required. Storage facilities dewatered for purposes of entering the tank and performing painting, repairs, or other highly invasive activities shall be disinfected and sampled. In some cases, the tank may remain in service, or isolated, for minimally intrusive activities such as remotely operated vehicle (ROV) or diver inspections. Where rigorous sanitary procedures have been followed, only sampling may be required.

As more frequent inspections and cleaning of reservoirs are required, utilities are turning to methods that minimize downtime and wasted water. Utilities may use methods employing divers or ROVs for both inspection and sediment removal. Section 4.4 of this standard describes the disinfection procedures and operational considerations for conducting inspection and cleaning in potable-water-storage facilities. Any underwater retrieval of ROVs with divers must be performed in accordance with all aspects of this standard. When selecting a contractor to perform this type of work, it is essential to evaluate their experience, safety procedures, and methods. Each bidder should be willing to meet the minimum requirements set by this standard for safe performance of the work. This standard includes references to pertinent OSHA regulations. There are specific technical skills a purchaser should look for when considering a firm for this type of work, such as the following:

- Qualifications for conducting in-service operations in compliance with OSHA.
- Qualifications for inspecting and evaluating steel/concrete/wood or membrane-covered reservoirs.
- Résumés for the specific personnel who will perform underwater inspection and/or cleaning.