

ANSI/AHRI Standard 280

2011 Standard for

Requirements for the Qualification of Reverberation Rooms in the 63 Hz Octave Band



Approved by ANSI on April 17, 2012



**Air-Conditioning, Heating,
and Refrigeration Institute**

2111 Wilson Boulevard, Suite 500
Arlington, VA 22201, USA
www.ahrinet.org

PH 703.524.8800
FX 703.562.1942



Documents

Document Sharing Hub

IMPORTANT

SAFETY DISCLAIMER

AHRI does not set safety standards and does not certify or guarantee the safety of any products, components or systems designed, tested, rated, installed or operated in accordance with this standard/guideline. It is strongly recommended that products be designed, constructed, assembled, installed and operated in accordance with nationally recognized safety standards and code requirements appropriate for products covered by this standard/guideline.

AHRI uses its best efforts to develop standards/guidelines employing state-of-the-art and accepted industry practices. AHRI does not certify or guarantee that any tests conducted under its standards/guidelines will be non-hazardous or free from risk.

Note:

This standard supersedes ANSI/AHRI Standard 280-2008.

TABLE OF CONTENTS

SECTION	PAGE
Section 1. Purpose.....	1
Section 2. Scope.....	1
Section 3. Definitions.....	1
Section 4. Reverberation Room Qualification and Testing Procedures	2
Section 5. Conformance Conditions	3

TABLES

Table 1. Broadband Standard Deviation Limits.....	2
Table 2. Pure Tone Standard Deviation	3

APPENDICES

Appendix A. References – Normative	4
Appendix B. References – Informative	4