



# **Information technology — Generic cabling for customer premises**

## **Part 6: Distributed building services (ISO/IEC 11801-6:2017, MOD)**



AS 11801.6:2019

This Australian Standard® was prepared by CT-001, Communications Cabling. It was approved on behalf of the Council of Standards Australia on 5 April 2019.

This Standard was published on 46 May 2019.

The following are represented on Committee CT-001:

- Australian Chamber of Commerce and Industry
- Australian Council of Trade Unions
- Australian Digital and Telecommunications Industry Association
- Australian Industry Group
- Australian Information Industry Association
- BICSI South Pacific (Australia)
- Energy Networks Australia
- Engineers Australia
- KNX National Group
- National Electrical and Communications Association
- Telstra Corporation

This Standard was issued in draft form for comment as DR AS 11801.6:2018.

### **Keeping Standards up-to-date**

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

[www.standards.org.au](http://www.standards.org.au)

ISBN 978 1 76072 442 9



# **Information technology — Generic cabling for customer premises**

## **Part 6: Distributed building services (ISO/IEC 11801-6:2017, MOD)**

First published as AS 11801.6:2019.

### **COPYRIGHT**

© ISO/IEC — All rights reserved  
© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth).

## Preface

This Standard was prepared by the Australian members of the Joint Standards Australia/Standards New Zealand Committee CT-001, Communications Cabling.

The objective of this Standard specifies generic cabling within premises that comprise single or multiple buildings on a campus. It covers balanced cabling and optical fibre cabling.

This Standard has been prepared to reflect the increasing use of generic cabling in support of non-user specific services and the sharing of information between such services that can also incorporate the supply of power, including—

- (a) telecommunications, e.g. wireless access points, distributed antenna systems;
- (b) energy management, e.g. lighting, power distribution, incoming utility metering;
- (c) environmental control, e.g. temperature, humidity;
- (d) personnel management, e.g. access control, cameras, PIR detectors, time and attendance monitoring, electronic signage, audio-visual projectors;
- (e) personal information and alarms, e.g. paging, patient monitoring, nurse call, infant security;
- (f) intelligent building systems.

This Standard specifies directly or via reference to AS/NZS ISO/IEC 11801-1—

- (i) the structure and configuration for generic cabling for distributed building services;
- (ii) the interfaces at the service outlet (SO);
- (iii) the performance requirements for cabling links and channels;
- (iv) the implementation requirements and options;
- (v) the performance requirements for cabling components;
- (vi) the conformance requirements and verification procedures.

Safety (e.g. electrical safety and protection, fire) and electromagnetic compatibility (EMC) requirements are outside the scope of this Standard, and are covered by other Standards and by regulations. However, information given by this Standard can be of assistance.

This Standard is intended to be read in conjunction with AS/NZS 11801-1, *Information Technology — Generic cabling for customer premises, Part 1: General requirements (ISO/IEC 11801-1:2017, MOD)*.

This Standard is one of a series of customer cabling Standards addressing design, minimum specification and performance of links and channels, cable/cabling accommodation and installation, conformance testing and administration.

This Standard is part of a series of Standards which are associated with other Australian Standards, Australian/New Zealand Standards and International Standards.

Standards which are part of the series and Standards that are associated with this Standard are as follows:

AS/NZS 11801.1, *Information technology—Generic cabling for customer premises, Part 1: General requirements (ISO/IEC 11801-1:2017, MOD)*

AS 11801.2, *Information technology—Generic cabling for customer premises, Part 2: Office premises (ISO/IEC 11801-2:2017, MOD)*

AS 11801.3, *Information technology—Generic cabling for customer premises, Part 3: Industrial premises (ISO/IEC 11801-3:2017, MOD)*

AS 11801.4, *Information technology—Generic cabling for customer premises, Part 4: Single-tenant homes (ISO/IEC 11801-4:2017, MOD)*

AS 11801.5, *Information technology—Generic cabling for customer premises, Part 5: Data centres (ISO/IEC 11801-5:2017, MOD)*

AS 11801.6, *Information technology—Generic cabling for customer premises, Part 6: Distributed building services (ISO/IEC 11801-6:2017, MOD)* (this Standard)

AS 30129, *Information technology—Telecommunications bonding networks for buildings and other structures (ISO/IEC 30129:2015 MOD)*

AS/NZS 2967, *Optical fibre communication cabling systems safety*

AS/NZS 3084, *Telecommunications installations—Telecommunications pathways and spaces for commercial buildings*

AS/NZS 3085.1, *Telecommunications installations—Administration of communications cabling systems, Part 1: Basic requirements*

AS/NZS ISO/IEC 14763.2, *Information technology—Implementation and operation of customer premises cabling, Part 2: Planning and installation*

AS/NZS 14763.3, *Information technology—Implementation and operation of customer premises cabling, Part 3: Testing of optical fibre cabling (ISO/IEC 14763-3:2014, MOD)*

IEC 61935-1, *Specification for the testing of balanced and coaxial information technology cabling — Part 1: Installed balance cabling as specified in ISO/IEC 11801 and related standards*

IEC 61935-2, *Specification for the testing of balanced and coaxial information technology cabling — Part 2: Cords as specified in ISO/IEC 11801 and related standards*

This Standard is an adoption with national modifications, and has been reproduced from, ISO/IEC 11801-6:2017, *Information technology — Generic cabling for customer premises — Part 6: Distributed building services* and its Corrigendum No. 1 (2018). The modifications in Appendix ZZ are additional requirements, which have been added at the end of the source text.

Appendix ZZ lists the variations to ISO/IEC 11801-6:2017 for the application of this Standard in Australia.

This Standard is structured as follows:

- (A) Preface.
- (B) ISO/IEC 11801-6:2017 (unedited from the contents page to the final clause of the source document) and its Corrigendum No. 1 (2018).
- (C) Appendix ZZ lists the variations to ISO/IEC 11801-6:2017 for the application of this Standard in Australia.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this part of ISO/IEC 11801” should read “this Australian Standard”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

## NOTES

## CONTENTS

|                                                                            |    |
|----------------------------------------------------------------------------|----|
| FOREWORD.....                                                              | 5  |
| INTRODUCTION.....                                                          | 6  |
| 1 Scope.....                                                               | 9  |
| 2 Normative references .....                                               | 9  |
| 3 Terms, definitions and abbreviated terms .....                           | 10 |
| 3.1 Terms and definitions.....                                             | 10 |
| 3.2 Abbreviated terms.....                                                 | 11 |
| 4 Conformance.....                                                         | 11 |
| 5 Structure of the generic cabling system .....                            | 12 |
| 5.1 General.....                                                           | 12 |
| 5.2 Functional elements.....                                               | 12 |
| 5.2.1 Stand-alone structure .....                                          | 12 |
| 5.2.2 Overlay structure .....                                              | 13 |
| 5.3 General structure and hierarchy.....                                   | 13 |
| 5.3.1 Type A generic cabling .....                                         | 13 |
| 5.3.2 Type B generic cabling .....                                         | 14 |
| 5.4 Cabling subsystems.....                                                | 15 |
| 5.4.1 Campus and building backbone cabling subsystem.....                  | 15 |
| 5.4.2 Service distribution cabling subsystem (Type A generic cabling)..... | 15 |
| 5.4.3 Service distribution cabling subsystem (Type B generic cabling)..... | 15 |
| 5.4.4 Design objectives .....                                              | 16 |
| 5.5 Accommodation of functional elements .....                             | 16 |
| 5.5.1 General .....                                                        | 16 |
| 5.5.2 Accommodation of service outlets.....                                | 16 |
| 5.5.3 Accommodation of service concentration points.....                   | 17 |
| 5.6 Interfaces.....                                                        | 17 |
| 5.6.1 Equipment interfaces and test interfaces .....                       | 17 |
| 5.6.2 Channels and links .....                                             | 18 |
| 5.7 Dimensioning and configuring .....                                     | 19 |
| 5.7.1 General .....                                                        | 19 |
| 5.7.2 Type A generic cabling .....                                         | 21 |
| 5.7.3 Type B generic cabling .....                                         | 22 |
| 5.7.4 Service concentration point.....                                     | 23 |
| 5.7.5 Connecting hardware.....                                             | 23 |
| 5.7.6 Telecommunications rooms and equipment rooms .....                   | 23 |
| 5.8 Relevant building services .....                                       | 23 |
| 6 Channel performance requirements .....                                   | 23 |
| 6.1 General.....                                                           | 23 |
| 6.2 Environmental performance .....                                        | 25 |
| 6.3 Transmission performance .....                                         | 25 |
| 6.3.1 General .....                                                        | 25 |
| 6.3.2 Balanced cabling .....                                               | 25 |
| 6.3.3 Optical fibre cabling.....                                           | 26 |
| 7 Link performance requirements .....                                      | 26 |
| 7.1 General.....                                                           | 26 |
| 7.2 Balanced cabling .....                                                 | 27 |

|         |                                                             |    |
|---------|-------------------------------------------------------------|----|
| 7.3     | Optical fibre cabling .....                                 | 27 |
| 8       | Reference implementations .....                             | 27 |
| 8.1     | General.....                                                | 27 |
| 8.2     | Balanced cabling .....                                      | 27 |
| 8.2.1   | General .....                                               | 27 |
| 8.2.2   | Service distribution cabling (Type A generic cabling) ..... | 28 |
| 8.2.3   | Service distribution cabling (Type B generic cabling) ..... | 31 |
| 8.2.4   | Campus and building backbone cabling .....                  | 31 |
| 8.3     | Optical fibre cabling .....                                 | 31 |
| 8.3.1   | Service distribution cabling (Type A generic cabling) ..... | 31 |
| 8.3.2   | Service distribution cabling (Type B generic cabling) ..... | 32 |
| 8.3.3   | Campus and building backbone cabling .....                  | 32 |
| 9       | Cable requirements .....                                    | 32 |
| 9.1     | General.....                                                | 32 |
| 9.2     | Balanced cables .....                                       | 32 |
| 9.3     | Optical fibre cables .....                                  | 32 |
| 10      | Connecting hardware requirements .....                      | 32 |
| 10.1    | General requirements .....                                  | 32 |
| 10.2    | Connecting hardware for balanced cabling.....               | 32 |
| 10.2.1  | General requirements .....                                  | 32 |
| 10.2.2  | Electrical, mechanical and environmental performance .....  | 32 |
| 10.3    | Connecting hardware for optical fibre cabling.....          | 33 |
| 11      | Cords .....                                                 | 33 |
| 11.1    | Jumpers.....                                                | 33 |
| 11.2    | Balanced cords .....                                        | 33 |
| 11.3    | Optical fibre cords.....                                    | 33 |
| Annex A | (informative) Services and applications .....               | 34 |
| A.1     | Overview.....                                               | 34 |
| A.2     | Service sectors and services.....                           | 34 |
| A.2.1   | Access control .....                                        | 34 |
| A.2.2   | Burglar alarms .....                                        | 35 |
| A.2.3   | Asset management .....                                      | 35 |
| A.2.4   | Audio-visual.....                                           | 35 |
| A.2.5   | Building information systems .....                          | 35 |
| A.2.6   | Building well-being and structural sensor systems .....     | 35 |
| A.2.7   | Energy management.....                                      | 35 |
| A.2.8   | Environmental control .....                                 | 36 |
| A.2.9   | Fixed information technology services .....                 | 36 |
| A.2.10  | Personal well-being .....                                   | 36 |
| A.2.11  | Shared information technology services.....                 | 36 |
| A.3     | Service concentration point grid density .....              | 38 |
| A.4     | Cabling provision to service concentration points .....     | 39 |
| Annex B | (informative) Overlay .....                                 | 40 |
| B.1     | General.....                                                | 40 |
| B.2     | Functional elements.....                                    | 40 |
| B.2.1   | Type A generic cabling .....                                | 40 |
| B.2.2   | Type B generic cabling .....                                | 40 |
| B.3     | General structure and hierarchy.....                        | 40 |

|                                                                                                      |                                                                              |    |
|------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------|----|
| B.3.1                                                                                                | Type A generic cabling .....                                                 | 40 |
| B.3.2                                                                                                | Type B generic cabling .....                                                 | 40 |
| Annex C (informative)                                                                                | Optical fibre within the Type B service distribution cabling subsystem ..... | 41 |
| C.1                                                                                                  | Overview.....                                                                | 41 |
| C.2                                                                                                  | Implementation recommendations.....                                          | 41 |
| C.2.1                                                                                                | Channel performance .....                                                    | 41 |
| C.2.2                                                                                                | Reference implementation .....                                               | 41 |
| C.2.3                                                                                                | Cables .....                                                                 | 42 |
| C.2.4                                                                                                | Connecting hardware.....                                                     | 42 |
| C.2.5                                                                                                | Cords .....                                                                  | 42 |
| Bibliography.....                                                                                    |                                                                              | 43 |
| Figure 1 – Relationships between the generic cabling documents produced by ISO/IEC JTC 1/SC 25 ..... |                                                                              | 7  |
| Figure 2 – Structure of Type A generic cabling.....                                                  |                                                                              | 13 |
| Figure 3 – Hierarchical structure of Type A generic cabling.....                                     |                                                                              | 14 |
| Figure 4 – Structure of Type B generic cabling.....                                                  |                                                                              | 14 |
| Figure 5 – Hierarchical structure of Type B generic cabling.....                                     |                                                                              | 15 |
| Figure 6 – Accommodation of functional elements .....                                                |                                                                              | 16 |
| Figure 7 – Cabling without the use of an SO .....                                                    |                                                                              | 17 |
| Figure 8 – Accommodation of TEs (Type B generic cabling).....                                        |                                                                              | 17 |
| Figure 9 – Test and equipment interfaces (Type A generic cabling) .....                              |                                                                              | 18 |
| Figure 10 – Test and equipment interfaces (Type B generic cabling).....                              |                                                                              | 18 |
| Figure 11 – Example of a Type A generic cabling system with combined BD and SD .....                 |                                                                              | 20 |
| Figure 12 – Connection of functional elements providing redundancy for Type A generic cabling .....  |                                                                              | 20 |
| Figure 13 –Transmission performance of a service distribution channel .....                          |                                                                              | 24 |
| Figure 14 – Example of a system showing the location of cabling interfaces .....                     |                                                                              | 25 |
| Figure 15 – Link options.....                                                                        |                                                                              | 27 |
| Figure 16 – Service distribution cabling models .....                                                |                                                                              | 29 |
| Figure A.1 – Wireless application coverage area grid.....                                            |                                                                              | 38 |
| Figure C.1 – Combined optical fibre backbone and service distribution channels .....                 |                                                                              | 42 |
| Table 1 – Maximum channel lengths for Type A reference implementations .....                         |                                                                              | 21 |
| Table 2 – Maximum channel lengths for Type B reference implementations .....                         |                                                                              | 22 |
| Table 3 – Service distribution channel length formulae in metres .....                               |                                                                              | 30 |
| Table A.1 – Supported wireless applications .....                                                    |                                                                              | 37 |
| Table A.2 – Recommended SCP grid dimensions .....                                                    |                                                                              | 39 |
| Table A.3 – Estimated SOs per SCP .....                                                              |                                                                              | 39 |

# INFORMATION TECHNOLOGY – GENERIC CABLING FOR CUSTOMER PREMISES –

## Part 6: Distributed building services

### FOREWORD

- 1) ISO (the International Organization for Standardization) and IEC (the International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards through technical committees established by the respective organization to deal with particular fields of technical activity. ISO and IEC technical committees collaborate in fields of mutual interest. Other international organizations, governmental and non-governmental, in liaison with ISO and IEC, also take part in the work. In the field of information technology, ISO and IEC have established a joint technical committee, ISO/IEC JTC 1.
- 2) The formal decisions or agreements of IEC and ISO on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees and ISO member bodies.
- 3) IEC, ISO and ISO/IEC publications have the form of recommendations for international use and are accepted by IEC National Committees and ISO member bodies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC, ISO and ISO/IEC publications is accurate, IEC or ISO cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees and ISO member bodies undertake to apply IEC, ISO and ISO/IEC publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any ISO, IEC or ISO/IEC publication and the corresponding national or regional publication should be clearly indicated in the latter.
- 5) ISO and IEC do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. ISO or IEC are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or ISO or its directors, employees, servants or agents including individual experts and members of their technical committees and IEC National Committees or ISO member bodies for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication of, use of, or reliance upon, this ISO/IEC publication or any other IEC, ISO or ISO/IEC publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this ISO/IEC publication may be the subject of patent rights. ISO and IEC shall not be held responsible for identifying any or all such patent rights.

International Standard ISO/IEC 11801-6 was prepared by subcommittee 25: Interconnection of information technology equipment, of ISO/IEC joint technical committee 1: Information technology.

ISO/IEC 11801-6 is to be read in conjunction with ISO/IEC 11801-1, which was created to consolidate general requirements for generic cabling into a single standard which allows the other standards in the ISO/IEC 11801 series to have a common reference.

This International Standard has been approved by vote of the member bodies, and the voting results can be obtained from the address given on the second title page.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the ISO/IEC 11801 series, published under the general title *Information technology – Generic cabling for customer premises*, can be found on the IEC website.

## INTRODUCTION

The importance of cabling infrastructure is similar to that of other fundamental utilities such as water and energy supply and interruptions to the services provided over that infrastructure can have a serious impact. A lack of design foresight, the use of inappropriate components, incorrect installation, poor administration or inadequate support can threaten quality of service and have commercial consequence for all types of users.


This document specifies generic cabling for distributed building services and can be used alone or in conjunction with all the premises-specific standards of the ISO/IEC 11801 series.

It has been prepared to reflect the increasing use of generic cabling in support of non-user specific services and the sharing of information between such services, many of which require the use of remote powered devices. The distribution of these services is implemented either as a stand-alone structure and configuration or as an overlay provided to locations other than those specified by premises-specific standards in the ISO/IEC 11801 series.

This document is not intended to replace the application of other premises-specific standards in the ISO/IEC 11801 series but has been prepared in recognition of the fact that, although certain functional elements of distributed building services cabling can be co-located with those of other generic cabling infrastructures, they can be

- a) specified, installed and operated by different entities than those responsible for other generic cabling infrastructures that are installed within the premises,
- b) specified and installed at a different time than other generic cabling infrastructures that are installed within the premises.

Figure 1 shows the schematic and contextual relationships between the standards relating to information technology cabling produced by ISO/IEC JTC 1/SC 25, namely the ISO/IEC 11801 series of standards for generic cabling design, standards for the installation, operation and administration of generic cabling and for testing of installed generic cabling.



IEC

**Figure 1 – Relationships between the generic cabling documents produced by ISO/IEC JTC 1/SC 25**

The generic cabling specified by this document provides users with

- a) an application independent system capable of supporting a wide range of applications in a range of installation and operating environments,
- b) a flexible scheme such that modifications are both easy and economical,
- c) a multi-vendor supply chain within an open market for cabling components.

In addition, this document provides

- d) relevant industry professionals with guidance allowing the accommodation of cabling before specific requirements are known, i.e. in the initial planning either for construction or refurbishment and for further deployment as the requirements of areas are defined,
- e) industry and standardization bodies with a cabling system which supports current products and provides a basis for future product development and applications standardization.

Applications addressed in this document include, but are not limited to those applications in ISO/IEC 11801:2017, Annex E, as used to support the following services:

- 1) telecommunications, e.g. wireless access points, distributed antenna systems;
- 2) energy management, e.g. lighting, power distribution, incoming utility metering;
- 3) environmental control, e.g. temperature, humidity;
- 4) personnel management, e.g. access control, cameras, passive infra-red (PIR) detectors, time and attendance monitoring, electronic signage, audio-visual projectors;
- 5) personal information and alarms, e.g. paging, patient monitoring, nurse call, infant security;

- 6) intelligent building systems;
- 7) communications between devices (i.e. “internet of things”).

Physical layer requirements for the applications listed in ISO/IEC 11801-1:2017, Annex E have been analysed to determine their compatibility with the cabling performance specified in this document and, together with statistics concerning premises geography from different countries and the models described in Clause 6, have been used to develop the requirements for cabling components and to stipulate their arrangement into cabling systems.

As a result, this document

- specifies a structure for generic cabling supporting a wide variety of applications including, but not restricted to, the applications in ISO/IEC 11801-1:2017, Annex E,
- adopts balanced cabling channel and link Classes E<sub>A</sub>, F and F<sub>A</sub>, specified in ISO/IEC 11801-1:2017,
- adopts optical fibre cabling channel and link requirements as specified in ISO/IEC 11801-1,
- adopts component requirements, specified in ISO/IEC 11801-1, and specifies cabling implementations that ensure performance of permanent links and of channels that meet or exceed the requirements of a specified group (e.g. Class) of applications.

Life expectancy of generic cabling systems can vary depending on environmental conditions, supported applications, aging of materials used in cables, and other factors such as access to pathways (campus pathways are more difficult to access than building pathways). With appropriate choice of components, generic cabling systems meeting the requirements of this document are expected to have a life expectancy of at least ten years.

This document has taken into account requirements specified in application standards listed in ISO/IEC 11801-1:2017, Annex E. It refers to International Standards for components and test methods whenever appropriate International Standards are available.

# INFORMATION TECHNOLOGY – GENERIC CABLING FOR CUSTOMER PREMISES –

## Part 6: Distributed building services

### 1 Scope

This part of ISO/IEC 11801 specifies generic cabling within premises that comprise single or multiple buildings on a campus. It covers balanced cabling and optical fibre cabling.

This document has been prepared to reflect the increasing use of generic cabling in support of non-user specific services and the sharing of information between such services that can also incorporate the supply of power, including

- 1) telecommunications, e.g. wireless access points, distributed antenna systems,
- 2) energy management, e.g. lighting, power distribution, incoming utility metering,
- 3) environmental control, e.g. temperature, humidity,
- 4) personnel management, e.g. access control, cameras, PIR detectors, time and attendance monitoring, electronic signage, audio-visual projectors,
- 5) personal information and alarms, e.g. paging, patient monitoring, nurse call, infant security,
- 6) intelligent building systems.

This document specifies directly or via reference to ISO/IEC 11801-1

- a) the structure and configuration for generic cabling for distributed building services,
- b) the interfaces at the service outlet (SO),
- c) the performance requirements for cabling links and channels,
- d) the implementation requirements and options,
- e) the performance requirements for cabling components,
- f) the conformance requirements and verification procedures.

Safety (e.g. electrical safety and protection, fire) and electromagnetic compatibility (EMC) requirements are outside the scope of this document, and are covered by other standards and by regulations. However, information given by this document can be of assistance.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO/IEC 11801-1:2017, *Information technology – Generic cabling for customer premises – Part 1: General requirements*

ISO/IEC 14763-2, *Information technology – Implementation and operation of customer premises cabling – Part 2: Planning and installation*

ISO/IEC 30129, *Information technology – Telecommunications bonding networks for buildings and other structures*

### 3 Terms, definitions and abbreviated terms

#### 3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO/IEC 11801-1, ISO/IEC 14763-2 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

##### 3.1.1

##### **building service**

non-user specific service within premises including, but not restricted to, building automation, security, access control, building management, wireless access points, information displays and alarm systems

##### 3.1.2

##### **distributed building service**

building service provided to locations additional to those specified in premises-specific standards in the ISO/IEC 11801 series

##### 3.1.3

##### **network conversion interface**

passive or active device allowing the attachment of cabling of different network topologies to a service concentration point

##### 3.1.4

##### **service area**

area in a room or facility where non-user specific equipment is placed and connected to the same service concentration point or groups of service outlets

##### 3.1.5

##### **service area cord**

cord connecting the service outlet to the terminal equipment

##### 3.1.6

##### **service concentration point**

##### **SCP**

connection point in the Type A generic cabling between a service distributor and a service outlet or a connection point offering connections to terminal equipment at the end of Type B generic cabling

##### 3.1.7

##### **service concentration point cable**

cable between a service concentration point and a service outlet

##### 3.1.8

##### **service distribution cable**

cable connecting the service distributor to the service outlet(s) of Type A cabling or service concentration point(s) of Type A or Type B cabling

##### 3.1.9

##### **service outlet**

##### **SO**

fixed connecting device where the service distribution cabling terminates

##### 3.1.10

##### **Type A generic cabling**

service distribution cabling between the service distributor and the service outlet

**3.1.11****Type B generic cabling**

service distribution cabling between the service distributor and the service concentration point when a service outlet is not used

**3.2 Abbreviated terms**

For the purposes of this document, the abbreviated terms given in ISO/IEC 11801-1 and the following apply.

|        |                                           |
|--------|-------------------------------------------|
| DAS    | distributed antenna system                |
| HVAC   | heating, ventilation and air conditioning |
| MIMO   | multiple input, multiple output           |
| NFC    | near field communication                  |
| OE EQP | opto-electronic equipment                 |
| PIR    | passive infrared                          |
| PP     | patch panel                               |
| RFID   | radio-frequency identification            |
| SCP    | service concentration point               |
| SD     | service distributor                       |
| SO     | service outlet                            |
| WAP    | wireless access point                     |

**4 Conformance**

For a cabling system to conform to this document the following applies.

- a) The configuration and structure shall conform to the requirements outlined in Clause 5.
- b) Channels shall meet the requirements specified in Clause 6 when subjected to environment conditions, local to the channels (see NOTE below), as defined by the applicable environmental Class(es) of Clause 6.

This shall be achieved by one of the following:

- 1) a channel design and implementation ensuring that the prescribed channel performance of Clause 6 is met;
  - 2) attachment of appropriate components to a permanent link or service concentration point (SCP) link design meeting the prescribed performance class of Clause 7. Channel performance shall be ensured where a channel is created by adding more than one cord to either end of a link meeting the requirements of Clause 7;
  - 3) for E<sub>1</sub> environments, using the reference implementations of Clause 8 and compatible cabling components conforming to the requirements of Clauses 9, 10 and 11, this is based upon a statistical approach of performance modelling.
- c) The interfaces to the cabling at the SO shall conform to the requirements of Clause 10 with respect to mating interfaces and performance when subjected to environment conditions, local to the connecting hardware (see NOTE below), as defined by the applicable environmental Class(es) of Clause 6.
  - d) Connecting hardware at other places in the cabling structure shall meet the performance requirements specified in Clause 10 when subjected to environment conditions, local to the connecting hardware (see NOTE below), as defined by the applicable environmental Class(es) of Clause 6,
  - e) The requirements of ISO/IEC 14763-2 and ISO/IEC 30129 shall be met.

This document does not specify which tests and sampling levels should be adopted. Test methods to assess conformance with the channel and link requirements of Clause 6 and Clause 7, respectively, are specified in ISO/IEC 11801-1. The test parameters to be measured, the sampling levels and the treatment of measured results to be applied for