



Gaseous hydrogen — Fuelling stations

Part 3: Valves (ISO 19880-3:2018, MOD)



AS 19880.3:2020

This Australian Standard® was prepared by ME-093, Hydrogen Technologies. It was approved on behalf of the Council of Standards Australia on 20 May 2020.

This Standard was published on 29 May 2020.

The following are represented on Committee ME-093:

- Association of Accredited Certification Bodies
- Australasian Fire and Emergency Service Authorities Council
- Australia New Zealand Industrial Gas Association
- Australian Energy Market Operator
- Australian Gas Association
- Australian Hydrogen Council
- Australian Industry Group
- Australian Pipelines and Gas Association
- Chemistry Australia
- CSIRO
- Department of Infrastructure, Regional Development and Cities
- Energy Networks Australia
- Engineers Australia
- Future Fuels Cooperative Research Centre
- Gas Appliance Manufacturers Association of Australia
- Gas Energy Australia
- Gas Technical Regulators Committee
- Institute of Chemical Engineers
- Institute of Electrical Inspectors
- National Energy Resources Australia
- University of Adelaide

This Standard was issued in draft form for comment as DR AS 19880.3:2020.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

ISBN 978 1 76072 859 5



Gaseous hydrogen — Fuelling stations

Part 3: Valves (ISO 19880-3:2018, MOD)

First published as AS 19880.3:2020.

COPYRIGHT

© ISO 2020 — All rights reserved
© Standards Australia Limited 2020

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth).

Preface

This Standard was prepared by the Standards Australia Committee ME-093, Hydrogen Technologies.

The objective of this document is to provide the requirements and test methods for the safety performance of high pressure gas valves that are used in gaseous hydrogen stations of up to the H70 designation.

This document covers the following gas valves:

- (a) Check valve.
- (b) Excess flow valve.
- (c) Flow control valve.
- (d) Hose breakaway device.
- (e) Manual valve.
- (f) Pressure safety valve.
- (g) Shut-off valve.

This document is an adoption with national modifications, and has been reproduced from ISO 19880-3:2018, *Gaseous hydrogen — Fuelling stations — Part 3: Valves*. The modifications are additional requirements and are set out in Appendix ZZ, which has been added at the end of the source text.

Appendix ZZ lists the variations to ISO 19880-3:2018 for the application of this document in Australia.

As this document has been reproduced from an International Standard, a full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

Contents

Preface ii

Foreword vi

Introduction.....vii

1 Scope 1

2 Normative references 1

3 Terms and definitions 1

4 General requirements..... 3

 4.1 General..... 3

 4.2 Intended use 3

 4.3 Material requirements..... 3

 4.4 Product quality 4

5 General test methods..... 4

 5.1 General..... 4

 5.2 Test conditions..... 4

 5.2.1 Test sample 4

 5.2.2 Pressure..... 5

 5.2.3 Normal test temperature 5

 5.2.4 Specified test temperature..... 5

 5.2.5 Test media..... 5

 5.2.6 Test sequence..... 5

 5.3 Hydrogen gas pressure cycle test..... 5

 5.3.1 General..... 5

 5.3.2 Test method..... 5

 5.4 Leakage 6

 5.4.1 General..... 6

 5.4.2 External leakage test..... 6

 5.4.3 Internal leakage test..... 6

 5.5 Worst case fault pressure cycle test 6

 5.6 Proof pressure test..... 6

 5.7 Hydrostatic strength test..... 7

 5.7.1 Test pressure 7

 5.7.2 Test method..... 7

 5.8 Excess torque resistance test 7

 5.9 Bending moment test..... 7

 5.10 Non-metallic materials test 9

 5.10.1 General 9

 5.10.2 Test method..... 9

 5.11 Cold gas in warm valve test 9

6 Check valves 10

 6.1 Applicability..... 10

 6.2 Hydrogen gas pressure cycle test..... 10

 6.3 External leakage test 10

 6.4 Internal leakage test..... 10

 6.5 Worst case fault pressure cycle test 11

 6.6 Proof pressure test..... 11

 6.7 Hydrostatic strength test..... 11

 6.8 Excess torque resistance test..... 11

 6.9 Bending moment test..... 11

 6.10 Non-metallic material test..... 11

7 Excess flow valves 11

 7.1 General..... 11

7.2	Tests	11
7.2.1	Classification	11
7.2.2	Applicability	11
7.2.3	Hydrogen gas pressure cycle test	12
7.2.4	External leakage test	12
7.2.5	Internal leakage test	12
7.2.6	Worst case fault pressure test	12
7.2.7	Proof pressure test	12
7.2.8	Hydrostatic strength test	12
7.2.9	Excess torque resistance test	12
7.2.10	Bending moment test	12
7.2.11	Non-metallic material test	13
7.2.12	Operation cycle test	13
7.2.13	Operation test	13
7.2.14	Pressure impulse test	13
8	Flow control valves	13
8.1	General	13
8.2	Tests	13
8.2.1	Applicability	13
8.2.2	Hydrogen gas pressure cycle test	14
8.2.3	External leakage test	14
8.2.4	Worst case fault pressure test	14
8.2.5	Proof pressure test	14
8.2.6	Hydrostatic strength test	14
8.2.7	Excess torque resistance test	14
8.2.8	Bending moment test	14
8.2.9	Non-metallic material test	14
8.2.10	Operation test under full pressure load	14
9	Hose breakaway devices	15
9.1	Specific design requirements	15
9.1.1	General	15
9.1.2	Electrical conductivity	15
9.1.3	Containment of/controlled relieving of hydrogen when uncoupled	15
9.1.4	Separation	15
9.2	Tests	15
9.2.1	Applicability	15
9.2.2	Hydrogen gas pressure cycle test	16
9.2.3	External leakage test	16
9.2.4	Worst case fault pressure test	16
9.2.5	Proof pressure test	17
9.2.6	Hydrostatic strength test	17
9.2.7	Excess torque resistance test	17
9.2.8	Bending moment test	17
9.2.9	Non-metallic material test	17
9.2.10	Separation test	17
9.2.11	Impact test (Applicable to rigid-mount devices)	19
9.2.12	Drop test	19
9.2.13	Twisting test	20
9.2.14	Cold gas in warm valve test	20
10	Manual valves	21
10.1	Construction and assembly	21
10.2	Tests	21
10.2.1	Applicability	21
10.2.2	Hydrogen gas pressure cycle test	21
10.2.3	External leakage test	21
10.2.4	Internal leakage test	21
10.2.5	Worst case fault pressure test	21

10.2.6	Proof pressure test.....	21
10.2.7	Hydrostatic strength test.....	22
10.2.8	Excess torque resistance test.....	22
10.2.9	Bending moment test.....	22
10.2.10	Non-metallic material test.....	22
10.2.11	Maximum flow shut-off test.....	22
10.2.12	Operation test.....	22
10.2.13	Excess torque operation test.....	22
11	Pressure safety valves (PSV).....	23
11.1	Applicability.....	23
11.2	Hydrogen gas pressure cycle test.....	23
11.3	PSV leakage tests.....	23
11.3.1	External leakage test.....	23
11.3.2	Seat leakage test.....	23
11.4	Worst case fault pressure test.....	24
11.5	Proof pressure test.....	24
11.6	Hydrostatic strength test.....	24
11.7	Excess torque resistance test.....	24
11.8	Bending moment test.....	24
11.9	Non-metallic material test.....	24
11.10	Operation test.....	24
12	Shut-off valves.....	25
12.1	Classification.....	25
12.2	Construction and assembly.....	25
12.3	Tests.....	25
12.3.1	Applicability.....	25
12.3.2	Hydrogen gas pressure cycle test.....	26
12.3.3	External leakage test.....	26
12.3.4	Internal leakage test.....	26
12.3.5	Worst case fault pressure test.....	26
12.3.6	Proof pressure test.....	27
12.3.7	Hydrostatic strength test.....	27
12.3.8	Excess torque resistance test.....	27
12.3.9	Bending moment test.....	27
12.3.10	Non-metallic material test.....	27
12.3.11	Operation test under full pressure load.....	27
12.3.12	Maximum flow shut-off test.....	27
12.3.13	Cold gas in warm valve test.....	28
13	Marking.....	28
13.1	Marking information.....	28
13.2	Marking method.....	28
14	Component literature.....	28
	Bibliography.....	30
Appendix ZZ	(normative) Variations to ISO 19880-3:2018 for Australia.....	31

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by ISO/TC 197, *Hydrogen technologies*.

A list of all parts in the ISO 19880 series can be found on the ISO website.

Introduction

Over the course of several years, international efforts have been initiated for the development of regulations, codes and standards that are required for the introduction of hydrogen energy systems. Hydrogen has unique properties and therefore presents unique safety concerns.

One of the many hydrogen energy applications is the automobile sector for which commercialization begun recently. For the success of this application, however, hydrogen infrastructure for fuelling vehicles is as essential as the hydrogen vehicles themselves. Thus, the development of safety standards for fuelling stations and components is of paramount importance.

This document provides safety performance requirements and test methods for valves to be used in gaseous hydrogen environment. Valves are critical to the safety of hydrogen fuelling stations, because they control the flow of gaseous hydrogen, shut it down in an emergency and, at the same time, may become a potential source of hydrogen release or leakage.

This document will facilitate the development of hydrogen infrastructure that is needed to pave a way for the widespread deployment of hydrogen-fuelled vehicles. Benefits to be gained by the implementation of this document include: the establishment of a certain level of safety performance for valves, a safety-critical component; the streamlining of the design and construction processes for fuelling stations by providing standardized components; and the promotion of public acceptance of hydrogen stations through the transparency of the international standardization processes.

This document is based on the Canadian Standards Association references CSA HGV3.1-2013, ANSI/CSA HGV 4.4-2013, ANSI/CSA HGV 4.6-2013 and ANSI/CSA HGV 4.7-2013.

This document is not intended to exclude any specific technologies that meet the performance requirements herein.

This document is to be applied in conjunction with other International Standards relevant to hydrogen fuelling stations and components.

NOTES

Australian Standard®

Gaseous hydrogen — Fuelling stations

Part 3: Valves (ISO 19880-3:2018, MOD)

1 Scope

This document provides the requirements and test methods for the safety performance of high pressure gas valves that are used in gaseous hydrogen stations of up to the H70 designation.

This document covers the following gas valves:

- check valve;
- excess flow valve;
- flow control valve;
- hose breakaway device;
- manual valve;
- pressure safety valve;
- shut-off valve.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0, *Explosive atmospheres — Part 0: Equipment — General requirements*

3 Terms and definitions

For the purpose of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1

allowable temperature range

minimum and maximum temperatures for which the manufacturer has designed the equipment (or any part to which the term is referred) when handling the specified fluid at the specified pressure

3.2

component pressure rating

maximum allowable pressure at which it is permissible to operate a component as specified by the manufacturer at a specified temperature

Note 1 to entry: Further guidance on dispenser pressure terminology is found in ISO 19880-1.

3.3

Cv value

<flow coefficient> coefficient to represent the flow rate of fluid that a valve is capable of handling

Note 1 to entry: Cv is the flow coefficient of a valve with the fluid at 15,56 °C under a pressure difference of 6 894 N/m².

Note 2 to entry: There are different types of flow coefficients including Cv, Kv and Av.

3.4

dispenser

system downstream of the hydrogen supply system comprising all equipment necessary to carry out the vehicle fuelling operation, through which the compressed hydrogen is supplied to the vehicle

Note 1 to entry: As an example, the dispenser can include a dispenser cabinet, gas flow meter, a fuelling hose and fuelling nozzle attachments.

3.5

hydrogen service level

HSL

pressure level in MPa used to characterize the hydrogen service of the dispenser based on the NWP rating of the vehicle

Note 1 to entry: The numerical value of HSL also matches the number after the “H” in Pressure Class.

Note 1 to entry: Hydrogen service level is expressed in MPa.

3.6

maximum allowable working pressure

MAWP

maximum pressure permissible in a system at the temperature specified for the pressure

Note 1 to entry: The maximum allowable working pressure may also be defined as the design pressure, the maximum allowable operating pressure, the maximum permissible working pressure, or the maximum allowable pressure for the rating of pressure vessels and equipment manufactured in accordance with national pressure vessel codes.

3.7

maximum operating pressure

MOP

highest pressure that is expected for a component or system during normal operation

3.8

valve

device by which the flow of a fluid may be started, stopped or regulated, using a movable part which opens or obstructs passage

3.8.1

check valve

valve which allows gas to flow in only one direction

3.8.2

excess flow valve

valve which automatically shuts off or limits the gas flow when the flow exceeds a set design value

3.8.3

flow control valve

gas flow restricting device, installed downstream of a pressure regulator, which controls gas flow

3.8.4

breakaway device

device on the fuelling hose that disconnects the hose from the dispenser when a tension limit is exceeded and blocks the flow of hydrogen from the dispenser, e.g. if the vehicle moves away with the fuelling hose connected to the vehicle

Note 1 to entry: This device is treated as a type of valve according to [3.8](#).

3.8.5

manual valve

hand-operated device for controlling the flow of gas

3.8.6

pressure safety valve

PSV

pressure activated valve that opens at a specified set point to protect the system from burst and recloses when the pressure falls below the set point

3.8.7

shut-off valve

on/off valve for controlling the flow of gas, which is pneumatically or electrically actuated

4 General requirements

4.1 General

This document defines proof of design (type) tests for valves, designed and manufactured under existing standards that are intended for use in hydrogen fuelling stations.

The requirements contained within this document are intended to provide performance-based tests to verify capability of valves for high pressure hydrogen service but not to prevent alternative methods to demonstrate acceptable capability. Valves that have extensive, successful service at comparable design conditions with similarly proportioned components made of the same or like material are not required to perform verification tests defined in [Clauses 5](#) through [12](#) of this document if allowed by applicable codes and regulations.

Components shall comply with all construction specifications set forth herein, or their construction shall demonstrate at least equivalent performance.

4.2 Intended use

The quality of hydrogen fuel dispensed to vehicles is defined in ISO 14687. The design, manufacture and operation of valves constructed in accordance with this document shall not introduce contamination to the hydrogen passing through or in contact with them.

4.3 Material requirements

Resistance to chloride stress corrosion cracking shall be taken under consideration if selecting stainless steel materials. Resistance to sustained load cracking shall be taken under consideration if selecting aluminum materials.

Materials normally in contact with hydrogen shall be determined to be acceptable in hydrogen service, with particular attention to hydrogen embrittlement and hydrogen accelerated fatigue. Materials and design shall be such that there will be no significant change in the functioning of the device, deformation or mechanical change in the device, and no harmful corrosion, deformation or deterioration of the materials.