

STANDARDS AUSTRALIA

Amendment No. 1
to
AS 2118.1:2017
Automatic fire sprinkler systems
Part 1: General systems

CORRECTION

The 2017 edition of AS 2118.1 is amended as follows; the amendment(s) should be inserted in the appropriate place(s).

SUMMARY: This Amendment applies to Tables 13.5.5.1, 13.5.5.4(A) and 13.5.5.4(B).

Published on 21 December 2017.

AMDT
No. 1
DEC
2017

Table 13.5.5.1

Delete last two columns and *replace* with the following:

Container type	Relieving-style	Storage configuration	Volume	Table	Clause
Metal	—	Palletized or solid pile	>230 L	13.5.5.2(A)	13.5.5.2
Metal	Yes	Rack storage	>230 L	13.5.5.2(B)	13.5.5.2
Metal	—	Rack storage	>25 L up to 230	13.5.5.3(A)	13.5.5.3
Metal	—	Palletized or solid pile	>25 L up to 230	13.5.5.3(B)	13.5.5.3
Metal	—	Rack storage	<25 L	13.5.5.4(A)	13.5.5.4
Metal	Yes	Any	<25 L	13.5.5.4(B)	13.5.5.4
Metal	No	Palletized or solid pile	<25 L	13.5.5.4(C)	13.5.5.4
Metal	No	Shelf storage	<25 L	13.5.5.4(D)	13.5.5.4
Plastic or glass	—	Palletized or solid pile	Various	13.5.5.5.1(A)	13.5.5.5
Composite IBCs	—	Rack storage	<1150 L	13.5.5.6	13.5.5.6
Plastic or glass	—	Rack storage—FP <93C	Various	13.5.5.7(A)	13.5.5.7
Plastic or glass	—	Rack storage—FP >93C	Various	13.5.5.7(B)	13.5.5.7
Plastic or glass	—	Rack storage—Water miscible	Various	13.5.5.7(C)	13.5.5.7
Plastic	—	Palletized or solid pile—FP >93C	Various	13.5.5.7(D)	13.5.5.7
Plastic or glass	—	Palletized or solid pile—Water miscible	Various	13.5.5.7(E)	13.5.5.7

AMDT
No. 1
DEC
2017

Table 13.5.5.4(A)

Delete title and *replace* with the following:

TABLE 13.5.5.4(A)

**RACK STORAGE OF IGNITABLE LIQUIDS IN METAL CONTAINERS
UP TO AND INCLUDING 25 L WITH AISLES A MINIMUM OF 2.4 m WIDE**

AMDT
No. 1
DEC
2017

Table 13.5.5.4(B)

Delete title and *replace* with the following:

TABLE 13.5.5.4(B)

**IGNITABLE LIQUIDS IN RELIEVING STYLE METAL CONTAINERS
UP TO AND INCLUDING 25 L, EXCLUDING IGNITABLE LIQUIDS
WITH BOILING POINT BELOW 38°C**
