

STANDARDS AUSTRALIA

RECONFIRMATION

OF

AS 2428.6—2004

Methods of testing smoke/heat release vents

Method 6: Determination of ability to operate under snow loading

RECONFIRMATION NOTICE

Technical Committee ME-062 has reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 13 October 2015.

The following are represented on Technical Committee ME-062:

Air Conditioning & Mechanical Contractors Association
Australasian Fire and Emergency Service Authorities Council
Australian Building Codes Board
Australian Industry Group
Australian Institute of Refrigeration Air Conditioning and Heating
Chartered Institution of Building Services Engineers
Climate Control Companies Association
Consumer Electronics Suppliers Association
Department of Health and Human Services (TAS)
Engineers Australia
Facility Management Association of Australia
Institute of Refrigeration Heating & AirConditioning Engineers of New Zealand
NATSPEC
The Insulation Contractors Association of Australia NSW
Victorian Building Authority

NOTES