

STANDARDS AUSTRALIA

Amendment No. 1
to
AS 2441—2005
Installation of hose reels

REVISED TEXT

The 2005 edition of AS 2441 is amended as follows; the amendments should be inserted in the appropriate places.

SUMMARY: This Amendment applies to Clauses 3, 6.1 and 6.5.

Published on 22 May 2009.

AMDT
No. 1
MAY
2009

Clause 3

After '1221' listing, *add* the following referenced Standard:

3500	Plumbing and drainage
3500.1	Part 1: Water services

AMDT
No. 1
MAY
2009

Clause 6.1

Delete existing text and *replace* with the following:

The supply of water to the fire hose reel assembly shall be sufficient to enable the hose reel to deliver the minimum demand specified in Table 6.1, for the two most hydraulically disadvantaged fire hose reels operating simultaneously (except where only one fire hose reel is installed), plus any probable simultaneous flow. The nominal diameter of the supply pipe shall be not less than that specified in Table 6.1.

AMDT
No. 1
MAY
2009

Clause 6.5

Delete existing text and *replace* with the following:

Pipes and fittings used in hose reels systems shall comply with one of the following:

- (a) AS 2419.1 where connected to fire hydrant systems.
- (b) AS/NZS 3500.1 where connected to another water supply.
- (c) AS 2118.1 where connected to automatic fire sprinkler system.

This page has been left intentionally blank.