

STANDARDS AUSTRALIA

Amendment No. 1
to
AS 3124—2002
Approval and test specification—For overhead line connector boxes

REVISED TEXT

The 2002 edition of AS 3124 is amended as follows; the amendment should be inserted in the appropriate place.

SUMMARY: This Amendment applies to Clause 8.8.

Published on 22 February 2005.

AMDT
No. 1
FEB
2005

Page 12 Clause 8.8

Delete this clause and *replace* with the following:

8.8 Determination of ignitability and combustion propagation

The connector box shall comply with the requirements for resistance to fire in accordance with AS/NZS 3100 Annex A. The glow-wire test temperature 'T' shall be 750°C.

Any non-metallic enclosures shall be subjected to the glow-wire test with a test temperature of 750°C.

This Amendment forms part of the Standard on publication but shall be applied from 9 July 2006.

This page has been left intentionally blank.