

STANDARDS AUSTRALIA

Amendment No. 2
to
AS 3745:2010
Planning for emergencies in facilities

REVISED TEXT

The 2010 edition of AS 3745 is amended as follows; the amendments should be inserted in the appropriate places.

SUMMARY: This Amendment applies to Clauses 1.4.14A, 1.4.20A, 1.4.20B, 3.5.1, 3.5.2, 3.5.3, 3.5.5, 3.5.6, 4.2.5, 4.2.6.3, 5.7.2, 6.3.3, Appendix B, and Figure 3.1.

Published on 29 June 2018.

AMDT
No. 2
JUN
2018

Clause 1.4.14A (new)

Add the following new term and definition (after Clause 1.4.14):

1.4.14A Emergency Service(s)

The State or Territory authority responsible for emergency response or recovery.

AMDT
No. 2
JUN
2018

Clause 1.4.20A (new)

Add the following new term and definition (after Clause 1.4.20):

1.4.20A First-attack firefighting equipment

Portable fire extinguishers, fire hose reels and fire blankets, which are used to fight fires in their early stages.

AMDT
No. 2
JUN
2018

Clause 1.4.20B (new)

Add the following new term and definition (after Clause 1.4.20A):

1.4.20B First-response emergency equipment

Resources, such as automatic external defibrillators (AEDs), spill kits and first aid kits, which are used to address various emergency scenarios in their early stages.

AMDT
No. 2
JUN
2018

Figure 3.1 (as amended by Amd 1:2014)

Delete the figure and *replace* with the following:



AMDT
No. 2
JUN
2018

Clause 3.5.1

- 1 Add new second paragraph as follows:

Where emergency and evacuation information is included on the evacuation diagram, this information shall reflect the facility emergency and evacuation information as documented in the emergency plan.

- 2 Add new Note (after Note 3), as follows:

- 4 For facilities with larger floor areas such as hospitals, tunnels, large office floors, warehouses, universities, shopping centres, etc., the pictorial representation should be prepared in sections or areas so that no more than two exits are shown on each pictorial representation.

AMDT
No. 2
JUN
2018

Clause 3.5.2

Add new Note at the end of the Clause, as follows:

NOTE: Evacuation diagrams should not be fitted to fire doors, smoke doors or other fire resistant elements of construction unless this has been tested or a formal opinion has been obtained from an appropriate authority (e.g. a testing laboratory or professional engineer).