

AS 4428.17:2024



STANDARDS
Australia



Fire detection, warning, control and intercom systems — Control and indicating equipment

Part 17: 003 key — Fire services key system



AS 4428.17:2024

This Australian Standard® was prepared by FP-002, Fire Detection, Warning, Control and Intercom Systems. It was approved on behalf of Standards Australia's Standards Development and Accreditation Committee on 19 July 2024.

This Standard was published on 13 September 2024.

The following are represented on Committee FP-002:

- Association of Accredited Certification Bodies
- Association of Australasian Acoustical Consultants
- Australasian Fire and Emergency Service Authorities Council
- Australian Building Codes Board
- Australian Chamber of Commerce and Industry
- Australian Industry Group
- Australian Institute of Building Surveyors
- CSIRO
- Deafness Forum of Australia
- Engineers Australia
- Engineers Australia/ Society of Fire Safety
- Fire Protection Association Australia
- Hydraulic Consultants Association Australasia
- National Electrical and Communications Association
- National Fire Industry Association
- Property Council of Australia

This Standard was issued in draft form for comment as DR AS 4428.17:2024.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

ISBN 978 1 76139 826 1

Fire detection, warning, control and intercom systems — Control and indicating equipment

Part 17: 003 key — Fire services key system

First published as AS 4428.17:2024.

© Standards Australia Limited 2024

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth).

Preface

This Standard was prepared by the Standards Australia Committee FP-002, Fire Detection, Warning, Control and Intercom Systems.

The objective of this document is to provide manufacturers with requirements for the design, manufacture and performance testing of a standardised fire service keying system. It is based on the previous “Lockwood 003” key and cylinder system.

Contents

Preface	ii
Introduction	iv
Section 1 Scope and general	1
1.1 Scope	1
1.2 Normative references	1
1.3 Terms and definitions	1
1.4 Classification	2
1.4.1 General	2
1.4.2 Padlocks and cylinders	2
Section 2 Design	3
2.1 General	3
2.2 Key and cylinder dimensions	3
2.2.1 Key blade nominal dimensions	3
2.2.2 Key code cuts	3
2.2.3 Key head width	4
2.2.4 Key thickness	4
2.2.5 Key profile	4
2.2.6 Cylinders	5
Section 3 Materials	6
3.1 Keys	6
3.2 Cylinders	6
3.3 Padlocks	6
3.4 Internal tumbler components	6
Section 4 Performance	7
4.1 General	7
4.2 Minimum product classification	7
4.2.1 General	7
4.2.2 Cylinders	7
4.2.3 Padlocks	7
4.3 Testing and conformance	8
4.3.1 General	8
4.3.2 Keys	8
4.3.3 Cylinders	8
4.3.4 Padlocks	8
4.3.5 Ease of operation	9
Section 5 Identification marking	10
5.1 Keys	10
5.2 Cylinders	10
5.3 Padlocks	10
Section 6 Documentation	11
6.1 General	11
6.2 Packaging and promotional material	11
Bibliography	12

Introduction

To align with current fire and locksmithing industry terminology, this key system will be known as the “003 key — fire services key system”, incorporating the original nomenclature of the Lockwood 003 keying system.

This document does not introduce any new requirements for existing 003 keys and cylinders.

A 003 keying system is installed into all locking mechanisms such as padlocks, camlocks, T-handles and cylinders that are typically used to secure fire services equipment and fire safety system components.

Any products that meet the requirements of this document will be fully compatible with existing Lockwood 003 keys and locks.