

## STANDARDS AUSTRALIA

---

**Amendment No. 1**  
to  
**AS 60044.1—2007**  
**Instrument transformers**  
**Part 1: Current transformers**

---

**CORRECTION**

The 2007 edition of AS 60044.1 is amended as follows; the amendment(s) should be inserted in the appropriate place(s).

*SUMMARY:* This Amendment applies to Clause 14.1 and Annex A.

Published on 31 January 2012.

**Clause 14.1, Item (c)**

*Strikethrough* Item (c) and *add* the following new Australian variation:

c) rated turns ratio. The turns ratio error shall not exceed  $\pm 0,25\%$  or  $\pm 50/N_s\%$ , whichever is the greater, where  $N_s$  is the number of secondary turns;

**Annex A, Paragraph A4**

In paragraph 2, *strikethrough* the reference to '2.1.31' and *add* the following:

**2.1.34.**

AMDT  
No. 1  
JAN  
2012

AMDT  
No. 1  
JAN  
2012

This page has been left intentionally blank.