

STANDARDS AUSTRALIA

Amendment No. 1
to
AS 7240.5—2004
Fire detection and alarm systems
Part 5: Point-type heat detectors
(ISO 7240-5:2003, MOD)

CORRECTION

The 2004 edition of AS 7240.5 is amended as follows; the amendment(s) should be inserted in the appropriate place(s).

SUMMARY: This Amendment applies to Clauses 2 and 5.

The text of this Amendment is reproduced from and is identical with ISO 7240-5:2003 Technical Corrigendum 1.

Published on 27 February 2007.

Fire detection and alarm systems —

Part 5: Point-type heat detectors

TECHNICAL CORRIGENDUM 1

Systèmes de détection et d'alarme d'incendie —

Partie 5: Détecteurs de chaleur ponctuels

RECTIFICATIF TECHNIQUE 1

Technical Corrigendum 1 to ISO 7240-5:2003 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 3, *Fire detection and alarm systems*.

Page 1, Clause 2:

Delete “IEC 60068-2-78, *Environmental testing — Part 2-78: Tests — Test Cab: Damp heat, steady state*” and after IEC 60068-2-27 add “IEC 60068-2-30, *Environmental testing — Part 2-30: Tests — Test Db: Damp heat, cyclic (12 h + 12 h cycle)*”.

Page 15, 5.11.2.1:

Replace “IEC 60068-2-78, *Test Cab*” with “IEC 60068-2-30, using Variant 1 test cycle”.

Page 15, 5.11.2.3:

Replace “IEC 60068-2-78, *Test Cab*” with “IEC 60068-2-30, Severity 1”.

Page 15, 5.11.2.3:

Replace “ $\leq 95\%$ ” with “ $\geq 95\%$ ”.