



Fire detection and alarm systems

Part 10: Point-type flame detectors



AS ISO 7240.10:2018

This Australian Standard® was prepared by FP-002, Fire Detection, Warning, Control and Intercom Systems. It was approved on behalf of the Council of Standards Australia on 30 November 2018.

This Standard was published on 20 December 2018.

The following are represented on Committee FP-002:

- Association of Hydraulic Services Consultants Australia
- Australasian Fire and Emergency Service Authorities Council
- Australian Chamber of Commerce and Industry
- Australian Industry Group
- Australian Institute of Building Surveyors
- CSIRO
- Deafness Forum of Australia
- Department of Health and Human Services (VIC)
- Engineers Australia
- Fire Protection Association Australia
- National Electrical and Communications Association
- National Fire Industry Association
- Property Council of Australia
- Society of Fire Safety

This Standard was issued in draft form for comment as DR AS ISO 7240.10:2018.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.saiglobal.com (sales and distribution)

ISBN 978 1 76072 309 5



Fire detection and alarm systems

Part 10: Point-type flame detectors

First published as AS 7240.10—2007.
This edition AS ISO 7240.10:2018.

COPYRIGHT

© ISO 2018 — All rights reserved
© Standards Australia Limited 2018

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth).

Published by SAI Global Pty Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001, Australia.

Preface

This Standard was prepared by the Standards Australia Committee FP-002, Fire Detection, Warning, Control and Intercom Systems, to supersede AS 7240.10—2007, *Fire detection and alarm systems, Part 10: Point-type flame detectors*.

The objective of this Standard is to specify requirements, test methods and performance criteria for point-type, resettable flame detectors that operate using radiation from a flame for use in fire detection systems installed in buildings.

This Standard is not applicable to flame detectors with special characteristics, developed for specific risks. It can be used as guidance in assessing other types of flame detectors not included in this Standard.

The performance of flame detectors is assessed from results obtained in specific tests. This Standard is not intended to place any other restrictions on the design and construction of such flame detectors.

This Standard is identical with, and has been reproduced from, ISO 7240-10:2012, *Fire detection and alarm systems — Part 10: Point-type flame detectors*.

As this document has been reproduced from an International Standard, the following applies:

- (a) In the source text “this part of ISO 7240” should read “this Australian Standard”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

Contents

Preface	ii
Foreword	vi
Introduction	viii
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Abbreviated terms	2
5 General requirements	3
5.1 Compliance	3
5.2 Classification	3
5.3 Individual alarm indication	3
5.4 Connection of ancillary devices	3
5.5 Monitoring of detachable detectors	3
5.6 Manufacturer adjustments	3
5.7 On-site sensitivity adjustment	4
5.8 Ingress protection (IP) — Optional function	4
5.9 Marking	4
5.10 Data	5
5.11 Requirements for software-controlled detectors	5
5.11.1 General	5
5.11.2 Software documentation	5
5.11.3 Software design	6
5.11.4 Storage of programs and data	6
6 Tests	6
6.1 General	6
6.1.1 Atmospheric conditions for tests	6
6.1.2 Operating conditions for tests	6
6.1.3 Mounting arrangements	7
6.1.4 Tolerances	7
6.1.5 Determination of response point	7
6.1.6 Test procedure	8
6.1.7 Reduced functional tests	8
6.1.8 Provision for tests	8
6.1.9 Test schedule	9
6.1.10 Test report	9
6.2 Reproducibility	9
6.2.1 Object of test	9
6.2.2 Test procedure	10
6.2.3 Requirements	10
6.3 Repeatability	10
6.3.1 Object of test	10
6.3.2 Test procedure	10
6.3.3 Requirements	10
6.4 Directional dependence	10
6.4.1 Object of test	10
6.4.2 Test procedure	10
6.4.3 Requirements	11
6.5 Fire sensitivity	12
6.5.1 Object of test	12
6.5.2 Test procedure	12
6.5.3 Classification	13
6.5.4 Requirements	13

6.6	Dazzling (operational)	15
6.6.1	Object of test	15
6.6.2	Test procedure and apparatus	15
6.6.3	Requirements	15
6.7	Dry heat (operational)	16
6.7.1	Object of test	16
6.7.2	Test procedure and apparatus	16
6.7.3	Requirements	16
6.8	Cold (operational)	17
6.8.1	Object of test	17
6.8.2	Test procedure	17
6.8.3	Requirements	17
6.9	Damp heat, cyclic (operational)	18
6.9.1	Object of test	18
6.9.2	Test procedure	18
6.9.3	Requirements	18
6.10	Damp heat, steady state (endurance)	19
6.10.1	Object of test	19
6.10.2	Test procedure	19
6.10.3	Requirements	19
6.11	Sulfur dioxide (SO ₂) corrosion (endurance)	19
6.11.1	Object of test	19
6.11.2	Test procedure	20
6.11.3	Requirements	20
6.12	Shock (operational)	20
6.12.1	Object of test	20
6.12.2	Test procedure and apparatus	20
6.12.3	Requirements	21
6.13	Impact (operational)	21
6.13.1	Object of test	21
6.13.2	Test procedure	21
6.13.3	Requirements	22
6.14	Vibration, sinusoidal (operational)	22
6.14.1	Object of test	22
6.14.2	Test procedure	22
6.14.3	Requirements	23
6.15	Vibration, sinusoidal (endurance)	23
6.15.1	Object of test	23
6.15.2	Test procedure	23
6.15.3	Requirements	24
6.16	Variation of supply parameters (operational)	24
6.16.1	Object of test	24
6.16.2	Test procedure	24
6.16.3	Requirements	24
6.17	EMC immunity tests (operational)	25
6.18	IP — Optional function	25
6.18.1	Object of test	25
6.18.2	Enclosure of the flame detector	25
6.18.3	Test procedure	25
6.18.4	Requirements	26
7	Test report	27
Annex A	(normative) Apparatus for response point determination	28
Annex B	(normative) Liquid (heptane) fire (TF5)	31
Annex C	(normative) Liquid (methyated spirit) fire (TF6)	32
Annex D	(normative) Apparatus for dazzling test	33

Annex E	(normative) Apparatus for impact test	34
Annex F	(informative) Example of methane burner	36

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 7240-10 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 3, *Fire detection and alarm systems*.

This second edition cancels and replaces the first edition (ISO 7240-10:2007), which has been technically revised.

ISO 7240 consists of the following parts, under the general title *Fire detection and alarm systems*:

- *Part 1: General and definitions*
- *Part 2: Control and indicating equipment*
- *Part 3: Audible alarm devices*
- *Part 4: Power supply equipment*
- *Part 5: Point-type heat detectors*
- *Part 6: Carbon monoxide fire detectors using electro-chemical cells*
- *Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization*
- *Part 8: Carbon monoxide fire detectors using an electro-chemical cell in combination with a heat sensor*
- *Part 9: Test fires for fire detectors* [Technical Specification]
- *Part 10: Point-type flame detectors*
- *Part 11: Manual call points*
- *Part 12: Line type smoke detectors using a transmitted optical beam*
- *Part 13: Compatibility assessment of system components*
- *Part 14: Guidelines for drafting codes of practice for design, installation and use of fire detection and fire alarm systems in and around buildings* [Technical Report]
- *Part 15: Point type fire detectors using scattered light, transmitted light or ionization sensors in combination with a heat sensor*
- *Part 16: Sound system control and indicating equipment*
- *Part 17: Short-circuit isolators*

- *Part 18: Input/output devices*
- *Part 19: Design, installation, commissioning and service of sound systems for emergency purposes*
- *Part 20: Aspirating smoke detectors*
- *Part 21: Routing equipment*
- *Part 22: Smoke-detection equipment for ducts*
- *Part 23: Visual alarm devices*
- *Part 24: Sound-system loudspeakers*
- *Part 25: Components using radio transmission paths*
- *Part 27: Point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor*
- *Part 28: Fire protection control equipment*

Introduction

A fire detection and fire alarm system is required to function satisfactorily, not only in the event of a fire, but also during and after exposure to conditions likely to be met in practice, such as corrosion, vibration, direct impact, indirect shock and electromagnetic interference. Some tests specified in this part of ISO 7240 are intended to assess the performance of the fire detectors under such conditions.

Australian Standard®

Fire detection and alarm systems

Part 10: Point-type flame detectors

1 Scope

This part of ISO 7240 specifies requirements, test methods and performance criteria for point-type, resettable flame detectors that operate using radiation from a flame for use in fire detection systems installed in buildings.

This part of ISO 7240 is not applicable to flame detectors with special characteristics, developed for specific risks. It can be used as guidance in assessing other types of flame detectors not included in this part of ISO 7240.

The performance of flame detectors is assessed from results obtained in specific tests. This part of ISO 7240 is not intended to place any other restrictions on the design and construction of such flame detectors.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 209, *Aluminium and aluminium alloys — Chemical composition*

ISO 7240-1, *Fire detection and alarm systems — Part 1: General and definitions*

IEC 60064, *Tungsten filament lamps for domestic and similar general lighting purposes — Performance requirements*

IEC 60068-1, *Environmental testing — Part 1: General and guidance*

IEC 60068-2-1, *Environmental testing — Part 2-1: Tests — Test A: Cold*

IEC 60068-2-2, *Environmental testing — Part 2-2: Tests — Test B: Dry heat*

IEC 60068-2-6, *Environmental testing — Part 2-6: Tests — Test Fc: Vibration (sinusoidal)*

IEC 60068-2-27, *Environmental testing — Part 2-27: Tests — Test Ea and guidance: Shock*

IEC 60068-2-30, *Environmental testing — Part 2-30: Tests — Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-42, *Environmental testing — Part 2-42: Tests — Test Kc: Sulphur dioxide test for contacts and connections*

IEC 60068-2-78, *Environmental testing — Part 2-78: Tests — Test Cab: Damp heat, steady state*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

EN 50130-4, *Alarm systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 7240-1 and the following apply.

3.1 detector classification

classification of flame detectors to indicate their relative sensitivity to fire

Note 1 to entry: Class 1 indicates the highest sensitivity acceptable and class 3 the lowest sensitivity acceptable within this part of ISO 7240, except for class 4 where the sensitivity is decided by the manufacturer.

3.2 infrared (IR) detector

flame detector responding only to radiation having wavelengths greater than 850 nm

3.3 multiband detector

flame detector that responds to radiation in more than one distinct wavelength range where each range may contribute to the alarm decision

Note 1 to entry: The alarm decision may be based on any arithmetic or logical combination of the individual signals.

3.4 response point

D

distance at which the individual flame detector under test gives an alarm signal

Note 1 to entry: The distance, *D*, is measured in accordance with [6.1.5](#).

3.5 sensitivity

measure of the ability of a flame detector to detect fires

Note 1 to entry: Sensitivity is not necessarily directly related to the response point.

3.6 sensitivity adjustment

any adjustment of the detector or of the alarm criteria within the supply and monitoring equipment that leads to a change in sensitivity

Note 1 to entry: See [6.1.2](#).

3.7 type A

device with no specific ingress protection (IP) rating

3.8 type B

device with ingress protection (IP) rating of IP54C

3.9 ultra-violet (UV) detector

flame detector responding only to radiation having wavelengths less than 300 nm

4 Abbreviated terms

— EMC	electromagnetic compatibility
— IP	ingress protection
— IR	infrared
— UV	ultra-violet

5 General requirements

5.1 Compliance

In order to comply with this part of ISO 7240, the detector shall meet the requirements of [Clause 5](#), which shall be verified visually or by engineering assessment. The detector shall be tested and shall meet the requirements of the tests as specified in [Clause 6](#).

5.2 Classification

Detectors shall conform to one or more of the following classifications to which the manufacturer claims compliance (see [Table 1](#)) and according to the requirements of the tests specified in [6.5](#).

Table 1 — Flame detector classifications

Class	Classification distance m
1	25
2	17
3	12
4	decided by the manufacturer

NOTE Detectors may be classified into more than one class, depending on the results of the assessment.

5.3 Individual alarm indication

5.3.1 Each detector shall be provided with an integral red visual indicator, by which the individual detector that released an alarm can be identified, until the alarm condition is reset. Where other conditions of the detector are visually indicated, they shall be clearly distinguishable from the alarm indication, except when the detector is switched into a service mode. For a detachable detector, the indicator may be integral with the base or the detector head.

5.3.2 The visual indicator shall be visible from a distance of 6 m in an ambient light intensity up to 500 lx at an angle of up to:

- 5° from the axis of the detector in any direction, and
- 45° from the axis of the detector in at least one direction.

5.4 Connection of ancillary devices

The detector may provide for connections to ancillary devices (remote indicators, control relays, etc.), but open- or short-circuit failures of these connections shall not prevent the correct operation of the detector.

5.5 Monitoring of detachable detectors

For detachable detectors, a means shall be provided for a remote monitoring system (e.g. the control and indicating equipment) to detect the removal of the head from the base, in order to give a fault signal.

5.6 Manufacturer adjustments

It shall not be possible to change the manufacturer's settings except by special means (e.g. the use of a special code or tool) or by breaking or removing a seal.

5.7 On-site sensitivity adjustment

If there is provision for on-site sensitivity adjustment of the detector, then:

- a) for all settings at which the manufacturer claims compliance, the detector shall comply with the requirements of this part of ISO 7240 and shall achieve a classification corresponding to that marked on the detector for that setting;
- b) for each setting in a), access to the adjustment means shall be possible only by the use of a code or special tool or by removing the detector from its base or mounting;
- c) any setting or settings at which the manufacturer does not claim compliance with this part of ISO 7240 shall only be accessible by the use of a code or special tool, and it shall be clearly marked on the detector or in the associated data that if these setting or settings are used, the detector does not comply with this part of ISO 7240.

NOTE These adjustments can be carried out on the detector or on the control and indicating equipment.

5.8 Ingress protection (IP) — Optional function

The IP category (i.e. IP rating) of the detector shall be specified by the manufacturer. No requirement shall apply to type A flame detectors. Type B flame detectors shall comply with rating IP54C of IEC 60529 (see [6.18](#)).

5.9 Marking

5.9.1 Each detector shall be clearly marked with, or supplied with, the following information:

- a) reference to this part of ISO 7240, i.e. ISO 7240-10:2012;
- b) name or trademark of the manufacturer or supplier;
- c) model designation (type or number);
- d) classification of the detector, e.g. class 1 (where the detector is classified as class 4, indicate class 4 and the distance as determined by [6.5.2.3](#));
- e) IP rating (if applicable).
- f) mark(s) or code(s), e.g. a serial number or batch code, by which the manufacturer can identify, at least, the date or batch and place of manufacture and the version number(s) of any software contained within the detector;
- g) wiring terminal designations;
- h) angle of reception as determined in [6.4](#);
- i) operating wavelength band(s), e.g. UV, IR.

5.9.2 For detachable detectors, the detector head shall be marked with at least a), b), c), d), e), f), h) and i) from [5.9.1](#), and the base shall be marked with at least c), i.e. its own model designation, and g).

5.9.3 Where any marking on the device uses symbols or abbreviations not in common use, these shall be explained in the data supplied with the device.

5.9.4 The marking shall be visible during installation of the detector and shall be accessible during maintenance.

5.9.5 The markings shall not be placed on screws or other easily removable parts.

5.10 Data

5.10.1 Detectors shall either be supplied with sufficient technical, installation and maintenance data to enable their correct installation and operation or, if all of these data are not supplied with each detector, reference to the appropriate data sheet shall be given on, or with, each detector.

5.10.2 To enable correct operation of the detectors, these data should describe the requirements for the correct processing of the signals from the detector. This may be in the form of a full technical specification of these signals, a reference to the appropriate signalling protocol or a reference to suitable types of control and indicating equipment, etc.

5.10.3 Installation and maintenance data shall include reference to an *in situ* test method to ensure that detectors operate correctly when installed.

NOTE Additional information can be required by organizations certifying that detectors produced by a manufacturer conform to the requirements of this part of ISO 7240.

5.11 Requirements for software-controlled detectors

5.11.1 General

For detectors that rely on software control, the requirements of [5.11.2](#), [5.11.3](#) and [5.11.4](#) shall be met in order to fulfil the requirements of this part of ISO 7240.

5.11.2 Software documentation

5.11.2.1 The manufacturer shall submit documentation that gives an overview of the software design. This documentation shall be in sufficient detail for the design to be inspected for compliance with this part of ISO 7240 and shall include at least the following:

- a) functional description of the main program flow (e.g. as a flow diagram or structogram), including a brief description of
 - 1) the modules and the functions that they perform,
 - 2) the way in which the modules interact,
 - 3) the overall hierarchy of the program,
 - 4) the way in which the software interacts with the hardware of the detector,
 - 5) the way in which the modules are called, including any interrupt processing;
- b) description of those areas of memory used for each purpose (e.g. the program, site-specific data and running data);
- c) designation by which the software and its version can be uniquely identified.

5.11.2.2 The manufacturer shall prepare and maintain detailed design documentation. This shall be available for inspection in a manner that respects the manufacturer's rights for confidentiality. It shall comprise at least the following:

- a) overview of the whole system configuration, including all software and hardware components;
- b) description of each module of the program, containing at least:
 - 1) the name of the module,
 - 2) a description of the tasks performed,