

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Amendment No. 1
to
AS/NZS 1660.2.5:1998
Test methods for electric cables, cords and conductors
Method 2.5: Insulation, extruded semi-conductive screens and non-metallic sheaths—
Methods specific to cables above 1 kV

REVISED TEXT

The 1998 edition of AS/NZS 1660.2.5 is amended as follows; the amendments should be inserted in the appropriate places.

SUMMARY: This Amendment applies to Clause 2.2 and Clause 2.3(a).

Published on 23 February 2001.

Approved for publication in New Zealand on behalf of the Standards Council of New Zealand on 2 February 2001.

Page 6 Clause 2.2

Insert a new (c) as follows:

For cables with sector shaped conductors, the cut shall be made on the curved surface (back radius) of the core.

Redesignate existing (c) and (d) as (d) and (e) respectively.

This Amendment forms part of the Standard on publication.

Page 6 Clause 2.3(a)

Add an additional sentence to the end of Clause 2.3(a) as follows:

For cables with sector shaped conductors the test piece shall be taken from the curved surface (back radius) and from one of the flat sides of the core.

This Amendment forms part of the Standard on publication.

AMDT
No. 1
FEB.
2001

AMDT
No. 1
FEB.
2001

This page has been left intentionally blank.