

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Amendment No. 1
to
AS/NZS 2566.2:2002
Buried flexible pipelines
Part 2: Installation

REVISED TEXT

The 2002 edition of AS/NZS 2566.2 is amended as follows; the amendments should be inserted in the appropriate places.

SUMMARY: This Amendment applies to Paragraph M7.5(c), Appendix M.

Published on 28 June 2013.

Approved for publication in New Zealand on behalf of the Standards Council of New Zealand on 20 May 2013.

Appendix M, Paragraph M7.5, Item (c)

- 1 *Delete* the equation and *replace* with the following:

$$\Delta V_{\max} = 1.2 \times V \times \Delta P \left(\frac{1}{E_w} + \frac{D}{e E_R} \right)$$

- 2 *Add* the following symbol and definition after 'D':

e = pipe wall thickness, in metres

AMDT
No. 1
JUN
2013

This page has been left intentionally blank.