

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

**Amendment No. 2
to
AS/NZS 3102:2002
Approval and test specification -
Electric duct heaters**

REVISED TEXT

The 2002 edition of AS/NZS 3102 is amended as follows; the amendments should be inserted in the appropriate places.

SUMMARY: This amendment applies to Preface and Clauses 3, and 6.

Published on 31 October 2008

Approved for publication in Australia on behalf of the Council of Standards Australia on 2 September 2008

Approved for publication in New Zealand by the Standards Council of New Zealand on 3 September 2008

This amendment takes effect from the date of publication.

Preface

Replace the second paragraph by the following:

This Standard incorporates Amendment No. 1 (November 2003) and Amendment 2 (October 2008). The changes required by the amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected. Where an application date other than immediate is applicable to an amendment the date of application (DOA) is indicated by the marginal bar against the part affected.

3 REFERENCED DOCUMENTS

Under the list of Australian standards replace the reference to AS 1939" by:

60529 Degrees of protection provided by enclosures (IP Code)

6 MEANS OF CONNECTION

Replace "6.1" by "6.1.1"

Add the following:

6.1.2 Connection via a socket outlet

The duct heater shall be provided with a supply cord and plug in accordance with clause 4.4 and clause 4.5 of AS/NZS 3100. However, the length of the supply flexible cord is not limited.

ISBN 0-7337-8914-5

6.2 Marking of terminals

Replace “The marking” *by* “Where it is necessary to mark and identify live supply connections the marking”