

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Amendment No. 2
to
AS/NZS 3111:2009
Approval and test specification—Miniature overcurrent circuit-breakers

REVISED TEXT

The 2009 edition of AS/NZS 3111 is amended as follows; the amendments should be inserted in the appropriate places.

SUMMARY: This Amendment applies to Clauses 7.5.1 and 7.11.3.

Published on 12 June 2015.

Approved for publication in New Zealand on behalf of the Standards Council of New Zealand on 29 May 2015.

Clause 7.5.1

Delete Item (b) and *replace* with the following:

- (b) With the circuit-breaker in the closed position, between each pole in turn and the others connected together. Applicable only for a circuit-breaker having more than one pole.
 - (c) With the circuit-breaker in the open position, between the incoming terminals and outgoing terminals. For a circuit-breaker having more than one pole, on each pole in turn.
-

Clause 7.11.3

First sentence, *delete* '±20%' and *replace* with '±20°'.

AMDT
No. 2
JUN
2015

AMDT
No. 2
JUN
2015

This page has been left intentionally blank.