

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Amendment No. 1
to
AS/NZS 3500.1.2:1998
National plumbing and drainage
Part 1.2: Water supply—Acceptable solutions

REVISED TEXT

The 1998 edition of AS/NZS 3500.1.2 is amended as follows; the amendments should be inserted in the appropriate places.

SUMMARY: This Amendment applies to Clauses 2.6.5 and 5.6.9.

Published on 27 August 2002.

Approved for publication in New Zealand on behalf of the Standards Council of New Zealand on 6 June 2002.

AMDT
No. 1
AUG
2002

Page 15 Clause 2.6.5

Add new Clause 2.6.5.

2.6.5 Rolled grooved joints Rolled grooved joints shall comply with the specification relevant to the pipe material being used.

AMDT
No. 1
AUG
2002

Page 34 Clause 5.6.9

Delete existing Clause and *replace* with the following:

5.6.9 Shouldered or grooved joints Shouldered or grooved joints buried below ground level shall only be permitted where—

- (a) they are manufactured from copper tubes to AS 1432;
- (b) installed in accordance with manufacturer's instructions;
- (c) protected against corrosion; and
- (d) external to a building and not under concrete.

This page has been left intentionally blank.