

Australian/New Zealand Standard™

**Performance of electrical appliances—
Air conditioners and heat pumps**

**Part 4.2: Air-cooled air conditioners and
air-to-air heat pumps—Testing and
calculating methods for seasonal
performance factors—Heating seasonal
performance factor (ISO 16358-2:2013,
(MOD))**



AS/NZS 3823.4.2:2014

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-056, Room Air Conditioners. It was approved on behalf of the Council of Standards Australia on 5 September 2014 and on behalf of the Council of Standards New Zealand on 12 September 2014.
This Standard was published on 1 October 2014.

The following are represented on Committee EL-056:

Airconditioning and Refrigeration Equipment Manufacturers Association of Australia
Australian Building Codes Board
Australian Industry Group
CHOICE
Consumer Electronics Association of New Zealand
Consumer Electronics Suppliers Association
Department of Industry (Australian Government)
Electrical Compliance Testing Association
Energy Efficiency and Conservation Authority of New Zealand
Energy Safe Victoria
Institute of Refrigeration Heating and Air Conditioning Engineers of New Zealand
Institution of Professional Engineers New Zealand
University of New South Wales

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR 102471.

Australian/New Zealand Standard™

Performance of electrical appliances— Air conditioners and heat pumps

Part 4.2: Air-cooled air conditioners and air-to-air heat pumps—Testing and calculating methods for seasonal performance factors—Heating seasonal performance factor (ISO 16358-2:2013, (MOD))

First published as AS/NZS 3823.4.2:2014.

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140.

ISBN 978 1 74342 852 8

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-056, Room Air Conditioners.

The objective of this Standard is to provide a method of testing and calculating the seasonal performance factor of equipment using temperature bin distributions modified for Australian and New Zealand conditions.

This Standard is an adoption with national modifications and has been reproduced from ISO 16358-2:2013, *Air-cooled air conditioners and air-to-air heat pumps—Testing and calculating methods for seasonal performance factors*, Part 2: *Heating seasonal performance factor*, and its Corrigendum 1:2013, which has been added immediately after the main source text. ISO 16358-3 has been varied as indicated to take account of Australian/New Zealand conditions. The modifications are specified in Appendix ZZ.

As this Standard is reproduced from an International Standard, the following applies:

- (a) In the source text ‘this part of ISO 16358’ should read ‘this Australian/New Zealand Standard’.
- (b) A full point substitutes for a comma when referring to a decimal marker.

References to International Standards should be replaced by references to Australian or Australian/New Zealand Standards, as follows:

<i>Reference to International Standard</i>		<i>Australian/New Zealand Standard</i>	
ISO		AS/NZS	
5151	Non-ducted air conditioners and heat pumps—Testing and rating for performance	3823	Performance of electrical appliances—Airconditioners and heat pumps
		3823.1.1	Part 1.1: Non-ducted airconditioners and heat pumps—Testing and rating for performance (ISO 5151:2010, MOD)
13253	Ducted air-conditioners and air-to-air heat pumps—Testing and rating for performance	3823.1.2	Part 1.2: Ducted airconditioners and air-to-air heat pumps—Testing and rating for performance (ISO 13253:2011, MOD)
15042	Multiple split-system air-conditioners and air-to-air heat pumps—Testing and rating for performance	3823.1.4	Part 1.4: Multiple split-system airconditioners and air-to-air heat pumps—Testing and rating for performance (ISO 15042:2011, MOD)

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the annex or appendix to which they apply. A ‘normative’ annex or appendix is an integral part of a Standard, whereas an ‘informative’ annex or appendix is only for information and guidance.

CONTENTS

1	Scope	1
2	Normative references	1
3	Terms and definitions	1
4	Symbols	4
5	Tests	7
5.1	General	7
5.2	Test conditions	7
5.3	Test methods	9
6	Calculations	10
6.1	Heating seasonal performance factor (HSPF) and total heating seasonal performance factor (THSPF)	10
6.2	Defined heating load	10
6.3	Outdoor temperature bin distribution for heating	10
6.4	Heating seasonal characteristics of fixed capacity units	11
6.5	Heating seasonal characteristics of two-stage capacity units	13
6.6	Heating seasonal characteristics of multi-stage capacity units	15
6.7	Heating seasonal characteristics of variable capacity units	20
7	Test report	24
Annex A (informative) Figures		26
Annex B (informative) Calculation of total heating seasonal performance factor (THSPF)		30
Annex C (normative) Testing and calculation method for degradation coefficient of cyclic operation		32
Annex D (informative) Calculating method for seasonal performance factor when setting a specific heating load		35
Annex E (informative) Calculating method for temperature when defined load line crosses each capacity line		36

NOTES

AUSTRALIAN/NEW ZEALAND STANDARD

Performance of electrical appliances—Air conditioners and heat pumps**Part 4.2:**

Air-cooled air conditioners and air-to-air heat pumps—Testing and calculating methods for seasonal performance factors—Heating seasonal performance factor (ISO 16358.2:2013, (MOD))

1 Scope

1.1 This part of ISO 16358 specifies the testing and calculating methods for seasonal performance factor of equipment covered by ISO 5151, ISO 13253 and ISO 15042. For the purposes of this part of ISO 16358, it is assumed that any make-up heating will be provided by electric heaters running concurrently with the heat pump.

1.2 This part of ISO 16358 also specifies the seasonal performance test conditions and the corresponding test procedures for determining the seasonal performance factor of equipment, as specified in [1.1](#), under mandatory test conditions and is intended for use only in marking, comparison, and certification purposes.

1.3 This part of ISO 16358 does not apply to the testing and rating of:

- a) water-source heat pumps or water-cooled air conditioners;
- b) portable units having a condenser exhaust duct;
- c) individual assemblies not constituting a complete refrigeration system; or
- d) equipment using the absorption refrigeration cycle.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5151, *Non-ducted air conditioners and heat pumps — Testing and rating for performance*

ISO 13253, *Ducted air-conditioners and air-to-air heat pumps — Testing and rating for performance*

ISO 15042, *Multiple split-system air-conditioners and air-to-air heat pumps — Testing and rating for performance*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 5151, ISO 13253, ISO 15042 and the following apply.

3.1

defined heating load, L_h

heat defined as heating demand for a given outdoor temperature

3.2**make-up heating**

electric heat required to cover the deficiency of the heating capacity delivered by the heat pump for the heating load

3.3**heating seasonal total load****HSTL**

total annual amount of heat, including make-up heat, which is added to the indoor air when the equipment is operated for heating in active mode

3.4**heating seasonal energy consumption****HSEC**

total annual amount of energy consumed by the equipment, including make-up heat, when it is operated for heating in active mode

3.5**heating seasonal performance factor****HSPF**

ratio of the total annual amount of heat that the equipment, including make-up heat, can add to the indoor air when operated for heating in active mode to the total annual amount of energy consumed by the equipment during the same period

3.6**part load factor****PLF**

ratio of the performance when the equipment is cyclically operated to the performance when the equipment is continuously operated, at the same temperature and humidity conditions

3.7**degradation coefficient, C_D**

coefficient that indicates efficiency loss caused by cyclic operation

3.8**fixed capacity unit**

equipment which does not have possibility to change its capacity

Note 1 to entry: to entry This definition applies to each cooling and heating operation individually.

3.9**two (2)-stage capacity unit**

equipment where the capacity is varied by two steps

Note 1 to entry: This definition applies to each cooling and heating operation individually.

3.10**multi-stage capacity unit**

equipment where the capacity is varied by 3 or 4 steps

Note 1 to entry: This definition applies to each cooling and heating operation individually.

3.11**variable capacity unit**

equipment where the capacity is varied by five or more steps to represent continuously variable capacity

Note 1 to entry: This definition applies to each cooling and heating operation individually.

3.12**heating full-load operation**

operation with the equipment and controls configured for maximum continuous refrigeration capacity at H1 condition

Note 1 to entry: Unless otherwise regulated by the automatic controls of the equipment, all indoor units and compressors shall be functioning.

3.13**heating extended-load operation**

operation of the equipment at maximum continuous refrigeration capacity at H2 condition

Note 1 to entry: Unless otherwise regulated by the automatic controls of the equipment, all indoor units and compressors shall be functioning.

3.14**minimum-load operation**

operation of the equipment and controls at minimum continuous refrigeration capacity

Note 1 to entry: All indoor units shall be functioning

3.15**standard heating full capacity**

heating capacity at H1 at full-load operating condition

3.16**standard heating full power input**

electric power input at H1 at full-load operating condition

3.17**standard heating half capacity**

capacity which is 50 % of heating full capacity at H1 condition with all indoor units functioning

3.18**standard heating half power input**

electric power input when operated at 50 % of heating full capacity at H1 condition with all indoor units functioning

3.19**standard heating minimum capacity**

capacity which is minimum heating capacity at H1 condition at the minimum-load operation

3.20**standard heating minimum power input**

electric power input when operated at minimum heating capacity at H1 condition at the minimum-load operation

3.21**standard heating extended capacity**

heating capacity when operated at H2 condition at the extended-load operation

3.22**standard heating extended power input**

electric power input when operated at H2 condition at the extended-load operation

3.23**total heating seasonal performance factor****THSPF**

ratio of the total annual amount of heat that the equipment, including make-up heat, can add to the indoor air to the total annual amount of energy consumed by the equipment, including the active, inactive and disconnected modes

3.24**active mode**

mode corresponding to the hours with a heating demand of the building and whereby the heating function of the unit is switched on

3.25**inactive mode**

mode corresponding to the hours when the unit is not operating to meet heating demand

Note 1 to entry: This mode may include the operation of a crankcase heater.

3.26**disconnected mode**

mode corresponding to the hours when the unit is electrically disconnected from the main power supply

Note 1 to entry: Power consumption is zero.

4 Symbols

Symbol	Description	Unit
C_{HSE}	heating seasonal energy consumption (HSEC)	Wh
$C_{OP}(t)$	heating coefficient of performance (COP) at continuous outdoor temperature t	W/W
$C_{OP}(t_j)$	heating coefficient of performance (COP) at outdoor temperature t_j	W/W
$C_{OP, ext}(t_h)$	heating coefficient of performance (COP) when heating load is equal to non-frosting range heating extended capacity	W/W
$C_{OP, ext, f}(t_f)$	heating coefficient of performance (COP) when heating load is equal to frosting range heating extended capacity	W/W
$C_{OP, fe}(t_j)$	heating coefficient of performance (COP) in non-frosting variable operation between full and extended capacity at outdoor temperature t_j	W/W
$C_{OP, fe, f}(t_j)$	heating coefficient of performance (COP) in frosting variable operation between full and extended capacity at outdoor temperature t_j	W/W
$C_{OP, ful}(t_a)$	heating coefficient of performance (COP) when heating load is equal to non-frosting range heating full capacity	W/W
$C_{OP, ful, f}(t_g)$	heating coefficient of performance (COP) when heating load is equal to frosting range heating full capacity	W/W
$C_{OP, haf}(t_d)$	heating coefficient of performance (COP) when heating load is equal to non-frosting range heating half capacity	W/W
$C_{OP, haf, f}(t_e)$	heating coefficient of performance (COP) when heating load is equal to frosting range heating half capacity	W/W
$C_{OP, hf}(t_j)$	heating coefficient of performance (COP) in non-frosting variable operation between half and full capacity at outdoor temperature t_j	W/W
$C_{OP, hf, f}(t_j)$	heating coefficient of performance (COP) in frosting variable operation between half and full capacity at outdoor temperature t_j	W/W
$C_{OP, mh}(t_j)$	heating coefficient of performance (COP) in non-frosting variable operation between minimum and half capacity at outdoor temperature t_j	W/W
$C_{OP, mh, f}(t_j)$	heating coefficient of performance (COP) in frosting variable operation between minimum and half capacity at outdoor temperature t_j	W/W
$C_{OP, min}(t_q)$	heating coefficient of performance (COP) when heating load is equal to non-frosting range heating minimum capacity	W/W

Symbol	Description	Unit
$C_{OP, min, f}(t_r)$	heating coefficient of performance (COP) when heating load is equal to frosting range heating minimum capacity	W/W
F_{HSP}	heating seasonal performance factor (HSPF)	–
$F_{PL}(t_j)$	part load factor (PLF) at outdoor temperature t_j	–
F_{THSP}	total heating seasonal performance factor (THSPF)	–
L_{HST}	heating seasonal total load (HSTL)	Wh
$L_h(t_j)$	defined heating load at outdoor temperature t_j	W
n	number of temperature bins	–
n_j	bin hours	h
$P(t)$	heating power input calculated by equation of $P(t_j)$ at continuous outdoor temperature t	W
$P(t_j)$	heating power input applicable to any capacity at outdoor temperature t_j	W
$P_{ext}(t_j)$	non-frosting range heating extended power input at outdoor temperature t_j	W
$P_{ext}(-7)$	heating extended power input at outdoor temperature $-7\text{ }^{\circ}\text{C}$	W
$P_{ext}(2)$	calculated heating extended power input at outdoor temperature $2\text{ }^{\circ}\text{C}$	W
$P_{ext, f}(t_j)$	frosting range heating extended power input at outdoor temperature t_j	W
$P_{ext, f}(2)$	heating extended power input at H2 temperature condition	W
$P_{fe}(t_j)$	heating power input in variable operation between full and extended capacity at outdoor temperature t_j	W
$P_{ful}(t_j)$	non-frosting range heating full power input at outdoor temperature t_j	W
$P_{ful}(7)$	heating full power input at H1 temperature condition	W
$P_{ful}(-7)$	heating full power input at outdoor temperature $-7\text{ }^{\circ}\text{C}$	W
$P_{ful}(2)$	calculated heating full power input at outdoor temperature $2\text{ }^{\circ}\text{C}$	W
$P_{ful, f}(t_j)$	frosting range heating full power input at outdoor temperature t_j	W
$P_{ful, f}(2)$	heating full power input at H2 temperature condition	W
$P_{haf}(t_j)$	non-frosting range heating half power input at outdoor temperature t_j	W
$P_{haf}(7)$	heating half power input at H1 temperature condition	W
$P_{haf}(-7)$	heating half power input at outdoor temperature $-7\text{ }^{\circ}\text{C}$	W
$P_{haf}(2)$	calculated heating half power input at outdoor temperature $2\text{ }^{\circ}\text{C}$	W
$P_{haf, f}(t_j)$	frosting range heating half power input at outdoor temperature t_j	W
$P_{haf, f}(2)$	heating half power input at H2 temperature condition	W
$P_{hf}(t_j)$	heating power input in variable operation between half and full capacity at outdoor temperature t_j	W
$P_{mf}(t_j)$	heating power input in second stage cyclic operation between minimum and full capacity at outdoor temperature t_j	W
$P_{mh}(t_j)$	heating power input in variable operation between minimum and half capacity at outdoor temperature t_j	W
$P_{min}(t_j)$	non-frosting range heating minimum power input at outdoor temperature t_j	W
$P_{min}(7)$	heating minimum power input at H1 temperature condition	W
$P_{min}(-7)$	heating minimum power input at outdoor temperature $-7\text{ }^{\circ}\text{C}$	W
$P_{min}(2)$	calculated heating minimum power input at outdoor temperature $2\text{ }^{\circ}\text{C}$	W

Symbol	Description	Unit
$P_{\min, f(t_j)}$	frosting range heating minimum power input at outdoor temperature t_j	W
$P_{\min, f(2)}$	heating minimum power input at H2 temperature condition	W
$P_{RH}(t_j)$	make-up heating energy at outdoor temperature t_j	Wh
t	general continuous outdoor temperature	°C
t_j	outdoor temperature corresponding to each temperature bin	°C
t_a	outdoor temperature when heating load is equal to non-frosting range heating full capacity	°C
t_d	outdoor temperature when heating load is equal to non-frosting range heating half capacity	°C
t_e	outdoor temperature when heating load is equal to frosting range heating half capacity	°C
t_f	outdoor temperature when heating load is equal to frosting range heating extended capacity	°C
t_g	outdoor temperature when heating load is equal to frosting range heating full capacity	°C
t_h	outdoor temperature when heating load is equal to non-frosting range heating extended capacity	°C
t_q	outdoor temperature when heating load is equal to non-frosting range heating minimum capacity	°C
t_r	outdoor temperature when heating load is equal to frosting range heating minimum capacity	°C
$X(t_j)$	ratio of load to capacity at outdoor temperature t_j	–
$X_{fe}(t_j)$	ratio of excess capacity over load to capacity difference between full and extended capacity at outdoor temperature t_j	–
$X_{hf}(t_j)$	ratio of excess capacity over load to capacity difference between half and full capacity at outdoor temperature t_j	–
$X_{mf}(t_j)$	ratio of excess capacity over load to capacity difference between minimum and full capacity at outdoor temperature t_j	–
$X_{mh}(t_j)$	ratio of excess capacity over load to capacity difference between minimum and half capacity at outdoor temperature t_j	–
$\phi(t)$	heating capacity calculated by equation of $\phi(t_j)$ at continuous outdoor temperature t	W
$\phi(t_j)$	heating capacity applicable to any capacity at outdoor temperature t_j	W
$\phi_{\text{ext}}(t_j)$	non-frosting range heating extended capacity at outdoor temperature t_j	W
$\phi_{\text{ext}}(-7)$	heating extended capacity at outdoor temperature -7°C	W
$\phi_{\text{ext}}(2)$	calculated heating extended capacity at outdoor temperature 2°C	W
$\phi_{\text{ext}, f}(t_j)$	frosting range heating extended capacity at outdoor temperature t_j	W
$\phi_{\text{ext}, f}(2)$	frosting range heating extended capacity at H2 temperature condition	W
$\phi_{\text{ful}}(t_j)$	non-frosting range heating full capacity at outdoor temperature t_j	W
$\phi_{\text{ful}}(7)$	heating full capacity at H1 temperature condition	W
$\phi_{\text{ful}}(-7)$	heating full capacity at outdoor temperature -7°C	W
$\phi_{\text{ful}}(2)$	calculated heating full capacity at outdoor temperature 2°C	W
$\phi_{\text{ful}, f}(t_j)$	frosting range heating full capacity at outdoor temperature t_j	W
$\phi_{\text{ful}, f}(2)$	frosting range heating full capacity at H2 temperature condition	W

Symbol	Description	Unit
$\phi_{\text{haf}}(t_j)$	non-frosting range heating half capacity at outdoor temperature t_j	W
$\phi_{\text{haf}}(7)$	heating half capacity at H1 temperature condition	W
$\phi_{\text{haf}}(-7)$	heating half capacity at outdoor temperature $-7\text{ }^{\circ}\text{C}$	W
$\phi_{\text{haf}}(2)$	calculated heating half capacity at outdoor temperature $2\text{ }^{\circ}\text{C}$	W
$\phi_{\text{haf}, f}(t_j)$	frosting range heating half capacity at outdoor temperature t_j	W
$\phi_{\text{haf}, f}(2)$	frosting range heating half capacity at H2 temperature condition	W
$\phi_{\text{min}}(t_j)$	non-frosting range heating minimum capacity at outdoor temperature t_j	W
$\phi_{\text{min}}(7)$	heating minimum capacity at H1 temperature condition	W
$\phi_{\text{min}}(-7)$	heating minimum capacity at outdoor temperature $-7\text{ }^{\circ}\text{C}$	W
$\phi_{\text{min}}(2)$	calculated heating minimum capacity at outdoor temperature $2\text{ }^{\circ}\text{C}$	W
$\phi_{\text{min}, f}(t_j)$	frosting range heating minimum capacity at outdoor temperature t_j	W
$\phi_{\text{min}, f}(2)$	frosting range heating minimum capacity at H2 temperature condition	W

5 Tests

5.1 General

These tests are additional to those in ISO 5151, ISO 13253 and ISO 15042.

The accuracy of the instruments used for tests shall conform to the test methods and uncertainties of measurements specified in ISO 5151, ISO 13253 and ISO 15042.

5.2 Test conditions

Temperature and humidity conditions as well as default values for calculation shall be as specified in [Table 1](#).

Table 1 — Temperature and humidity conditions and default values for heating

Test	Characteristics	Fixed	Two-stage	Multi-stage	Variable	Default value
Standard heating capacity	Full capacity $\phi_{\text{ful}}(7)$ (W)	■	■	■	■	
	Full power input $P_{\text{ful}}(7)$ (W)					
Indoor DB 20°C WB 15°C Max.	Half capacity $\phi_{\text{haf}}(7)$ (W)	—	—	■	■	
	Half power input $P_{\text{haf}}(7)$ (W)					
Outdoor DB 7°C WB 6°C	Minimum capacity $\phi_{\text{min}}(7)$ (W)	—	■	○	○	
	Minimum power input $P_{\text{min}}(7)$ (W)					
Low temperature heating capacity	Extended capacity $\phi_{\text{ext},f}(2)$ (W)	—	—	■ ^a	■ ^a	
	Extended power input $P_{\text{ext},f}(2)$ (W)					
	Calculated extended capacity $\phi_{\text{ext}}(2)$ (W)	—	—	b	b	1,12 $\phi_{\text{ext},f}(2)$
	Calculated extended power input $P_{\text{ext}}(2)$ (W)					1,06 $P_{\text{ext},f}(2)$
	Indoor DB 20°C	■ ^c	■ ^c	□ ^{ac}	□ ^{ac}	$\phi_{\text{ful}}(2)/1,12^{\text{d}}$
	WB 15°C Max.					$P_{\text{ful}}(2)/1,06^{\text{d}}$
	Outdoor DB 2°C	—	—	○ ^c	○ ^c	$\phi_{\text{haf}}(2)/1,12^{\text{d}}$
	WB 1°C					$P_{\text{haf}}(2)/1,06^{\text{d}}$
	Minimum capacity $\phi_{\text{min},f}(2)$ (W)	—	○ ^c	—	—	$\phi_{\text{min}}(2)/1,12^{\text{d}}$
	Minimum power input $P_{\text{min},f}(2)$ (W)					$P_{\text{min}}(2)/1,06^{\text{d}}$
Extra-low temperature heating capacity	Extended capacity $\phi_{\text{ext}}(-7)$ (W)	—	—	○	○	0,734 $\phi_{\text{ext}}(2)$
	Extended power input $P_{\text{ext}}(-7)$ (W)					0,877 $P_{\text{ext}}(2)$
	Full capacity $\phi_{\text{ful}}(-7)$ (W)	○	○	○	○	0,64 $\phi_{\text{ful}}(7)$
	Full power input $P_{\text{ful}}(-7)$ (W)					0,82 $P_{\text{ful}}(7)$
	Indoor DB 20°C	—	—	○	○	0,64 $\phi_{\text{haf}}(7)$
	WB 15°C Max.					0,82 $P_{\text{haf}}(7)$
	Outdoor DB -7°C	—	—	—	—	0,64 $\phi_{\text{min}}(7)$
	WB -8°C					0,82 $P_{\text{min}}(7)$
Cyclic heating	Degradation coefficient C_D	○	—	—	—	0,25
		—	—	○	—	0,25
		—	○	○	—	0,25

■ required test.

○ optional test.

□ test required when there is not an extended mode.

^a When the equipment has an extended mode, low temperature extended capacity measurement is mandatory and low temperature full capacity measurement is optional. When the equipment has not an extended mode, low temperature full capacity measurement is mandatory.

^b This value shall be calculated using default value.

^c When this value is measured, $\phi_x(2)$ and/or $P_x(2)$ shall not be calculated from this value, but the equations in footnote d shall be used instead.

^d The following two equations apply to the full capacity, half capacity and minimum capacity data when $\phi_{x,f}(2)$ and $P_{x,f}(2)$ are calculated:

$$\phi_x(2) = \phi_x(-7) + \frac{\phi_x(7) - \phi_x(-7)}{7 - (-7)} \times (2 - (-7)), \quad P_x(2) = P_x(-7) + \frac{P_x(7) - P_x(-7)}{7 - (-7)} \times (2 - (-7))$$

NOTE Voltage(s) and frequency(ies) shall be as given in the three referenced standards.

5.3 Test methods

5.3.1 Standard heating capacity tests

The standard heating capacity tests shall be conducted in accordance with Annex A of ISO 5151 and Annex B of ISO 13253 and ISO 15042. The heating capacity and effective power input shall be measured during the standard heating capacity tests.

The half capacity test shall be conducted at 50 % of full load operation. The test tolerance shall be ± 5 % of full load capacity for continuously variable equipment. For multi-stage equipment, if 50 % capacity is not achievable, then the test shall be conducted at the next step above 50 %.

The minimum capacity test shall be conducted at the lowest capacity control setting which allows steady-state operation of the equipment at the given test conditions.

If the minimum capacity tests are conducted, but if the required uncertainty of measurement specified in ISO 5151, ISO 13253 and ISO 15042 cannot be achieved, the alternative method of calculation shall be used. (Refer to [6.6.4](#) and [6.7.4](#).)

The manufacturer shall provide information on how to set the capacity if requested by the testing laboratories.

5.3.2 Low temperature heating capacity test

The low temperature heating capacity test shall be conducted at H2 condition in accordance with Annex A of ISO 5151 and Annex B of ISO 13253 and ISO 15042. The heating capacity and effective power input shall be measured during the low temperature heating capacity test.

The half capacity test shall be conducted at 50 % of full load operation. The test tolerance shall be ± 5 % of full load capacity for continuously variable equipment. For multi-stage equipment, if 50 % capacity is not achievable, then the test shall be conducted at the next step above 50 %.

The minimum capacity test shall be conducted at the lowest capacity control setting which allows steady-state operation of the equipment at the given test conditions.

If the minimum capacity tests are conducted, but if the required uncertainty of measurement specified in ISO 5151, ISO 13253 and ISO 15042 cannot be achieved, the alternative method of calculation shall be used. (Refer to [6.6.4](#) and [6.7.4](#).)

The manufacturer shall provide information on how to set the capacity if requested by the testing laboratories.

5.3.3 Extra-low temperature heating capacity test

The extra-low temperature heating capacity test shall be conducted at H3 condition in accordance with Annex A of ISO 5151 and Annex B of ISO 13253 and ISO 15042. The heating capacity and effective power input shall be measured during the extra-low temperature heating capacity test. If the test is not conducted, default values as given in [Table 1](#) shall be used.

The half capacity test shall be conducted at 50 % of full load operation. The test tolerance shall be ± 5 % of full load capacity for continuously variable equipment. For multi-stage equipment, if 50 % capacity is not achievable, then the test shall be conducted at the next step above 50 %.

The manufacturer shall provide information on how to set the capacity if requested by the testing laboratories.

5.3.4 Cyclic heating test

The cyclic heating test shall be conducted in accordance with [Annex C](#). If the test is not conducted, default values as given in [Table 1](#) shall be used.

6 Calculations

6.1 Heating seasonal performance factor (HSPF) and total heating seasonal performance factor (THSPF)

Heating seasonal performance factor (HSPF), F_{HSP} , of the equipment shall be calculated by Formula (1).

$$F_{HSP} = \frac{L_{HST}}{C_{HSE}} \quad (1)$$

In case of calculating the total heating seasonal performance factor (THSPF), refer to [Annex B](#).

6.2 Defined heating load

The defined heating load shall be represented by a value and the assumption that it is linearly changing depending on the change in outdoor temperature.

Defined heating load which shall be used is shown in [Table 2](#).

Table 2 — Defined heating load

Parameter	Load zero (0)	Load 100 %
Heating load (W)	0	$0,82 \times \phi_{ful}(H1)$
Temperature(°C)	t_0	t_{100}

where t_{100} is the outdoor temperature at 100 % load and t_0 is the outdoor temperature at 0 % load.

Reference values of defined heating load to be used shall be as follows:

$$t_0 = 17 \text{ °C and } t_{100} = 0 \text{ °C}$$

In case of setting other heating load, refer to the setting method as described in [Annex D](#).

Defined heating load $L_h(t_j)$ at outdoor temperature t_j , which is necessary to calculate heating seasonal performance factor, shall be determined by Formula (2).

$$L_h(t_j) = \frac{\phi_{ful}(t_{100}) \times (t_0 - t_j)}{(t_0 - t_{100})} \quad (2)$$

where $\phi_{ful}(t_{100})$ is the heating capacity at t_{100} at full-load operating conditions.

Ratio of the heating operational capacity at 0 °C in non-frosting condition to the standard heating capacity at 7 °C is assumed to be 0,82.

6.3 Outdoor temperature bin distribution for heating

Value of outdoor temperature and bin hours differ from region to region. If bin hours is set to a certain value for a certain region, the integrated value of heating load and electric energy consumption can be determined.

[Table 3](#) shows the reference outdoor temperature bin distribution.

Table 3 — Reference outdoor temperature bin distribution for heating

Bin number j	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Outdoor temperature t_j °C	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3
Fractional bin hours	0	0	0	0	0	0	0	0	0	0,001	0,005	0,012	0,024	0,042
Bin hours n_j	n_1	n_2	n_3	n_4	n_5	n_6	n_7	n_8	n_9	n_{10}	n_{11}	n_{12}	n_{13}	n_{14}
Reference bin hours (n_j) h	0	0	0	0	0	0	0	0	0	4	15	33	68	119
Bin number j	15	16	17	18	19	20	21	22	23	24	25	26	27	Total
Outdoor temperature t_j °C	4	5	6	7	8	9	10	11	12	13	14	15	16	
Fractional bin hours	0,059	0,070	0,082	0,087	0,091	0,092	0,091	0,085	0,075	0,067	0,053	0,038	0,027	
Bin hours n_j	n_{15}	n_{16}	n_{17}	n_{18}	n_{19}	n_{20}	n_{21}	n_{22}	n_{23}	n_{24}	n_{25}	n_{26}	n_{27}	
Reference bin hours (n_j) h	169	200	234	250	260	265	260	245	215	192	151	110	76	2 866

Bin hours of each outdoor temperature may be calculated by multiplying the fractional bin hours by the total annual heating hours if the fractional bin hours are applicable.

In case of setting other outdoor temperature bin distribution, refer to the setting method as described in [Annex D](#).

6.4 Heating seasonal characteristics of fixed capacity units

Operational performance at each test, which is necessary to calculate the heating seasonal performance factor, shall be in accordance with [Table 1](#).

6.4.1 Capacity characteristics against outdoor temperature

Frosting occurs in a range of outdoor temperature from 5,5 °C to -7 °C. It is assumed that decrease rates in heating capacity and electric power input due to defrost operation are the biggest when operated at 5,5 °C, then become smaller as outdoor temperature goes down, and reach zero (0) at -7 °C.

- a) In case that outdoor temperature is in non-frosting temperature range ($t_j \leq -7^\circ\text{C}$ or $5,5^\circ\text{C} \leq t_j$):

Capacity $\phi_{\text{ful}}(t_j)$ (W) of the equipment when it is operated for heating at outdoor temperature t_j shall linearly change depending on outdoor temperatures in the non-frosting temperature range, as shown in [Figure A.1](#) in [Annex A](#), and be determined by Formula (3).

$$\phi_{\text{ful}}(t_j) = \phi_{\text{ful}}(-7) + \frac{\phi_{\text{ful}}(7) - \phi_{\text{ful}}(-7)}{7 - (-7)} \times (t_j - (-7)) \quad (3)$$

- b) In case that outdoor temperature is in frosting temperature range ($-7^\circ\text{C} < t_j < 5,5^\circ\text{C}$):

Capacity $\phi_{\text{ful},f}(t_j)$ (W) of the equipment when it is operated for heating at outdoor temperature t_j shall linearly change depending on outdoor temperatures in the frosting temperature range, as shown in [Figure A.1](#) in [Annex A](#), and be determined by Formula (4).

$$\phi_{\text{ful},f}(t_j) = \phi_{\text{ful}}(-7) + \frac{\phi_{\text{ful},f}(2) - \phi_{\text{ful}}(-7)}{2 - (-7)} \times (t_j - (-7)) \quad (4)$$

6.4.2 Power input characteristics against outdoor temperature

- a) Electric power input $P_{\text{ful}}(t_j)$ (W) of the equipment when it is operated for heating at outdoor temperature t_j shall linearly change depending on outdoor temperatures in the non-frosting temperature range, as shown in [Figure A.1](#) in [Annex A](#), and be determined by Formula (5).

$$P_{\text{ful}}(t_j) = P_{\text{ful}}(-7) + \frac{P_{\text{ful}}(7) - P_{\text{ful}}(-7)}{7 - (-7)} \times (t_j - (-7)) \quad (5)$$

- b) Electric power input $P_{\text{ful},f}(t_j)$ (W) of the equipment when it is operated for heating at outdoor temperature t_j shall linearly change depending on outdoor temperatures in the frosting temperature range, as shown in [Figure A.1](#) in [Annex A](#), and be determined by Formula (6).

$$P_{\text{ful},f}(t_j) = P_{\text{ful}}(-7) + \frac{P_{\text{ful},f}(2) - P_{\text{ful}}(-7)}{2 - (-7)} \times (t_j - (-7)) \quad (6)$$

6.4.3 Calculation of heating seasonal total load (HSTL)

Heating seasonal total load (HSTL), L_{HST} , shall be calculated by Formula (7).

$$L_{\text{HST}} = \sum_{j=1}^n L_h(t_j) \times n_j \quad (7)$$

6.4.4 Calculation of heating seasonal energy consumption (HSEC)

Heating seasonal energy consumption (HSEC), C_{HSE} , shall be determined using Formula (8) from the total sum of heating energy consumption at each outdoor temperature t_j .

$$C_{\text{HSE}} = \sum_{j=1}^n \frac{X(t_j) \times P(t_j) \times n_j}{F_{\text{PL}}(t_j)} + \sum_{j=1}^n P_{\text{RH}}(t_j) \times n_j \quad (8)$$

When load is rather large as compared to heating capacity, make-up heating by the electric heater shall be added.

Operation factor $X(t_j)$ shall be calculated by Formula (9).

$$X(t_j) = \frac{L_h(t_j)}{\phi(t_j)} \quad (9)$$

Part load factor (PLF), $F_{\text{PL}}(t_j)$, shall be calculated by Formula (10) using degradation coefficient C_D .

$$F_{\text{PL}}(t_j) = 1 - C_D (1 - X(t_j)) \quad (10)$$

When $L_h(t_j) > \phi(t_j)$, $X(t_j) = F_{\text{PL}}(t_j) = 1$.

Make-up heat $P_{\text{RH}}(t_j)$ shall be calculated by Formula (11).

$$P_{\text{RH}}(t_j) = L_h(t_j) - \phi(t_j) \quad (11)$$

- a) Non-frosting temperature range ($t_j \leq -7^\circ\text{C}$ or $5,5^\circ\text{C} \leq t_j$)

- 1) Cyclic operation ($L_h(t_j) \leq \phi_{\text{ful}}(t_j)$)

$$P_{\text{RH}}(t_j) = 0$$

$$\phi(t_j) = \phi_{\text{ful}}(t_j) \text{ in Formula (9)}$$

$$P(t_j) = P_{\text{ful}}(t_j).$$

- 2) Full capacity operation ($L_h(t_j) > \phi_{\text{ful}}(t_j)$)