

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Amendment No. 2
to
AS/NZS 4456.4:2003
Masonry units, segmental pavers and flags—Methods of test
Method 4: Determining compressive strength of masonry units

CORRECTION

The 2003 edition of AS/NZS 4456.4 is amended as follows; the amendment(s) should be inserted in the appropriate place(s).

SUMMARY: This Amendment applies to Clauses 7, 8 and 10, and the Back Cover.

Published on 9 September 2009.

Approved for publication in New Zealand on behalf of the Standards Council of New Zealand on 26 August 2009.

AMDT
No. 2
SEP
2009

Clause 7(b)

Insert new Note 3, as follows:

- ‘3 Fresh packing pieces should be used for each specimen and discarded following testing.’

AMDT
No. 2
SEP
2009

Clause 8

- 1 *Insert* the following under K_a (third line):

‘Linear interpolation shall be used.’

- 2 *Delete* the last paragraph.

- 3 *Insert* the following Notes before Table 1:

NOTES:

- 1 The width of the unit is its smaller work size measured in a horizontal plane when the unit is in its normal orientation in a wall.
- 2 The height of the unit is its vertical work size when the unit is in its normal orientation in a wall.

AMDT
No. 2
SEP
2009

Clause 10

Insert the following new Item (n):

- ‘(n) The maximum load for each specimen, in kilonewtons, to the resolution of the testing machine on the scale being used.’

AMDT
No. 2
SEP
2009

Back Cover

Under Committee Representatives:

- 1 *Delete* ‘Institute of Engineers Australia’ and *replace* with ‘Engineers Australia’.
- 2 *Delete* ‘Institute of Municipal Engineering Australia NSW Division’ and *replace* with ‘Institute of Public Works Australia (NSW Division)’.

This page has been left intentionally blank.