

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Amendment No. 1
to
AS/NZS 5000.1:2005
Electric cables—Polymeric insulated
Part 1: For working voltages up to and including 0.6/1 (1.2) kV

REVISED TEXT

The 2005 edition of AS/NZS 5000.1 is amended as follows; the amendment should be inserted in the appropriate place.

SUMMARY: This Amendment applies to Clause 16.1.

Published on 7 December 2006.

Approved for publication in New Zealand on behalf of the Standards Council of New Zealand on 24 November 2006.

AMDT
No. 1
DEC
2006

Page 17 Clause 16.1

Delete the text of List Item (e) and *substitute* the following:

Cables designed for specific applications shall be marked accordingly, as follows:

- (i) Aerial cables shall be marked with the word 'AERIAL'.
- (ii) Cables suitable for d.c. applications only shall be marked with the words 'FOR D.C. USE ONLY'.
- (iii) Fixed cables with flexible conductors shall be marked 'FOR FIXED APPLICATIONS ONLY'.

This Amendment forms part of the Standard on publication.

This page has been left intentionally blank.