

Australian/New Zealand Standard™

**Residential heating and cooling
systems—Minimum applications and
requirements for energy efficiency,
performance and comfort criteria**



AS/NZS 5141:2018

This Joint Australian/New Zealand Standard™ was prepared by Joint Technical Committee EE-001, Residential Air-conditioning. It was approved on behalf of the Council of Standards Australia on 11 October 2018 and by the New Zealand Standards Approval Board on 6 November 2018.

This Standard was published on 26 November 2018.

The following are represented on Committee EE-001:

- Airconditioning & Refrigeration Equipment Manufacturers Association of Australia
- Australian Ductwork Manufacturers Alliance
- Australian Industry Group
- Australian Institute of Refrigeration Air Conditioning and Heating
- Australian Refrigeration Council
- Climate Control Companies Association of NZ
- Consumer Electronics Suppliers Association
- E-Oz Energy Skills Australia
- Gas Appliance Manufacturers Association of Australia
- Institute of Refrigeration Heating & AirConditioning Engineers of New Zealand
- Master Plumbers and Mechanical Services Association of Australia, Vic.
- National Acoustic Laboratory
- Office of Environment and Heritage
- Refrigeration & Air Conditioning Contractors Association of Australia
- TAFE NSW
- Victorian Building Authority

This Standard was issued in draft form for comment as DR AS/NZS 5141:2018.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.standards.govt.nz

www.saiglobal.com (sales and distribution)

ISBN 978 1 76072 278 4

Australian/New Zealand Standard™

**Residential heating and cooling
systems—Minimum applications and
requirements for energy efficiency,
performance and comfort criteria**

First published as AS/NZS 5141:2018.

COPYRIGHT

© Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2018

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand).

Preface

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EE-001, Residential Air Conditioning.

The objective of this Standard is to specify requirements for the design, selection, installation, commissioning and maintenance of residential heating and cooling systems to maximize operating energy efficiency within residential buildings. It also sets requirements to achieve prescribed performance and comfort criteria.

This Standard includes requirements for ducted systems.

It does not include design and performance requirements for evaporative coolers as defined by AS 2913.

The terms “normative” and “informative” are used in a Standard to define the application of the appendices to which they apply. A “normative” appendix is an integral part of a Standard, whereas an “informative” appendix is only for information and guidance. Statements expressed in mandatory terms in notes and footnotes to tables and figures are deemed to be requirements of this Standard.

Contents

Preface	ii
Foreword	v
1 Scope and general	1
1.1 Scope	1
1.2 Application	1
1.3 Referenced documents	1
1.4 Definitions	2
2 Design	4
2.1 General	4
2.2 Design conditions	4
2.3 Heat load assessment	4
2.4 Selection and siting of equipment	5
2.4.1 General	5
2.4.2 Air filters	5
2.4.3 Safety	5
2.4.4 Outdoor air provision	5
2.4.5 Noise and vibration	6
2.4.6 Structural support	6
2.4.7 Pipework	6
2.4.8 Fuel gas supply pipes shall be in accordance with AS/NZS 5601. Electrical supply	7
2.4.9 Flashing and weatherproofing	7
2.4.10 Fire wall penetrations	7
2.4.11 Access for maintenance	7
2.4.12 Safety of outdoor unit	7
2.4.13 Siting of outdoor unit	7
2.5 Sizing/siting of return air for ducted systems	7
2.5.1 Return air grille size	7
2.5.2 Return air positioning	7
2.6 Supply air outlets	8
2.6.1 General	8
2.6.2 Design air velocities	8
2.7 Design of ductwork system	8
2.7.1 General	8
2.7.2 Flexible ductwork	8
2.7.3 Design velocity of air within ductworks	8
2.7.4 Ductwork insulation	9
2.7.5 Rigid ductwork	9
2.8 Controls	9
3 Installation requirements	9
3.1 Refrigerant use conformance	9
3.2 Ductwork	9
3.3 Pipework	9
3.3.1 Pipework installation	9
3.3.2 Pipe materials	10
3.3.3 Pipe insulation	10
3.3.4 Condensate drains	10
3.4 Electrical	11
3.5 Controls	11
3.5.1 Control cables	11
3.5.2 Temperature sensor positioning	11
3.6 Mechanical fixing	11
3.6.1 Installation of outdoor air conditioner units	11

3.6.2	Installation of gas ducted air heaters	11
3.6.3	NZ seismic requirements	12
3.6.4	AU seismic requirements	12
3.7	Non-ducted indoor units	12
4	Testing and commissioning	12
4.1	General	12
4.2	Testing and commissioning	12
4.2.1	Pre-test checks	12
4.2.2	Testing operation	12
4.2.3	Testing	12
4.2.4	Verify settings	13
4.3	Consumer handover	13
Appendix A (informative) Example of heat load estimate calculation		14
Bibliography		15

Foreword

This Standard should be read in conjunction with laws and regulations related to the installation of residential air conditioners and gas heating appliances. These include:

(a) Noise level requirements

State and local authorities may impose noise control regulations that set limits on the noise level of air conditioners. It may be the responsibility of the user of the air conditioner, or the owner/occupier of the property in which the air conditioner is installed, to ensure that noise emitted due to the operation of the machine does not have an adverse impact on the amenity of neighbours. This Standard should be read in conjunction with state and local authority noise control requirements.

(b) Minimum Energy Performance (MEPS) requirements

Air conditioners installed in Australia and New Zealand are required to meet Minimum Energy Performance (MEPS) requirements and be registered on the government website www.energyrating.gov.au. Equipment installed to this Standard should meet MEPS requirements.

(c) Electrical and gas safety

In Australia, air conditioners and gas heaters for residential use are required to be registered by a responsible supplier on the Electrical Regulatory Authorities Council (ERAC) website under the Electrical Equipment Safety System (EESS) <http://www.erac.gov.au/>. In New Zealand, the air conditioner needs to either be registered on the EESS or the New Zealand supplier needs to have issued a Supplier Declaration of Compliance (SDoC) for the air conditioner. An air conditioner is required to display the Regulatory Compliance Mark (RCM) as evidence that the appliance conforms with applicable appliance Standards. Gas ducted heaters are required to conform with AS/NZS 5263.1.6 and be certified by a Conformity Assessment Body (CAB) with the certification number and CAB's certification label displayed on the heater. In New Zealand the heater is required to carry a compliance label. Equipment installed to this Standard should conform with the relevant electrical and gas safety requirements.

(d) The National Construction Code (NCC)

The Australian National Construction Code (NCC) specifies minimum R-Value requirements for heating and cooling ductwork based on climate zone and type of heating or cooling system. Ductwork and ductwork fittings should conform with NCC requirements.

(e) Refrigerant licensing

In Australia, practitioners installing or working on air conditioning systems that are designed to contain a controlled HFC, HCFC or CFC refrigerant are required to hold a relevant licence, granted under the Ozone Protection and Synthetic Greenhouse Gas Management Regulations 1995. In New Zealand, practitioners transferring refrigerant into a pressure vessel are required to hold an Approved Filler Certificate for Class 2.2.1A refrigerant gas. Installers working with systems that are designed to contain a controlled HFC, HCFC or CFC refrigerant should hold the relevant refrigerant licences.

Commonwealth and State/Territory agencies may have additional requirements regarding installer licensing. Up-to-date information can be accessed via the appropriate agencies.

Commonwealth	Australian Refrigeration Council
ACT	Access Canberra — Construction and Workplace and Dangerous Substances Licensing
NSW	Fair Trading
NT	Electrical Workers and Contractors Licensing Board

QLD	Queensland Building and Construction Commission WorkCover Queensland
SA	Consumer and Business Services
TAS	Consumer, Business and Occupational Services Department of Justice
VIC	Energy Safe Victoria Victorian Building Authority
WA	Energy Safety — Department of Mines, Industry Regulation and Safety

(f) Installation (gasfitting) licensing

Installers working with systems that consume fuel gases are to hold the relevant gasfitting license.