

Gas installations

Part 1: General installations

Amendment No. 1

Correction amendment

Publishing and Approval Dates

Council of Standards Australia Approval: 9 February 2023

New Zealand Standards Approval Board Approval: 31 January 2023

Published: 24 March 2023

Summary

This Amendment applies to the following elements:

- Preface
- Clauses 5.2.11, 6.4, 6.4.1 and 6.10.1.1
- Table 6.10.2.3

Amendment Details

AS/NZS 5601.1:2022 is amended as follows. The amendments should be inserted in the locations as instructed.

Element	Instruction / New text
Preface	<i>Delete</i> item (H) and <i>replace</i> with the following: (H) Restrictions on the use of semi-rigid connectors in the installation of commercial catering equipment.
Cl 5.2.11	1 <i>Delete</i> last paragraph and <i>replace</i> with the following: Alternatively, for a Class 1a building in Australia, or detached or multi-unit dwelling in New Zealand, a system or device that automatically shuts off the gas supply if gas tightness is adversely affected by a fire emergency event shall be provided. The system or device which shuts off the gas supply shall be installed in a readily accessible location as close as practicable to the point of supply and prior to any multi-layer pipe. The device shall be sized and commissioned in accordance with manufacturer's instructions, to ensure safe and correct operation and avoid nuisance tripping. 2 After Note 3, <i>add</i> the following: NOTE 4: This clause also applies to the alteration of consumer piping using multilayer pipe in an existing installation but does not apply to the replacement of a gas appliance in an existing installation.
Cl 6.4	In title, <i>delete</i> "gas appliances" and <i>replace</i> with "appliances".
Cl 6.4.1	In paragraph, <i>delete</i> "Gas appliances" and <i>replace</i> with "Appliances".
Cl 6.10.1.1	In item (a)(iii), after "highest burner of the appliance", <i>add</i> "or the hob".
Tbl 6.10.2.3	1 <i>Delete</i> Note 2. 2 In Note 3, <i>delete</i> "NOTE 3" and <i>replace</i> with "NOTE 2".

Element	Instruction / New text
3	In Note 4, <i>delete</i> "NOTE 4" and <i>replace</i> with "NOTE 3".
4	In Note 5, <i>delete</i> "NOTE 5" and <i>replace</i> with "NOTE 4".
5	In Note 6, <i>delete</i> "NOTE 6" and <i>replace</i> with "NOTE 5".
7	After the table, <i>add</i> the following: The clearances in Table 6.10.2.3 do not apply where the adjacent surface and structure is non-combustible. Where the combustible materials are within the required clearance zone and the correct clearance is not able to be provided, the combustible materials shall be protected in accordance with Clause C.2. The protective materials may be covered by ceramic tiles or stainless steel to meet appropriate requirements relating to health protection.