

AS/NZS 61008.1:2015
Residual current operated circuit-breakers without integral overcurrent
protection for household and similar uses (RCCBs), Part 1: General rules
(IEC 61008-1, Ed 3.2 (2013) MOD)

Amendment No. 1

Revised text amendment

Publishing and Approval Dates

Council of Standards Australia Approval: 27 February 2024

New Zealand Standards Approval Board Approval: 7 February 2024

Published: 5 April 2024

Summary

This Amendment applies to the following element:

- Clause ZZ2

Amendment Details

AS/NZS 61008.1:2015 is amended as follows. The amendments should be inserted in the locations as instructed.

Element	Instruction / New text	
CI ZZ2	1	After modification to Introduction, <i>add</i> the following:
	1	1 Delete NOTE 5.
	2	2 After last paragraph, <i>add</i> the following: For portable RCCBs, refer to AS/NZS 3190. This standard only applies to RCCBs for fixed installation and fixed wiring.
	2	2 Delete modification to Clause 5.3.1 and <i>replace</i> with the following:
	5.3.1	After the Note, <i>add</i> the following: The marking of the rated voltage for single-phase RCCBs shall be 110 V or 230 V or 240 V or 230/240 V. The marking of the rated voltage for multi-phase RCCBs shall be 190 V or 400 V or 415 V or 400/415 V.
	3	After modification 4 of Clause 6, <i>add</i> the following:
	5	After the last paragraph of Clause 6, <i>add</i> the following: For RCCBs that have a rated voltage marking of 110 V or 190 V, the following statement shall be included in the manufacturer's literature: "This device is for use in speciality applications such as mining. It is not intended to be used in domestic installations."
	4	After modification to Clause 9.9.2.4, <i>add</i> the following:
	9.9.4	After the first sentence, <i>add</i> the following: For test purposes:
	(a)	For single phase RCCBs, if marked with a rated voltage of "230 V", "240 V" or "230/240 V" test —

Element	Instruction / New text
	(i) at 0.8×230 V; and
	(ii) at 1.1×240 V.
(b)	For multi-phase RCCBs, if marked with a rated voltage of “400 V”, “415 V” or “400/415 V” test —
	(i) at 0.8×400 V; and
	(ii) at 1.1×415 V.
(c)	If marked with voltages other than the above, then test —
	(i) at $0.8 \times$ the lowest marked voltage; and
	(ii) at $1.1 \times$ the highest marked voltage.