

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Amendment No. 1
to
AS/NZS 61241.14:2005
Electrical apparatus for use in the presence of combustible dust
Part 14: Selection and installation (IEC 61241-14, Ed. 1.0(2003) MOD)

CORRECTION

The 2005 edition of AS/NZS 61241.14 is amended as follows; the amendments should be inserted in the appropriate places.

SUMMARY: This Amendment applies to the Contents and Clause 6.6.

Published on 14 June 2005.

Approved for publication in New Zealand on behalf of the Standards Council of New Zealand on 20 May 2005.

Page iii Contents

Add **Clause 6.6 Selection of repaired or existing equipment.**

Page 20 Clause 6.5

Add the following new Clause:

6.6 Selection of repaired or existing equipment

When it is intended that existing equipment, or repaired equipment, is to be installed in a hazardous area that is deemed to be a new installation, the requirements of Clauses 6.1 to 6.5 apply, as appropriate. In addition, the procedure set out in Figure 2 shall be followed.

NOTE – The act of introducing other than like for like apparatus (i.e. identical characteristics and protection techniques) in an existing installation may cause that installation to be deemed 'new'.

AMDT
No. 1
JUNE
2005

AMDT
No. 1
JUNE
2005

This page has been left intentionally blank.