

Australian/New Zealand Standard™

**Electrical apparatus for use in the
presence of combustible dust**

**Part 2.1: Test methods—Methods for
determining the minimum ignition
temperatures of dust**

AS/NZS 61241.2.1:2000

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL/14, Electrical Equipment in Hazardous Areas. It was approved on behalf of the Council of Standards Australia on 3 December 1999 and on behalf of the Council of Standards New Zealand on 22 November 1999. It was published on 3 February 2000.

The following interests are represented on Committee EL/14:

Association of Consulting Engineers Australia
Auckland Regional Chamber of Commerce
Australian Association of Certification Bodies
Australian Chamber of Commerce and Industry
Australian Coal Association
Australian Electrical and Electronic Manufacturers Association
Australian Gas Association
Australian Industry Group
Australian Institute of Petroleum
Australian Institute of Refrigeration Air Conditioning and Heating
Department of Mineral Resources, N.S.W.
Department of Mines and Energy, Qld
Electricity Supply Association of Australia
Institute of Electrical Inspectors
Institute of Instrumentation and Control Australia
Institution of Engineers Australia
Ministry of Commerce New Zealand
National Electrical and Communications Association
New Zealand Association of Marine, Aviation and Power Engineers
New Zealand Employers and Manufacturers Association
New Zealand Hazardous Areas Electrical Coordinating Committee
Regulatory authorities (electrical)
WorkCover New South Wales

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Australia web site at www.standards.com.au or Standards New Zealand web site at www.standard.co.nz and looking up the relevant Standard in the on-line catalogue.

Alternatively, both organizations publish an annual printed Catalogue with full details of all current Standards. For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia International or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR 99145.

Australian/New Zealand Standard™

Electrical apparatus for use in the presence of combustible dust

Part 2.1: Test methods—Methods for determining the minimum ignition temperatures of dust

First published as AS/NZS 61241.2.1:2000.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia International Ltd, PO Box 1055, Strathfield, NSW 2135 and Standards New Zealand, Private Bag 2439, Wellington 6020

ISBN 0 7337 2950 9

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL/14, Electrical Equipment in Hazardous Areas.

This Standard is identical with and has been reproduced from, IEC 61241-2-1:1994, *Electrical apparatus for use in the presence of combustible dust*, Part 2: *Test methods*, Section 1: *Methods for determining the minimum ignition temperatures of dust*.

The objective of this Standard is to provide testing authorities and certifying bodies with test methods to determine the minimum ignition temperatures of dust layers and clouds, so as to allow the proper selection of adequate electrical apparatus to be used in areas where combustible dusts are or may be present.

In January 1997, the IEC commenced numbering its Standards from 60000 by adding 60000 to the number of each existing Standard. This coordinates IEC numbering with ISO numbering. During the transition period an IEC Standard might be identified by its new number or its old number (for example, IEC 60050 or IEC 50).

This Standard is part of a series covering electrical apparatus for use in the presence of combustible dust which comprises the following:

AS/NZS

- | | |
|-----------|---|
| 61241 | Electrical apparatus for use in the presence of combustible dust |
| 61241.1.1 | Part 1.1: Electrical apparatus protected by enclosures and surface temperature limitation—Specification for apparatus |
| 61241.1.2 | Part 1.2: Electrical apparatus protected by enclosures and surface temperature limitation—Selection, installation and maintenance |
| 61241.2.1 | Part 2.1: Test methods—Methods for determining the minimum ignition temperatures of dust (this Standard) |
| 61241.2.2 | Part 2.2: Test methods—Method for determining the electrical resistivity of dust in layers |
| 61241.2.3 | Part 2.3: Test methods—Method for determining minimum ignition energy of dust/air mixtures |
| 61241.3 | Part 3: Classification of areas where combustible dusts are or may be present. |

As this Standard is reproduced from an International Standard a full point should be substituted for a comma when referring to a decimal marker.

The term 'normative' has been used in this Standard to define the application of the annex to which it applies. A 'normative' annex is an integral part of a Standard.

CONTENTS

	<i>Page</i>
Introduction.....	iv
Clause	
1 Scope.....	1
2 Normative references	1
3 Definitions.....	2
4 Method A: Dust layer on a heated surface at a constant temperature	2
4.1 Preparation of dust sample.....	2
4.2 Test apparatus.....	2
4.3 Procedure.....	4
4.4 Test acceptance criteria.....	6
4.5 Reporting of results	6
4.6 Application of results	6
5 Method B: Dust cloud in a furnace at a constant temperature	7
5.1 Preparation of dust sample.....	7
5.2 Test apparatus.....	7
5.3 Procedure.....	7
5.4 Criterion of ignition	8
5.5 Minimum ignition temperature of a dust cloud.....	8
5.6 Reporting of results	8
Figures A.1 - A.5	10
Figures B.1 - B.10.....	16
Annexes	
A Method A - Construction of a heated surface and measurement of temperature distribution on the surface	9
B Construction of a constant temperature furnace	15

INTRODUCTION

This part of AS/NZS 61241 describes methods for determining the minimum ignition temperature of dust which are:

- method A: Dust layer on a heated surface at a constant temperature (clause 4);
- method B: Dust cloud in a furnace at a constant temperature (clause 5).

Method A determines the minimum ignition temperature of a dust layer on a prescribed heated surface.

Method B determines the minimum ignition temperature of a dust cloud within a prescribed heated furnace.

The test methods are of a general nature, and may be used for purposes of comparison, but in certain industrial situations further tests may be necessary.

The methods for determining the minimum ignition temperatures are not suitable for use with recognized explosives, for example, gunpowder, dynamite, or mixtures of substances which may, under some circumstances, behave similarly.

Where there is doubt, an indication of the existence of a hazard due to explosive properties may be obtained by testing a very small quantity of the dust on a surface at 400°C or higher, located remotely from the operator.

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard**Electrical apparatus for use in the presence of combustible dust**
Part 2.1: Test methods—Methods for determining
the minimum ignition temperatures of dust

1 Scope

This part of AS/NZS 61241 specifies two test methods for determining the minimum ignition temperatures of dust.

The methods are not suitable for use with substances having explosive properties.

Method A (clause 4) is applicable to the determination of the minimum temperature of a prescribed hot surface which will result in the decomposition and/or ignition of a layer of dust of a specified thickness deposited on it. The method is particularly relevant to industrial equipment with which dust is present on hot surfaces in thin layers exposed to the atmosphere.

Method B (clause 5) is applicable to the determination of the minimum temperature of a prescribed hot surface which will result in the ignition of a cloud of a given sample of dust or other particulate solid. The test is intended to be carried out as a complementary test after determining the minimum ignition temperature of a dust layer by method A of this standard.

NOTES concerning method B

- 1 Because the method of operation of the furnace gives short residence times for dust particles within it, this method of test is applicable to industrial equipment where dust is present as a cloud for a short time. This method of test is of small scale and the results are not necessarily representative of all industrial conditions.
- 2 The method is not applicable to dusts which may, over a longer period of time than provided for in the test method, produce from deposits gases generated during pyrolysis or smouldering.

2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of AS/NZS 61241. At the time of publication, the editions indicated were valid. All normative documents are subject to revision, and parties to agreements based on this part of AS/NZS 61241 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 565: 1990, Test sieves - Metal wire cloth, perforated metal plate and electroformed sheet
- Nominal sizes of opening

ISO 4225: 1980: Air quality - General aspects - Vocabulary

3 Definitions

For the purpose of this part of AS/NZS 61241, the following definitions apply:

3.1 dust: Small solid particles in the atmosphere which settle out under their own weight, but which may remain suspended in air for some time (includes dust and grit as defined in ISO 4225).

3.2 ignition of a dust layer: Ignition is considered to have occurred if glowing or flaming is initiated in the material, or a temperature of 450°C or more, or a temperature rise of 250 K or more above the temperature of the prescribed hot surface, is measured in the test.

3.3 minimum ignition temperature of a dust layer: Lowest temperature of a hot surface at which ignition occurs in a dust layer of specified thickness on this hot surface.

NOTES

- 1 Because of the wide range of processes in industry, the ignition of dust layers may be dependent upon local conditions. This method of test is not necessarily representative of all industrial conditions, where account may need to be taken of such factors as the presence of thick layers of dust and of the distribution of temperature in the environment.
- 2 When carrying out this test, it is essential that all necessary precautions be taken to safeguard the health of personnel, for example, against the risk of fire, explosion, inhalation of smoke and any toxic products of combustion.

3.4 ignition of a dust cloud: Initiation of an explosion by the transfer of energy to a dust cloud in air.

3.5 ignition temperature of a dust cloud: Lowest temperature of the hot inner wall of furnace at which ignition occurs in a dust cloud in air contained therein.

NOTE - When carrying out this test, it is essential that all necessary precautions be taken to safeguard the health of personnel, for example, against the risk of fire, explosion, inhalation of smoke and any toxic products of combustion.

4 Method A: Dust layer on a heated surface at a constant temperature

4.1 Preparation of dust sample

The sample shall be prepared so as to be homogeneous and representative of the dust received for consideration.

The dust sample to be tested shall, in general, be able to pass through a woven metal wire cloth or a square hole perforated plate test sieve with a nominal size of aperture of 200 µm (for supplementary sizes, see ISO 565). If it is necessary to test a coarser dust, passing a test sieve with a nominal size of aperture up to 500 µm, the fact shall be stated in the test report.

Any apparent changes noted in the properties of the dust during preparation of the sample, for example, by sieving or owing to temperature or humidity conditions, shall be stated in the test report.

4.2 Test apparatus

The apparatus is shown schematically in figure A.1. Essential details and performance requirements are given in the following subclauses. Methods of construction to enable these requirements to be met are described in annex A.

4.2.1 Heated surface

The heated surface shall consist of a circular metal plate and shall provide a working area of at least 200 mm in diameter and be not less than 20 mm in thickness. The plate shall be heated electrically and its temperature shall be controlled by a device for which the sensing element is a thermocouple mounted in the plate near the centre and with its junction within $1\text{ mm} \pm 0.5\text{ mm}$ of the upper surface and in good thermal contact with the plate.

A similar thermocouple shall be mounted near the control thermocouple in a similar manner, and shall be connected to a temperature recorder to record the temperature of the surface during a test. The heated surface and its control device shall satisfy the following performance requirements:

- the heated surface shall be capable of attaining a maximum temperature of 400°C without a dust layer in position;
- the temperature of the heated surface shall be constant to within $\pm 5\text{ K}$ throughout the period of a test;
- when the heated surface has reached a steady state, the temperature across the surface shall be uniform to within $\pm 5\text{ K}$ when measured across two diameters at right angles, by the procedure described in annex A. This requirement shall be satisfied at nominal surface temperatures of 200°C and 350°C ;
- the temperature control shall be such that the recorded surface temperature does not change by more than $\pm 5\text{ K}$ during the placing of the dust layer, and it shall be restored to within $\pm 2\text{ K}$ of the previous value within 5 min of placing the dust layer;
- temperature control and measurement devices shall be calibrated and shall have limits of inaccuracy of $\pm 3\text{ K}$.

4.2.2 Dust layer thermocouple

A fine thermocouple (0.20 mm to 0.25 mm diameter) of chromel-alumel or other suitable material shall be stretched across the heated surface, and parallel to it, at a height of between 2 mm and 3 mm from it with the junction over the centre of the plate. This thermocouple shall be connected to a temperature recorder in order to determine the behaviour of the dust layer during the test.

4.2.3 Temperature measurements

Temperature measurements using thermocouples shall be made either relative to a fixed reference junction or with automatic cold junction compensation. In either case, calibration shall satisfy the requirements of 4.2.1e).

4.2.4 Ambient temperature measurements

The ambient temperature shall be measured by a thermometer placed not more than 1 m from the heated surface, but shielded from heat convection and radiation from the surface. The ambient temperature shall be within the range 15°C to 35°C .

4.2.5 Dust layers

Dust layers shall be prepared by filling the cavity formed by placing a metal ring of appropriate height on the heated surface and levelling the layer to the top of the ring. The ring shall have an internal diameter of nominally 100 mm and shall have slots at opposite ends of a diameter to clear the test thermocouple (figure A.2). The ring shall be left in place during a test.

A given dust shall be tested in a layer of $5.0\text{ mm} \pm 0.1\text{ mm}$ depth. For predictive purposes (see 4.6) a second depth (such as $12.5\text{ mm} \pm 0.1\text{ mm}$ or $15.0\text{ mm} \pm 1\text{ mm}$) is useful. Rings of appropriate depths will be required.

4.2.6 Formation of dust layer

The dust layer shall be formed without compressing it unduly. That is to say, the dust shall be put into the ring with a spatula and distributed mainly with sideways movement of the spatula until the ring is slightly overfilled. The layer shall then be levelled by drawing a straight edge across the top of the ring. Any excess should be swept away.

For each type of dust, a layer shall be formed in the above manner on a sheet of paper whose weight is known and weighed. The density shall be calculated from the mass of the dust and the filled volume of the ring, and shall be reported.

4.3 Procedure

4.3.1 General

Ignition in particulate or porous solids exposed to elevated temperatures is generally preceded by a more or less protracted period of self-heating (usually due to atmospheric oxidation). Depending on the temperature of exposure, self-heating may result in no more than a transient, though sometimes substantial, rise in temperature within the solid which does not lead to propagation of combustion. Further, the 'induction period' for ignition, at temperatures near to the minimum required for ignition is usually many times greater than for ignition in dust clouds or in gases and vapours (minutes or hours rather than seconds). For both reasons the recognition of the minimum ignition temperature of dust layers is less straightforward than for dust clouds or for gases and vapours. It is necessary especially to be certain that failure to ignite at a given temperature is not merely because a test was terminated prematurely.

The occurrence of ignition in a layer of dust on a surface at a given temperature depends critically on the balance between the rate of heat generation ('self-heating') in the layer and the rate of heat loss to the surroundings. The temperature at which ignition of a given material occurs depends, therefore, on the thickness of the layer. Values determined for two or more thicknesses of a given dust may be used for predictive purposes (see 4.6).

Following the recommended procedure, ignition shall be considered to have occurred if:

- a) visible glowing or flaming is observed (figure A.3(a)), or
- b) a temperature of 450°C, is measured or
- c) a temperature rise of 250 K above the temperature of the heated plate (figure A.3(c)), is measured.

With regard to items b and c above, ignition shall not be considered to have occurred if it can be shown that the reaction does not propagate to glowing or flaming. The temperature shall be measured by thermocouple (see 4.2.2) It will usually be found that, provided the temperature of the heated surface is high enough, the temperature in the layer will slowly increase to a maximum value which may be in excess of the temperature of the heated surface and then slowly fall to a steady value below the temperature of the heated surface (figure A.3(b)). This behaviour is evidence of self-heating in the dust layer and it may often be accompanied by a discoloration of the dust but without active and visible combustion of the layer. If the temperature of the heated surface is slightly higher, the temperature measured in the dust layer will continue to rise instead of passing through a maximum. Some materials exhibit more than one stage of self-heating, and it may sometimes be necessary to prolong the test in order to fully explore this possibility. With organic dust, combustion will usually take the form of charring followed by the appearance of smouldering with glowing which will progress through the layer and leave a residue of ash. With dust layers composed of certain divided metals, ignition may be characterized by the relatively sudden appearance of highly incandescent smouldering combustion progressing rapidly through the layer.