

Boxes and enclosures for electrical accessories for household and similar fixed electrical installations

Part 22: Particular requirements for connecting boxes and enclosures

Amendment No. 1

International adoption identical

Publishing and Approval Dates

Council of Standards Australia Approval: 12 October 2021

New Zealand Standards Approval Board Approval: 6 October 2021

Published: 22 October 2021

Summary

This Amendment applies to the following elements:

- Front cover
- Preface
- Amendment 1

Amendment Details

AS/NZS IEC 60670.22:2012 is amended as follows. The amendment should be inserted in the locations as instructed.

Element	Instruction/New text
Front cover	Top right corner, after "IEC 60670-22, Ed.1.0 (2003)" <i>add</i> the following: IEC 60670-22:2003/AMD1:2015 (Incorporating Amendment No. 1)
Preface	After the first paragraph, <i>add</i> the following: Amendment No. 1 to this Standard was prepared by the Joint Standards Australia/ Standards New Zealand Committee EL-004. <i>Delete</i> the fourth paragraph, and <i>replace</i> with the following: This Standard is identical with, and has been reproduced from, IEC 60670-22, Ed.1.0 (2003), <i>Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 22: Particular requirements for connecting boxes and enclosures</i> and its Amendment No. 1 (2016) which has been added at the end of the source text.
Amd 1 (new)	After Annex BB Figure BB.1, <i>add</i> the following Amendment No. 1 (2021):

FOREWORD

This amendment has been prepared by subcommittee 23B: Plugs, socket-outlets and switches, of IEC technical committee 23: Electrical accessories.

The text of this amendment is based on the following documents:

FDIS	Report on voting
23B/1174/FDIS	23B/1182/RVD

Full information on the voting for the approval of this amendment can be found in the report on voting indicated in the above table.

Annex AA and Annex BB are for information only.

The committee has decided that the contents of this amendment and the base publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

3 Definitions

3.102

connecting box with integral clamping units

Replace the term and definition of 3.102 by the following:

connecting box with integrated clamping units

connecting box in which clamping units are permanently retained as an integrated part of the box (see Annex AA)

3.107

terminal

Replace the definition of 3.107 by the following:

conductive part of one pole comprising one or more clamping unit(s) and insulation if necessary