Boxes and enclosures for electrical accessories for household and similar fixed electrical installations

Part 23: Particular requirements for floor boxes and enclosures

Amendment No. 1

International adoption identical

Publishing and Approval Dates

Council of Standards Australia Approval: 12 October 2021

New Zealand Standards Approval Board Approval: 6 October 2021

Published: 22 October 2021

Summary

This Amendment applies to the following elements:

- Front cover
- Preface
- Amendment 1

Amendment Details

AS/NZS IEC 60670.23:2012 is amended as follows. The amendment should be inserted in the locations as instructed.

Element	Instruction/New text
Front cover	Top right corner, after "IEC 60670-23, Ed.1.0 (2006)" *add* the following: IEC 60670-23:2006/AMD1:2016 (Incorporating Amendment No. 1)
Preface	After the first paragraph, *add* the following: Amendment No. 1 to this Standard was prepared by the Joint Standards Australia/ New Zealand Committee EL-004. *Delete* the fourth paragraph, and *replace* with the following: This Standard is identical with, and has been reproduced from, IEC 60670-23, Ed.1.0 (2006), *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 23: Particular requirements for floor boxes and enclosures* and its Amendment No. 1 (2016) which has been added at the end of the source text.
Amd 1 (new)	After Clause 21 Figure 101, *add* the following Amendment No. 1 (2021):

© Standards Australia Ltd/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2021

ISBN 978 1 76113 545 3

Full document details: AS NZS IEC 60670.23-2012 amd1-2021

FOREWORD

This amendment has been prepared by subcommittee 23B: Plugs, socket-outlets and switches, of IEC technical committee 23: Electrical accessories.

The text of this amendment is based on the following documents:

FDIS	Report on voting
23B/1199/FDIS	23B/1204/RVD

Full information on the voting for the approval of this amendment can be found in the report on voting indicated in the above table.

The committee has decided that the contents of this amendment and the base publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

FOREWORD

Delete the date "(2002)*" from the reference to IEC 60670-1.*

1 Scope

Delete, in the third paragraph the following existing phrase:

intended to be installed in any kind of floor, and to protect accessories against load up to and including 1 000 N.

Add, after the third paragraph the following new phrase:

Flush floor boxes and flush floor enclosures are intended to protect accessories against a load up to and including 1 000 N.

7 Classification

Replace the existing text by the following new text:

This clause of Part 1 is applicable except as follows:

7.8 This subclause is not applicable.

AVA Documents
Document Sharing Hub

Full document details: AS NZS IEC 60670.23-2012 amd1-2021