

ASABE S565 OCT2005 (R2015)
Agricultural Ventilation Constant Speed Fan Test Standard



**American Society of
Agricultural and Biological Engineers**

**S
T
A
N
D
A
R
D**

ASABE is a professional and technical organization, of members worldwide, who are dedicated to advancement of engineering applicable to agricultural, food, and biological systems. ASABE Standards are consensus documents developed and adopted by the American Society of Agricultural and Biological Engineers to meet standardization needs within the scope of the Society; principally agricultural field equipment, farmstead equipment, structures, soil and water resource management, turf and landscape equipment, forest engineering, food and process engineering, electric power applications, plant and animal environment, and waste management.

NOTE: ASABE Standards, Engineering Practices, and Data are informational and advisory only. Their use by anyone engaged in industry or trade is entirely voluntary. The ASABE assumes no responsibility for results attributable to the application of ASABE Standards, Engineering Practices, and Data. Conformity does not ensure compliance with applicable ordinances, laws and regulations. Prospective users are responsible for protecting themselves against liability for infringement of patents.

ASABE Standards, Engineering Practices, and Data initially approved prior to the society name change in July of 2005 are designated as "ASAE", regardless of the revision approval date. Newly developed Standards, Engineering Practices and Data approved after July of 2005 are designated as "ASABE".

Standards designated as "ANSI" are American National Standards as are all ISO adoptions published by ASABE. Adoption as an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by ASABE.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

CAUTION NOTICE: ASABE and ANSI standards may be revised or withdrawn at any time. Additionally, procedures of ASABE require that action be taken periodically to reaffirm, revise, or withdraw each standard.

Copyright American Society of Agricultural and Biological Engineers. All rights reserved.

ASABE, 2950 Niles Road, St. Joseph, MI 49085-9659, USA, phone 269-429-0300, fax 269-429-3852, hq@asabe.org

Agricultural Ventilation Constant Speed Fan Test Standard

Proposed by the ASABE Electrical Utilization & Energy Applications Committee and developed by the ASABE Fan Testing Subcommittee. Adopted by ASABE October 2005; reaffirmed January 2011, reaffirmed October 2015.

Keywords: Energy efficient, Fan test, Ventilation

1 Purpose and scope

- 1.1 This standard covers the testing procedure and performance presentation of wall mounted greenhouse, poultry and livestock ventilation fans, including manure storage pit fans.
- 1.2 This standard applies to constant speed, un-ducted wall mounted fans used for air exchange purposes.
- 1.3 Air circulating fans are not covered by this standard.
- 1.4 Airflow rate (m^3/hr , cfm) and the Ventilation Efficiency Rating ($\text{m}^3/\text{hr}/\text{W}$, cfm/W) are the two main performance parameters.
- 1.5 This standard is a complimentary standard to ANSI/AMCA 210-99 ANSI/ASHRAE 51-1999 but focused on constant speed agricultural ventilation fans.

2 Normative references

- 2.1 At the time of publication the standards referenced were up to date and valid. All standards are subject to revision, and parties to agreements based on this Standard are encouraged to investigate the possibility of applying the most recent editions of the standards listed below.
 - 2.1.1 ANSI/ASHRAE 51-1999 (ANSI/AMCA 210-99) *Laboratory Methods of Testing Fans for Aerodynamic Performance Rating*
 - 2.1.2 ANSI/ASAE S493.1 JUL03, *Guarding For Agricultural Equipment*
 - 2.1.3 ASAE EP566, *Guidelines for Selection of Energy Efficiency Agricultural Ventilation Fans*

3 Definitions

- 3.1 **Agricultural ventilation fan:** An axial flow fan system consisting of a propeller, housing, electric motor, shutter or back-draft damper, guard and all other components regularly supplied. These un-ducted fans are used for air exchange purposes.
- 3.2 **Air density:** The mass per unit volume of air (kg/m^3 or lb/ft^3).
- 3.3 **Airflow:** The volume of air moved by the fan (m^3/hr or cfm).

