

Standard Specification for Drain, Waste, and Vent (DWV) Plastic Fittings Patterns¹

This standard is issued under the fixed designation D3311; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This specification provides standard fitting geometries and laying lengths for plastic fittings intended for use in drain, waste, and vent applications. (See Specifications [D2661](#) and [D2665](#).)

1.2 Fittings meeting the requirements of this standard specification are designed for use with outside diameter controlled pipe. The inside diameter can vary significantly as the wall thickness and outside diameter varies and therefore is not suitable for use as a fitting socket.

1.3 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

2. Referenced Documents

2.1 ASTM Standards:²

[D2661](#) Specification for Acrylonitrile-Butadiene-Styrene (ABS) Schedule 40 Plastic Drain, Waste, and Vent Pipe and Fittings

¹ This specification is under the jurisdiction of ASTM Committee [F17](#) on Plastic Piping Systems and is the direct responsibility of Subcommittee [F17.63](#) on DWV. Current edition approved Aug. 1, 2011. Published August 2011. Originally approved in 1974. Last previous edition approved in 2009 as D3311 – 09a. DOI: 10.1520/D3311-11.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

[D2665](#) Specification for Poly(Vinyl Chloride) (PVC) Plastic Drain, Waste, and Vent Pipe and Fittings

[F1498](#) Specification for Taper Pipe Threads 60° for Thermoplastic Pipe and Fittings

3. Requirements

3.1 Fittings shall conform to the geometries and laying lengths as shown in [Tables 1-45](#) and [Figs. 1-5](#). Tolerances shall be $\pm 1/16$ in. unless otherwise specified.

3.2 Spigot and hub dimensions shall conform to the requirements of the referencing standard.

3.3 The exact outside shape of a fitting is not determined by the outline drawings shown in this specification but rather by the socket dimensions, wall thickness requirements, waterway, laying lengths, and any other critical dimensions that may be specified.

3.4 The pitch of sockets for patterns with 90° angles (except vent fittings) shall be $1/4$ in./ft or $1^\circ 12$ min.


3.5 On double reducing sanitary tees, the *G2* dimension on branches will be calculated on the larger size and centerlines shall remain the same for both branches.

3.6 All other dimensions, materials and property requirements shall be in conformance with the referencing standard.

4. Keywords

4.1 DWV; fittings; plastic; Schedule 40; thermoplastic


TABLE 1 Bends, in. (mm)



Nominal Pipe Size	1/4 Bend	Long Sweep 1/4 Bend	1/8 Bend	1/6 Bend	1/16 Bend
	G	G	G	G	G
1 1/4	1 9/16 (40)	2 1/4 (57)	1 (25)	7/8 (22)	7/16 (11)
1 1/2	1 3/4 (44)	2 3/4 (70)	1 1/8 (29)	1 (25)	1/2 (13)
2	2 5/16 (59)	3 1/4 (83)	1 1/2 (38)	1 5/16 (33)	11/16 (17)
3	3 1/16 (78)	4 1/16 (103)	1 3/4 (44)	1 11/16 (43)	13/16 (21)
4	3 7/8 (98)	4 15/16 (125)	2 3/16 (56)	2 1/16 (52)	1 (25)
6	5 (min) (127)	9 (229)	2 (min) (51)	3 3/8 (86)	1 1/2 (38)
8	6 (152)	...	2 1/16 (52)	...	1 1/2 (38)
10	9 1/4 (235) ^A	...	2 5/8 (67) ^A	...	2 3/16 (56) ^A
12	10 1/16 ^A	...	3 1/8 (79) ^A	...	2 3/8 (60) ^A


^A10 in. and 12 in. fittings dimensions are minimum

TABLE 2 Bends with Inlets, in. (mm)



Nominal Pipe Size	1/4 Bend with Low Heel Inlet		Long-Sweep 1/4 Bend with Low Heel Inlet		Long-Sweep 1/4 Bend with High Heel Inlet		
	G	N	G	N	G	N	GG
3 by 3 by 1 1/2	3 1/16 (78)	4 3/16 (106)	4 1/16 (103)	4 3/4 (121)	...	...	...
3 by 3 by 2	3 1/16 (78)	4 7/16 (113)	4 1/16 (103)	4 15/16 (125)	4 1/16 (103)	5 5/8 (143)	2 1/4 (57)
4 by 4 by 2	3 7/8 (98)	5 7/16 (138)	4 15/16 (125)	6 (152)	...	...	...

TABLE 3 Sanitary Tees, 45° Wyes, Combination Wyes and 1/8 Bends, in. (mm)




Nominal Pipe Size	Sanitary Tee Single and Double ^A		45° Wye, Single and Double		Combination Wye and 1/8 Bend Single and Double	
	GN	GJ	GN	GJ	GN	GJ
1 1/4	3/4 (19)	1 9/16 (40)	1 1/16 (27)	2 9/16 (65)	7/16 (11)	2 15/16 (75)
1 1/2	1 (25)	1 3/4 (44)	1 1/8 (29)	2 7/8 (73)	1/2 (13)	3 3/8 (86)
2	1 3/8 (35)	2 5/16 (59)	1 3/8 (35)	3 5/8 (92)	1 (25)	4 1/2 (114)
3	1 13/16 (46)	3 1/16 (78)	1 5/8 (41)	5 (127)	1 1/8 (29)	6 5/16 (160)
4	2 1/4 (57)	3 7/8 (98)	1 7/8 (48)	6 3/8 (162)	1 13/16 (46)	8 5/8 (219)
6	3 1/2 (89)	5 (127)	1 3/4 (44)	8 7/16 (214)	^B	^B
8	4 1/2 (114)	6 (152)	2 3/8 (60)	11 3/4 (298)	^B	^B
10	5 1/2 (140) ^C	9 1/16 (246) ^C	2 7/16 (62) ^C	13 (330) ^C	^B	^B
12	6 9/16 (167) ^C	11 (279) ^C	2 7/8 (73) ^C	15 3/8 (391) ^C	^B	^B

^ANon-reducing double sanitary tees are for vent use only.

^BCombination wye and 1/8 bend is assembled from two standard fittings.

^C10 in. and 12 in. fittings dimensions are minimum.

TABLE 4 Reducing Sanitary Tees, 45° Wyes, Combination Wyes, and 1/8 Bends, in. (mm)




Nominal Pipe Size	Sanitary Tee, Reducing Single and Double ^A				45° Wye, Reducing Single and Double			Combination Wye and 1/8 Bend Reducing Single and Double		
	G1	G2	G3	G4	G1	G2	G3	G1	G2	G3
1½ by 1¼ by 1¼	1½ (17) ^B	1½ (38) ^B	1½ (43) ^B	1½ (43) ^B	—	—	—	—	—	—
1½ by 1¼ by 1½	1 (25)	¾ (44)	¾ (44)	¾ (44)	—	—	—	—	—	—
1½ by 1½ by 1¼	1½ (21)	1½ (43)	1½ (46)	1½ (46)	—	—	—	½ (13)	¾ (83)	¾ (81)
2 by 1¼ by 1½	1½ (30)	1½ (49)	2½ (56)	2½ (56)	—	—	—	—	—	—
2 by 1½ by 1½	1½ (30)	1½ (49)	2½ (56)	2½ (56)	¾ (19) ^B	2½ (71) ^B	2½ (75) ^B	¾ (14)	3½ (94)	¾ (92)
2 by 1½ by 2	1½ (35)	2½ (59)	2½ (59)	2½ (59)	1 (25) ^B	3½ (89) ^B	3½ (86) ^B	1 (25)	4½ (114)	4½ (114)
2 by 2 by 1¼	1½ (30)	1½ (49)	2½ (56)	2½ (56)	—	—	—	—	—	—
2 by 2 by 1½	1½ (30)	1½ (49)	2½ (56)	2½ (56)	1½ (27)	3½ (84)	3½ (87)	¾ (14)	3½ (170)	¾ (92)
3 by 3 by 1½	1½ (24)	¾ (44)	2½ (65)	2½ (65)	½ (13)	3½ (95)	4½ (110)	¾ (3)	3½ (87)	4¼ (108)
3 by 3 by 2	1½ (30)	2½ (54)	2½ (73)	2½ (73)	¾ (22)	4½ (105)	4½ (117)	¾ (11)	4¼ (121)	5½ (135)
3 by 3 by 2 by 1½	1½ (24) ^B	2½ (52) ^B	2½ (62) ^B	2½ (64) ^B	—	—	—	—	—	—
4 by 4 by 1½	1½ (27) ^B	2 (51) ^B	¾ (83) ^B	¾ (83) ^B	0 (0) ^B	3½ (84) ^B	3½ (100) ^B	—	—	—
4 by 4 by 2	1½ (29)	2½ (52)	3½ (84)	3½ (84)	¾ (10)	4½ (119)	5½ (141)	5½ (8)	4¼ (121)	5½ (149)
4 by 4 by 3	1¾ (44)	3 (76)	3½ (90)	3½ (90)	1½ (27)	5½ (141)	6 (152)	1½ (27)	6½ (162)	6½ (175)
6 by 6 by 3	—	—	—	—	¾ (5) ^B	6½ (176) ^B	7½ (189) ^B	1½ (17) ^B	7½ (198) ^B	8½ (224) ^B
6 by 6 by 4	2½ (56) ^B	3½ (92) ^B	4½ (110) ^B	4½ (110) ^B	¾ (5) ^B	6½ (170) ^B	7½ (189) ^B	¾ (14) ^B	7½ (198) ^B	8½ (227) ^B
8 by 8 by 4	2½ (67)	4½ (105)	5¼ (133)	5¼ (133)	¾ (10)	7½ (194)	8½ (219)	C	C	C
8 by 8 by 6	3½ (90)	4½ (122)	5½ (140)	5½ (140)	1 (25)	9½ (241)	9½ (249)	C	C	C
10 by 10 by 4	...	...	...	...	-1½ (-38) ^B	8½ (221) ^B	10½ (264) ^B	C	C	C
10 by 10 by 6	...	...	...	...	0	10½ (257) ^B	11¼ (286) ^B	C	C	C
10 by 10 by 8	...	...	...	...	1¼ (32) ^B	11½ (202) ^B	12½ (316) ^B	C	C	C
12 by 12 by 4	...	...	...	...	-2½ (-62) ^B	9¾ (248) ^B	11½ (284) ^B	C	C	C
12 by 12 by 6	...	...	...	...	-¾ (-19) ^B	11½ (284) ^B	11½ (297) ^B	C	C	C
12 by 12 by 8	...	...	...	...	½ (13) ^B	12½ (319) ^B	13½ (352) ^B	C	C	C
12 by 12 by 10	...	...	...	...	1½ (29) ^B	14 (356) ^B	14½ (379) ^B	C	C	C

^ANon-reducing double sanitary tees are for vent use only.

^BThis dimension is a minimum with no upper maximum limit.


^CCombination Wye and 1/8 bend is assembled from two standard fittings.

TABLE 5 60° Wyes, Single, and Double, in. (mm)




Nominal Pipe Size	GN	GJ
1½	1½ (40)	2½ (73)
2	1½ (37)	3½ (92)
3	1½ (37)	5 (127)

TABLE 6 Fixture Tees, in. (mm)



Nominal Pipe Size	G1	G2	G3
1½	1½ (40)	1½ (30)	1¼ (32)
2 by 1½ by 1½	1½ (37)	1½ (30)	1¼ (32)
2 by 2 by 1½	1½ (37)	1½ (33)	1¼ (32)


TABLE 7 Cleanout Tees, in. (mm)



Nominal Pipe Size	G	I
1½	1⅞ (30)	⅝ (16)
2	1½ (38)	⅝ (16)
3	1⅞ (48)	¾ (19)
4	2½ (64)	⅞ (22)
6	3½ (89) ^A	1⅝ (33) ^A
8	4⅞ (102) ^A	1½ (38) ^A


^A6 in. and 8 in. fittings dimensions are minimum.

TABLE 8 Reducing Cleanout Tees, in. (mm)




Nominal Pipe Size	GN, min	GJ, min	I, min
10 by 10 by 8	5⅞ (132)	5½ (140)	1¾ (44)
12 by 12 by 8	6 (152)	5½	1⅞ (43)

TABLE 9 60° Reducing Wyes, Single and Double, in. (mm)




Nominal Pipe Size	G1	G2	G3
2 by 2 by 1½	1⅞ (27)	3⅞ (87)	3⅞ (87)
3 by 3 by 1½	½ (13)	3¾ (95)	4⅞ (110)
3 by 3 by 2	⅞ (22)	4⅞ (105)	4⅞ (117)

TABLE 10 Molded Nipples, in. (mm)



Nominal Pipe Size	OD	ID	Length
1½	1.900	1.500	½-in. increments from
2	2.375	1.939	close to 18 in. long
3	3.500	2.900	


TABLE 11 Vent Tees and ¼ Bend Vents, in. (mm)



Nominal Pipe Size	Vent Tee	¼ Bend Vent
1¼	1 (25)	1 (25)
1½	1⅞ (30)	1⅞ (30)
2	1½ (38)	1½ (38)
3	1⅞ (48)	1⅞ (48)
4	2½ (64)	2½ (64)
6	3½ (89) ^A	3½ (89) ^A
8	4½ (114) ^A	4½ (89) ^A
10	5⅞ (148) ^A	5⅞ (148) ^A
12	6⅞ (175) ^A	6⅞ (175) ^A


^A6 in., 8 in., 10 in., and 12 in. fitting dimensions are minimum.

TABLE 12 Reducing Vent Tees, Single, and Double, in. (mm)




Nominal Pipe Size	GN, min	GJ, min
2 by 1½ by 1½	1⅜ (30)	1½ (38)
2 by 2 by 1½	1⅜ (30)	1½ (38)
3 by 3 by 1½	1⅜ (30)	1⅞ (48)
3 by 3 by 2	1½ (38)	1⅞ (48)
6 by 6 by 4	2½ (64)	3⅞ (87)
8 by 8 by 4	2½ (64)	4½ (114)
8 by 8 by 6	3⅝ (92)	4½ (114)
10 by 10 by 4	3⅝ (84)	5⅞ (149)
10 by 10 by 6	3⅝ (100)	5⅞ (149)
10 by 10 by 8	3½ (89)	5⅞ (140)
12 by 12 by 4	3½ (89)	6⅝ (176)
12 by 12 by 6	4½ (114)	6⅝ (176)
12 by 12 by 8	4⅞ (124)	6⅝ (176)
12 by 12 by 10	6½ (165)	7½ (190)

TABLE 13 Pipe Increases, in. (mm)




Nominal Pipe Size	N, min
1¼ by 1½	1⅜ (10)
1½ by 2	1⅞ (13)
1½ by 3	1⅞ (28)
2 by 3	⅞ (22)
2 by 4	1⅞ (35)
3 by 4	1⅝ (24)
3 by 6	1⅝ (49)
4 by 6	1⅞ (30)
4 by 8	1⅝ (41)
4 by 10	2⅞ (56)
6 by 8	¾ (19)
6 by 10	1⅞ (40)
6 by 12	2⅞ (60)
8 by 10	1⅝ (33)
8 by 12	1⅞ (46)
10 by 12	1¼ (32)

TABLE 14 Trap Adapters, in. (mm)




Without stop		With Stop
Nominal Pipe Size	N, min	A, min
1¼	¾ (5)	1.250 (32)
1½	¾ (5)	1.500 (38)
2	¾ (5)	2.000 (51)
1¼ by 1½	¾ (5)	1.250 (32)

TABLE 15 Hubs, in. (mm)




Nominal Pipe Size	A	C	N	AJ	CJ	N
2	...	...	...	2.94 (74.7)	2⅜ (60)	⅜ (10)
3	3.448 (87.58)	1⅜ (43)	⅝ (8)	3.94 (100.1)	2⅝ (67)	⅞ (11)
4	4.493 (114.12)	1⅝ (49)	11/32 (9)	4.94 (125.5)	2⅞ (73)	1½ (13)
Reducing 4 by 3	4.493 (114.12)	1⅝ (49)	⅝ (8)	4.94 (125.5)	2⅞ (73)	⅞ (11)

TABLE 16 Spigots, in. (mm)




Nominal Pipe Size	$L2$, min	$L1$, min	$L3$, min	M		AN
				max	min	
2	3½ (89)	4½ (117)	¾ (10)	2.75 (69.9)	2.63 (66.8)	2.00 (50.8)
3	3¾ (95)	5½ (143)	¾ (10)	3.88 (98.6)	3.63 (92.2)	3.00 (76.2)
4	4 (102)	6½ (156)	¾ (10)	4.88 (124.0)	4.63 (117.6)	4.00 (101.6)

TABLE 17 Reducing Spigots, in. (mm)




Nominal Pipe Size	$L2$ min	$L1$ min	$L3$ min	M		AJ
				max	min	
2 by 1½	3½ (89)	4¼ (108)	¾ (10)	2.75 (69.9)	2.63 (66.8)	2.00 (50.8)
3 by 1½	3¾ (95)	4½ (114)	¾ (10)	3.88 (98.6)	3.63 (92.2)	3.00 (76.2)
3 by 2	3¾ (95)	4½ (117)	¾ (10)	3.88 (98.6)	3.63 (92.2)	3.00 (76.2)
4 by 2	4 (102)	4¾ (124)	¾ (10)	4.88 (124.0)	4.63 (117.6)	4.00 (101.6)
4 by 3	4 (102)	5½ (140)	¾ (10)	4.88 (124.0)	4.63 (117.6)	4.00 (101.6)

TABLE 18 P Traps, in. (mm)



Nominal Pipe Size	min GJ	min GGJ	min GGN	min GN	min R
1/4	4 1/8 (105)	3 5/8 (86)	3 (76)	1 3/8 (35)	1 5/8 (41)
1/2	4 7/32 (107)	3 5/8 (92)	3 (76)	1 3/8 (35)	1 5/8 (41)
2	7 1/4 (184)	4 1/16 (103)	5 (127)	2 1/4 (57)	2 1/2 (64)
3	8 7/16 (214)	6 5/16 (160)	6 1/4 (159)	2 5/8 (67)	3 1/8 (79)
4	10 13/16 (275)	7 7/8 (200)	8 1/16 (205)	3 7/16 (87)	4 1/16 (103)
6	17 3/4 (451)	12 3/4 (324)	11 3/4 (298)	4 3/4 (121)	6 3/8 (162)

TABLE 19 Double Fixture Fitting, in. (mm)



Nominal Pipe Size	G1	G2	G3	G4
1 1/2	5/8 (10)	3 9/16 (90)	2 7/16 (62)	2 7/16 (62)
2	5/8 (10)	4 9/16 (116)	3 1/16 (78)	3 1/16 (78)
3	1/2 (13)	6 3/4 (171)	4 1/2 (114)	4 1/2 (114)
Reducing:				
2 by 1 1/2 by 1 1/2 by 1 1/2	5/8 (10)	3 9/16 (90)	2 7/16 (62)	2 7/16 (62)
2 by 1 1/2 by 2 by 2	5/8 (10)	4 9/16 (116)	3 1/16 (78)	3 1/16 (78)
2 by 1 1/2 by 2 by 1 1/2	5/8 (10)	4 9/16 (116)	3 1/16 (78)	3 1/16 (78)