



**American Water Works
Association**

The Authoritative Resource on Safe Water®

ANSI/AWWA B300-10
(Revision of ANSI/AWWA B300-04)

AWWA Standard

Hypochlorites



Effective date: April 1, 2010.

First edition approved by AWWA Board of Directors June 2, 1953.

This edition approved Jan. 17, 2010.

Approved by American National Standards Institute Jan. 14, 2010.

6666 West Quincy Avenue
Denver, CO 80235-3098
T 800.926.7337
www.awwa.org

Advocacy
Communications
Conferences
Education and Training
Science and Technology
Sections



Documents
Document Sharing Hub

Copyright © 2010 American Water Works Association. All Rights Reserved.

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing info@ansi.org.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2010 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Disinfectants, which reviewed and approved this standard, had the following personnel at the time of approval:

Clifford L. McLain, *Chair*

General Interest Members

D.J. Gates, Citrus Heights, Calif.	(AWWA)
G. Giasson, Pawtucket Water Supply Board, Pawtucket, R.I.	(AWWA)
S.J. Posavec,* Standards Group Liaison, AWWA, Denver, Colo.	(AWWA)
K.B. Stark, NSF International, Ann Arbor, Mich.	(NSF)
D.R. Wilkes,* Standards Council Liaison, Jordan Jones & Goulding Inc., Norcross, Ga.	(AWWA)

Producer Members

W.B. Huebner, Mine Hill, N.J.	(AWWA)
J. Sloan, American Chemistry Council, Arlington, Va.	(AWWA)

User Members

I. Alvarez,† John Preston Water Plant, Hialeah, Fla.	(AWWA)
R.C. Lorenz, Westerville Water Plant, Westerville, Ohio	(AWWA)
C.L. McLain, Moorhead Public Service, Moorhead, Minn.	(AWWA)
A. Segars, Miami–Dade Water & Sewer Department, Hialeah, Fla.	(AWWA)

* Liaison, nonvoting

† Alternate

This page intentionally blank.



Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
<i>Foreword</i>		1.3	Application..... 1
I	Introduction..... vii	2	References 1
I.A	Background..... vii	3	Definitions 2
I.B	History..... viii	4	Requirements
I.C	Acceptance viii	4.1	Materials 3
II	Special Issues..... x	4.2	Physical Requirements..... 3
II.A	Storage and Handling	4.3	Chemical Requirements 4
	Precautions..... x	4.4	Impurities..... 4
II.B	Strength of Solutions..... x	5	Verification
II.C.	Sodium Hypochlorite..... xi	5.1	Sampling..... 5
II.D	Bromate in Sodium	5.2	Test Procedures 6
	Hypochlorite xii	5.3	Notice of Nonconformance..... 8
III	Use of This Standard xii	6	Delivery
III.A	Purchaser Options and	6.1	Marking..... 8
	Alternatives xii	6.2	Packaging and Shipping 9
III.B	Modification to Standard xiii	6.3	Affidavit of Compliance 10
IV	Major Revisions..... xiii		
V	Comments xiii		
<i>Standard</i>		<i>Table</i>	
1	General	F.1	Chlorine Available in Sodium
1.1	Scope 1		Hypochlorite viii
1.2	Purpose 1		

This page intentionally blank.



Foreword

This foreword is for information only and is not part of ANSI/AWWA B300-10.

I. Introduction.

I.A. *Background.* *Hypochlorites* is used as an all-inclusive term for chlorinated lime, calcium hypochlorite, and sodium hypochlorite. A concise description of each chemical follows.

Chlorinated lime: 25 percent to 37 percent available chlorine. Other common names for chlorinated lime are bleaching powder and chloride of lime. Because it is an unstable material and is subject to deterioration from heat and moisture, it is not usually fed dry but as a 2 percent solution. Excess insolubles present in this solution must be separated by decantation before use. Storage in a cool, dry area, for no more than nine months, is advisable. Chlorinated lime is available in 100-lb (45.4-kg), 300-lb (136-kg), and 800-lb (363-kg) drums. Approximately 0.25 lb/gal (30 g/L) of water will produce a solution of approximately 1 percent available chlorine.

Calcium hypochlorite: 65 percent to 70 percent available chlorine. This material is unstable but more stable than the grade with 35 percent available chlorine. It is best fed as a solution. Its theoretical solubility is approximately 22 g/100 mL of water (18 percent) at room temperature; however, its practical solubility use is closer to 3 percent. Decantation is advisable before use because of the excess insolubles present. Storage in a cool, dry area is advisable, but storage periods should not exceed one year. Calcium hypochlorite can lose 3 percent to 10 percent available chlorine in one year. It is available in 3-lb to 5-lb (1.4-kg to 2.3-kg) cans, 2-lb to 9-lb (0.9-kg to 4.1-kg) plastic containers, and 100-lb (45.4-kg) steel drums and in granular powder, granule, and tablet form. Solubility tests that determine both rate and percentage should be conducted with particular emphasis on testing the tablets. Approximately $\frac{1}{8}$ lb/gal (15 g/L) of calcium hypochlorite to water produces a solution of approximately 1 percent available chlorine.

Sodium hypochlorite: 12 percent to 20 percent available chlorine. Other common names for sodium hypochlorite are bleach, liquor, chlorine water, and Javelle water. Sodium hypochlorite will undergo some decomposition over time. There are numerous parameters that affect the rate of decomposition (see The Chlorine Institute* Pamphlet 96, *Sodium Hypochlorite Manual*).

* The Chlorine Institute Inc., 1300 Wilson Blvd., Arlington, VA 22209.

Sodium hypochlorite is miscible in any proportion with water. It should be stored in a dark area where the temperature does not exceed 80°F (30°C). A 12 percent to 20 percent solution is still liquid at 0°F (–17.8°C) but is a slush at –20°F (–28.9°C). It is available in 5-gal and 13-gal (19-L and 49-L) carboys (glass or polyethylene), 30-gal (113.6-L) drums, and in approximately 5,000-gal (18,926-L) tank trucks. The available chlorine content is as indicated in Table F.1.

I.B. *History.* The original AWWA Standard for Hypochlorites, prepared for the AWWA Water Purification Division, was approved by the Executive Committee of the Water Purification Division and by the Water Works Practice Committee and received approval by the AWWA Board of Directors on June 2, 1953. It was designated ANSI/AWWA B300 53T.

The initial document was reaffirmed without revision on June 17, 1955, and the designation was changed from ANSI/AWWA B300 53T to ANSI/AWWA B300 55. Subsequent revisions were adopted on June 5, 1964, Jan. 26, 1975, June 15, 1980, and June 14, 1987. This standard was revised by the AWWA Standards Committee on Disinfectants, and ANSI/AWWA B300-99 was approved by the AWWA Board of Directors on June 20, 1999. A subsequent revision was adopted on June 13, 2004. This edition was approved on Jan. 17, 2010.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AwwaRF, now

Table F.1 Chlorine available in sodium hypochlorite

gpl Available Chlorine	Trade % Available Chlorine	Chlorine Equivalent <i>lb/gal</i>	Chlorine Equivalent <i>kg/L</i>	Gallons to Obtain 1 lb Chlorine	Liters to Obtain 1 kg Chlorine
200	20.0	1.630	0.200	0.610	5.000
160	16.0	1.333	0.160	0.752	6.250
150	15.0	1.200	0.150	0.800	6.667
120	12.0	1.000	0.120	1.000	8.333
50	5.0	0.417	0.050	2.400	20.000
10	1.0	0.083	0.010	12.000	100.000

Sample Calculation:

12 trade percent available chlorine = 120 grams per liter (gpl) available chlorine

120 gpl $\times$ 3.785 L/gal $\times$ 2.205 lb/1,000 g = 1 lb/gal available chlorine

Water Research Foundation) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including two standards developed under the direction of NSF, NSF†/ANSI‡ 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 60. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 60 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA B300 addresses additives requirements in Sec. 4.4 of the standard. The transfer of contaminants from chemicals to processed water or the residual solids is becoming a problem of great concern. The language in Sec. 4.4.2 is a recommendation only for direct additives used in the treatment of potable water to be certified by an accredited certification organization in accordance with NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects. However, users of the standard may opt to make this certification a requirement for the product. Users of this standard should also consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

* Persons outside the United States should contact the appropriate authority having jurisdiction.

† NSF International, 789 N. Dixboro Road, Ann Arbor, MI 48105.

‡ American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.