



**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA B405-16
(Revision of ANSI/AWWA B405-06)

AWWA Standard

Sodium Aluminate

Effective date: Nov. 1, 2016.

First edition approved by AWWA Board of Directors May 15, 1960.

This edition approved June 19, 2016

Approved by American National Standards Institute May 12, 2016.




AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or code of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the Official Notice section of *Journal – American Water Works Association*. The action becomes effective on the first day of the month following the month of *Journal – American Water Works Association* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; 212.642.4900; or emailing info@ansi.org.



ISBN-13, print: 978-1-62576-186-6

eISBN-13, electronic: 978-1-61300-395-4

DOI: <http://dx.doi.org/10.12999/AWWA.B405.16>

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2016 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Iron Salts, Aluminum Salts, and Related Coagulant Aids, which reviewed and approved this standard, had the following personnel at the time of approval:

Glenn R. Evers, *Chair*

Jan J. Pavlicek, *Vice-Chair*

General Interest Members

M.B. Alvarez, CH2M, Coral Gables, Fla.	(AWWA)
K-K Au, FMC Global Peroxygens, Naperville, Ill.	(AWWA)
J.D. Edwards, Westerville, Ohio	(AWWA)
G.R. Evers, IS2 LLC, Hockessin, Del.	(AWWA)
J.J. Gemin, AECOM, Kitchener, Ont., Canada	(AWWA)
P.H. Hargette, Black & Veatch Corporation, Greenville, S.C.	(AWWA)
S. Heidary-Monfared, EIT, Edmonton, Alta, Canada	(AWWA)
G.A. Iversen, Hazen and Sawyer, Raleigh, N.C.	(AWWA)
D. Larson,* St. Louis, Mo.	(AWWA)
C.B. Lind, Mauser USA LLC, East Brunswick, N.J.	(AWWA)
J.W. Patterson, J.W. Patterson Environmental Consultants, Chicago, Ill.	(AWWA)
S.J. Posavec,* Standards Group Liaison, AWWA, Denver, Colo.	(AWWA)
B.H. Wilder, Daytona Beach, Fla.	(AWWA)

Producer Members

T.A. Badwak, USALCO LLC, Baltimore, Md.	(AWWA)
J.P. Crass, Ventura, Calif.	(AWWA)
D.E. Gordon, QC Corporation, Baltimore, Md.	(AWWA)
L.N. Hjersted,† Agro Iron, Lakeland, Fla.	(AWWA)
B. Keogh, B.I.K. Water Technologies, Dundas, Ont., Canada	(AWWA)
J.J. Pavlicek, Detroit, Mich.	(AWWA)
K.E. Ruehl, Chemtrade Logistics, Ballwin, Mo.	(AWWA)
G. Shull, Yantis, Texas	(AWWA)
B. Wodetzki, PVS Chemicals Inc., Valparaiso, Ind.	(AWWA)

* Liaison, nonvoting

†Alternate

User Members

J.M. Carroll, East Lansing-Meridian Water, East Lansing, Mich.	(AWWA)
L.V. Landry, Consolidated Waterworks/Sewerage District Number 1, Princeton, La.	(AWWA)
C.A. Owen, Tampa Bay Water, Clearwater, Fla.	(AWWA)
B.K. Parsons, City of Greensboro, Greensboro, N.C.	(AWWA)
R.S. Smith, Louisville Water Co., Louisville, Ky.	(AWWA)
J.S. Trotter, City of Bloomington Utilities, Bloomington, Ind.	(AWWA)

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		1.3	Application..... 1
I	Introduction..... vii	2	References 2
I.A	Background..... vii	3	Definitions 2
I.B	History..... vii	4	Requirements
I.C	Acceptance vii	4.1	Physical Requirements..... 3
II	Special Issues..... ix	4.2	Chemical Requirements 3
II.A	Advisory Information on Product Application..... ix	4.3	Impurities..... 4
III	Use of This Standard..... ix	5	Verification
III.A	Purchaser Options and Alternatives ix	5.1	Sampling..... 4
III.B	Modification to Standard x	5.2	Test Procedures 6
IV	Major Revisions..... x	5.3	Notice of Nonconformance 11
V	Comments x	6	Delivery
Standard		6.1	Marking..... 12
1	General	6.2	Packaging and Shipping 12
1.1	Scope 1	6.3	Affidavit of Compliance or Certified Analysis..... 13
1.2	Purpose 1		

This page intentionally blank.



Foreword

This foreword is for information only and is not a part of ANSI/AWWA B405.

I. Introduction.

I.A. *Background.* Sodium aluminate ($\text{Na}_2\text{Al}_2\text{O}_4$) is used to improve hardness reduction and coagulation when softening water with lime or lime and soda ash. It can also be used in conjunction with alum to improve coagulation.

Sodium aluminate is a manufactured product obtained by combining aluminum oxide (Al_2O_3) with sufficient excess causticity (sodium oxide) for stabilization. Sodium aluminate is produced either as a solid or liquid. The solid form is a white or brown granular material containing 60–80 percent $\text{Na}_2\text{Al}_2\text{O}_4$ (19.75–26.33 percent aluminum). The density of solid sodium aluminate is 800 kg/m^3 (50 lb/ft^3). Liquid sodium aluminate is a concentrated solution containing approximately 30–45 percent $\text{Na}_2\text{Al}_2\text{O}_4$ (9.87–14.80 percent aluminum). The specific gravity of liquid sodium aluminate is 1.45–1.60.

Refer to safety data sheets (SDSs) available from the supplier or manufacturer for safety information.

I.B. *History.* Prior to May 15, 1960, a tentative standard for sodium aluminate was designated AWWA B405-59T. On May 15, 1960, the first edition was approved. Subsequent revisions to ANSI/AWWA B405 were prepared by the AWWA Standards Committee on Iron Salts, Aluminum Salts, and Related Coagulant Aids and approved by the AWWA Board of Directors in 1983, 1989, 1994, and 2000. The sixth edition was approved by the AWWA Board of Directors on June 11, 2006. This edition was approved by the AWWA Board of Directors on June 19, 2016.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation[†] (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

† Water Research Foundation, 6666 West Quincy Avenue, Denver, CO 80235.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including two standards developed under the direction of NSF†: NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 60. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdictions. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 60 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA B405 addresses additives requirements in Sec. 4.3.2 of the standard. The transfer of contaminants from chemicals to processed water or to the residual solids is becoming a problem of greater concern. The language in Sec. 4.3.2 is a recommendation only for direct additives used in the treatment of potable water to be certified by an accredited certification organization in accordance with NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects (http://www.nsf.org/newsroom_pdf/NSF-ANSI_60_watemarked.pdf). However, users of the standard may opt to make this certification a requirement for the product. Users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

* Persons outside the United States should contact the appropriate authority having jurisdiction.

† NSF International, 789 North Dixboro Road, Ann Arbor, MI 48105.