

American Water Works Association
ANSI/AWWA B510-95
(Revision of ANSI/AWWA B510-89)



AWWA STANDARD
FOR
CARBON DIOXIDE



Addendum B510a-97 is incorporated into this standard.

Effective date: Nov. 1, 1995.

First edition approved by AWWA Board of Directors June 18, 1989.

This edition approved Jan. 22, 1995.

Approved by American National Standards Institute July 10, 1995.

AMERICAN WATER WORKS ASSOCIATION

6666 West Quincy Avenue, Denver, Colorado 80235

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 11 W. 42nd St., New York, NY 10036; (212) 642-4900.

Copyright © 1995 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Carbon Dioxide, which developed this standard, had the following personnel at the time of approval:

Franklyn W. Pogge, *Chair*

Consumer Members

Herb Gehrling, Brandon Water Treatment Plant, Brandon, Man.	(AWWA)
F.W. Pogge, Kansas City Water Department, Kansas City, Mo.	(AWWA)

General Interest Members

F.L. Hinker,* Montgomery Watson, Pasadena, Calif.	(AWWA)
V.E. Jacobsen, Toltz King Duvall Anderson, St. Paul, Minn.	(AWWA)
D.A. Johnson, City of St. Cloud, St. Cloud, Minn.	(AWWA)
W.H. Mahoney, Water Testing Service, Coventry, R.I.	(NEWWA)
J.L. Patton, Black & Veatch, Kansas City, Mo.	(AWWA)
E.S. Ralph,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
J.F. Thomas, University of California, Berkeley, Calif.	(AWWA)

Producer Members

David Burgener, Liquid Air Corporation/Cardox Division, Countryside, Ill.	(AWWA)
Ray Sartor, TOMCO ₂ Equipment Company, Loganville, Ga.	(AWWA)

*Liaison, nonvoting

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		3	Definitions 2
I	Introduction v	4	Requirements
I.A	Background v	4.1	Physical Description 2
I.B	History vi	4.2	Chemical Requirements 2
I.C	Acceptance vi	4.3	Impurities 2
II	Special Issues vii	5	Verification
II.A	Storage and Handling	5.1	Sampling 4
	Precautions vii	5.2	Test Procedures 5
III	Use of This Standard viii	6	Delivery
III.A	Purchaser Options and	6.1	Marking 10
	Alternatives viii	6.2	Packaging and Shipping 10
III.B	Modification of Standard viii	6.3	Affidavit of Compliance 11
IV	Major Revisions viii	Appendix	
V	Comments ix	A	Bibliography 12
Standard		Table	
1	General	1	Directory of Limiting
1.1	Scope 1		Characteristics 3
1.2	Purpose 1		
1.3	Application 1		
2	References 1		

Foreword

This foreword is for information only and is not a part of AWWA B510.

I. Introduction.

I.A. *Background.* Carbon dioxide is a colorless, odorless, and tasteless gas that forms a very weak acid known as carbonic acid when dissolved in water. The reaction of the carbon dioxide in the water to be treated forms bicarbonates with calcium carbonate or calcium hydroxide when used to neutralize excess lime following lime softening. Originally, carbon dioxide gas was added to the water to convert normal carbonates, which are slightly soluble, to bicarbonates, which are more soluble, to prevent the precipitation of encrusting scale from the water. This practice, however, led to the formation of an aggressive water, and the addition of carbon dioxide is now used primarily for pH adjustment following excess lime softening or lime treatment. Additional information on carbon dioxide is contained in CGA (Compressed Gas Association) G-6, *Carbon Dioxide*.*

Carbon dioxide gas for recarbonation may be obtained in several ways. In older water plants, the gas is made by burning a hydrocarbon fuel, such as coke, oil, or gas (or a combination of these), with an excess of air, scrubbing the stack gases if necessary, and then conveying the gas to the point of application by means of a compressor or blower. There may be a wide variation in the percentage of carbon dioxide in the gases, so that very frequent attention and adjustment of the regulating valves is necessary. Underwater burners, in which a mixture of air and gas such as propane is ignited and burned near the bottom of the recarbonation basin, are free from many of these difficulties.

Production problems in on-site generation of carbon dioxide and low-absorption efficiency led to the use of commercially manufactured carbon dioxide in the 1960s. A vaporizer is used to change the liquid carbon dioxide to a gas, which then passes through a pressure-regulating valve to the diffusers. The amount of gas used can be controlled very accurately by flow measurement. Because the gas is pure carbon dioxide, much smaller pipe and diffusing equipment is needed than for carbon dioxide generated from fuels, and the danger from carbon monoxide is virtually eliminated.

Commercial carbon dioxide is generally obtained in bulk as a liquid under pressure from industrial gas companies and certain chemical suppliers. It must then be vaporized and dissolved in the water at the point of application. Commercial production of carbon dioxide is generally by one of the following methods:

- recovery of CO₂ gas as a by-product from ammonia plants
- recovery and purification of by-product CO₂ from steam reforming of methane followed by the shift reaction
- recovery and purification of gas produced as a by-product of alcohol plants
- natural CO₂ gas wells
- recovery and purification of by-product gas from the calcining of limestone

*CGA G-6, *Carbon Dioxide*. Available from the Compressed Gas Association Inc., 1235 Jefferson Davis Highway, Room 501, Arlington, VA 22202.

- acid neutralization
- combustion of carbonaceous materials (such as fuel oil and natural gas) and purification of the resulting flue gas

Carbon dioxide obtained from any of these sources is processed to a purity of 99 percent or better, and contains no odor or taste contaminants. By compressing and cooling, carbon dioxide gas is condensed into its liquid form, which is the state most commonly used for transfer and storage in water treatment plants.

Because of the varied nature of carbon dioxide production and feed equipment in use in the water supply industry today, it was the consensus of the AWWA Standards Committee on Carbon Dioxide that this standard address only the recommendations for procurement of commercial carbon dioxide. This does not preclude any user of carbon dioxide who produces it on-site from using the analytical techniques described in this standard to determine the purity of the product produced. It was not the intention of the committee to recommend any particular means of carbon dioxide generation or use, but merely to provide a standard for the purchaser of commercially produced carbon dioxide on the industrial market.

I.B. *History.* The first edition of the AWWA standard for carbon dioxide (CO₂) was approved by the AWWA Board of Directors on June 18, 1989. The standard was approved in the course of the activities of the AWWA Standards Committee on Carbon Dioxide. The purpose of AWWA B510 is to cover carbon dioxide and not the design of carbon dioxide handling facilities or methods of transfer of carbon dioxide to the water being treated. Design information may be found in *Journal AWWA* and in other publications, some of which are listed in appendix A.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for all direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AWWARF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including two standards developed under the direction of NSF, ANSI†/NSF‡ 60, Drinking Water Treatment Chemicals—Health Effects, and ANSI/NSF 61, Drinking Water System Components—Health Effects.

Various certification organizations may be involved in certifying products in accordance with ANSI/NSF 60 (61). Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

*Persons in Canada, Mexico, and non-North American countries should contact the appropriate authority having jurisdiction.

†American National Standards Institute, 11 W. 42nd St., New York, NY 10036.

‡NSF International, 3475 Plymouth Rd., Ann Arbor, MI 48106.

Appendix A, “Toxicology Review and Evaluation Procedures,” to ANSI/NSF 60 (61) does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Appendix A procedures may not always be identical, depending on the certifier.

AWWA B510-95 addresses additives requirements in Sec. 4.3 of the standard. The transfer of contaminants from chemicals to processed water or the residual solids is becoming a problem of greater concern. The language in Sec. 4.3.4 is a recommendation only for direct additives used in the treatment of potable water to be certified by an accredited certification organization in accordance with ANSI/NSF Standard 60, Drinking Water Treatment Chemicals—Health Effects. However, users of the standard may opt to make this certification a requirement for the product. Users of this standard should also consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by all parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues.

II.A. *Storage and Handling Precautions.* Carbon dioxide is a colorless, odorless gas of high specific gravity. It is hazardous because it is an asphyxiant and can replace the ambient air, causing an oxygen deficiency. Carbon dioxide gas is physiologically active and is used in low concentrations. Increasing exposure to elevated concentrations of CO₂ in air breathed results in an increased respiration rate. Carbon dioxide gas has been given an 8-h, time-weighted average (TWA) by the Occupational Safety and Health Administration (OSHA) of 5,000 ppm (1/2 percent).^{*} The immediately dangerous to life or health level (IDLH) recommended by the National Institute for Occupational Safety and Health (NIOSH)[†] has been set at 40,000 ppm. Further details on physiological effects of CO₂ can be found in specific texts, such as *Carbon Dioxide Tolerance and Toxicity*.[‡]

Because carbon dioxide is denser than air, it tends to accumulate in low and confined areas. Therefore, such precautions as the careful location of storage facilities and ventilation of enclosed areas where CO₂ can accumulate should be taken in the design of CO₂ systems to minimize the hazard. Filtering-type gas masks are not to be used where there is a possibility of a high concentration of CO₂. Self-contained breathing apparatus and hose masks are required. Contact of skin with liquid CO₂ or with expanding liquid CO₂ (dry ice) should be avoided, as it can cause severe freeze burns on the skin. Consult appropriate OSHA, NIOSH, and CGA reference materials for additional safety information.

^{*}*Code of Federal Regulations*, Title 29, CFR Part 1910 (Labor). US Department of Labor, Superintendent of Documents, US Government Printing Office, Washington, DC 20402.

[†]National Institute for Occupational Safety and Health, 4676 Columbia Parkway, Cincinnati, OH 45226.

[‡]Lambertson, C.J. 1974. *Carbon Dioxide Tolerance and Toxicity*. Institute for Environmental Medicine, University of Pennsylvania, Philadelphia, PA 19104.

All lines or piping from a bulk CO₂ storage tank must be protected by adequate pressure-relief devices when there is any possibility of pressure buildup from entrapped liquid CO₂. A pressure-relief device should be provided between the tank shutoff valve and the first pressure regulator, between the first and second pressure regulators, and between any other two points where liquid CO₂ might be entrapped. Because of the possibility that a buildup of static electricity could result from the flow of liquid CO₂ in a pipeline, liquid CO₂ pipelines should be electrically grounded.

Appropriate signs should be posted near areas where CO₂ is stored or fed to warn of the possibility of high CO₂ concentrations. Tunnels or other poorly ventilated areas where carbon dioxide lines are placed should be monitored with a continuous carbon dioxide analyzer. The analyzer should indicate carbon dioxide levels at the entrances to tunnels or poorly ventilated areas, and should be capable of activating high-level alarms.

For additional safety information, refer to material safety data sheets (MSDS) available from the supplier or manufacturer.

III. Use of This Standard. AWWA has no responsibility for the suitability or compatibility of the provisions of this standard to any intended application by any user. Accordingly, each user of this standard is responsible for determining that the standard's provisions are suitable for and compatible with that user's intended application.

III.A. Purchaser Options and Alternatives. The following items should be covered in the purchaser's specifications:

1. Standard used — that is, AWWA B510-95, Standard for Carbon Dioxide, of latest revision.
2. Delivery method.
3. Size and specific type of storage container to be used.
4. If the CO₂ supplied should exceed the 99.5 percent purity level or be less than 99.5 percent pure (Sec. 4.2) in accordance with Table 1 of this standard.
5. If cylinder shipments are specified and, if required, the number of cylinders to be sampled (Sec. 5.1.1).
6. In the event that an analysis by a referee laboratory is required, the assignment of testing costs (Sec. 5.2.16.4).
7. If bulk shipments are specified and, if required, a weight certificate from a certified weigher supplied by the supplier or manufacturer. In lieu of weight certificates, certified liquid meter tickets may be accepted by the purchaser (Sec. 6.2.2.1).
8. If an affidavit of compliance or certified analysis, or both, are required (Sec. 6.3).
9. Whether the recommended compliance with ANSI/NSF Standard 60, Drinking Water Treatment Chemicals—Health Effects, is to be required. If this certification is to be required, the purchaser's specifications shall read, "This material *shall* be certified as suitable for contact with or treatment of drinking water by an accredited certification organization in accordance with ANSI/NSF Standard 60, Drinking Water Treatment Chemicals—Health Effects."

III.B. Modification of Standard. Any modification of the provisions, definitions, or terminology in this standard must be provided in the purchaser's specifications.

IV. Major Revisions. Major changes to the standard made in this revision include the following:

1. The format has been changed to reflect current AWWA standard style.
2. The acceptance clause (Sec. I.C) and the definitions of parties (Sec. 3) have been revised to approved wording.