

ANSI AWWA

C104/A21.4-22

(Revision of ANSI/AWWA C104/A21.4-16)

AWWA Standard

Cement–Mortar Lining for Ductile-Iron Pipe and Fittings

Effective date: Feb. 1, 2023.

First edition approved by Board of Directors Jan. 28, 1980.

This edition approved Oct. 24, 2022.

Approved by American National Standards Institute Oct. 4, 2022.




AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or code of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; 212.642.4900, or emailing info@ansi.org.



ISBN-13, print: 978-1-64717-117-9

eISBN-13, electronic: 978-1-61300-648-1

DOI: <http://dx.doi.org/10.12999/AWWA.C104.22>

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher.

Copyright © 2022 by American Water Works Association
Printed in USA

 **Documents**
Document Sharing Hub

Committee Personnel

The AWWA A21 Standards Subcommittee 4, Coatings and Linings, which reviewed and approved this standard, had the following personnel at the time of approval:

Gregg Horn, *Chair*

General Interest Members

J.A. Hrdlicka (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.

D.H. Kroon, Aegion, Houston, Tex.

J.R. Plattsmier, Consultant, New Port Richey, Fla.

P.A. Selig, Consultant, Birmingham, Ala.

Producer Members

J.H. Eddings, McWane Inc., Phillipsburg, N.J.

J.A. Fancher (*alternate*), American Cast Iron Pipe Company, Birmingham, Ala.

M.D. Gaston, American Cast Iron Pipe Company, Birmingham, Ala.

L.G. Horn, Ductile Iron Pipe Research Association, Birmingham, Ala.

A.M. Horton, US Pipe & Foundry Company, Birmingham, Ala.

K.J. Kempf, Kempf Holdings, LLC, Foundry Services Co., Omaha, Neb.

H. Kennedy, Jr., Harold Kennedy & Associates, Fuquay-Varina, N.C.

V. O'Dea, Tnemec Company, Kansas City, Mo.

D. Swalley, Electrosteel USA, Birmingham, Ala.

User Members

M.J. Britch, Tualatin Valley Water District, Beaverton, Ore.

B. Matejcek, Orange County Utilities, Orlando, Fla.

J.R. Waugh, Bureau of Reclamation, Denver, Colo.

R.L. Worden, COMCD, Norman, Okla.

AWWA Standards Committee A21, Ductile Iron Pipe and Fittings, which reviewed and approved this standard, had the following personnel at the time of approval:

John R. Plattsmier, *Chair*
Maury D. Gaston, *Vice-Chair*

General Interest Members

M. Dunn, Crist Engineers, Inc., Little Rock, Ark.
J. Hebenstreit, Underwriters Laboratories Inc., Northbrook, Ill.
M.B. Horsley, Horsley Engineering LLC, Overland Park, Kans.
J.A. Hrdlicka (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.
D.H. Kroon, Aegion, Houston, Tex.
D.D. Lary (*alternate*), Wright-Pierce, Topsham, Maine
C.R. Laucamp, AECOM, Chicago, Ill.
P.J. Mourt, Mott MacDonald, Philadelphia, Pa.
J.R. Plattsmier, Consultant, New Port Richey, Fla.
S. Pool (*alternate*), HDR Engineering, Denver, Colo.
T.M. Stinson, Kleinfelder SEA Company, Holbrook, Mass.

Producer Members

L.R. Dunn (*alternate*), US Pipe & Foundry Company, Birmingham, Ala.
J.H. Eddings, McWane Inc., Phillipsburg, N.J.
J.A. Fancher (*alternate*), American Cast Iron Pipe Company, Birmingham, Ala.
M.D. Gaston, American Cast Iron Pipe Company, Birmingham, Ala.
L.G. Horn, Ductile Iron Pipe Research Association, Birmingham, Ala.
D. Hughes, US Pipe & Foundry Company, Birmingham, Ala.
J.C. Jones, Georg Fischer, Dallas, Tex.
H. Kennedy, Jr., Harold Kennedy & Associates, Fuquay-Varina, N.C.
J.S. Palombo, Everett J. Prescott, Inc., Gardiner, Maine
A. Rich (*alternate*), G.A. Rich and Sons, Deer Creek, Ill.
D. Swalley, Electrosteel, Birmingham, Ala.

User Members

M.J. Britch, Tualatin Valley Water District, Beaverton, Ore.

J. Fox, Tampa Bay Water, Clearwater, Fla.

D.D. Montgomery, Independence Water Department, Independence, Mo.

C.J. Patla, Connecticut Water Service Inc., Clinton, Conn.

G. Ramon (*liaison, nonvoting*), Standards Council Liaison, Little Rock Water Reclamation Authority, Little Rock, Ark.

J.M. Ross, Denver Water, Denver, Colo.

P.A. Shively, City of Kansas City, Kansas City, Mo.

J.R. Waugh, Bureau of Reclamation, Denver, Colo.

J.T. Wilson, Cobb County-Marietta Water Authority, Marietta, Ga.

R.L. Worden, COMCD, Norman, Okla.

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
<i>Foreword</i>		4	Requirement
I	Introduction..... ix	4.1	Materials 3
I.A	Background..... ix	4.2	Cement 4
I.B	History..... ix	4.3	Sand 4
I.C	Acceptance xi	4.4	Water 4
II	Special Issues xii	4.5	Mortar..... 4
II.A	Use of Seal Coat..... xii	4.6	Surface of Pipe and Fittings for Lining 4
II.B	Lining of Pipelines in Place..... xii	4.7	Method of Lining..... 5
III	Use of This Standard xiii	4.8	Thickness of Lining..... 5
III.A	Purchaser Options and Alternatives xiii	4.9	Determination of Thickness 5
III.B	Modification to Standard xiii	4.10	Curing..... 6
IV	Major Revisions..... xiii	4.11	Lining Quality..... 6
V	Comments xiii	4.12	Seal Coat..... 6
<i>Standard</i>		5	Verification
1	General	5.1	Testing of Sand..... 7
1.1	Scope..... 1	5.2	Testing of Seal Coat..... 8
1.2	Purpose 1	6	Delivery
1.3	Application..... 1	6.1	Notice of Nonconformance..... 9
2	References 2	6.2	Affidavit of Compliance 9
3	Definitions 3	<i>Tables</i>	
		1	Minimum Thickness of Linings for Pipe and Fittings 5
		2	Requirements for Sand Tested with Standard Sieves..... 7

This page intentionally blank.