

American Water Works Association
ANSI/AWWA C115/A21.15-99
(Revision of ANSI/AWWA C115/A21.15-94)



AMERICAN NATIONAL STANDARD
FOR
FLANGED DUCTILE-IRON PIPE
WITH DUCTILE-IRON OR GRAY-IRON
THREADED FLANGES



Administrative Secretariat
AMERICAN WATER WORKS ASSOCIATION

Co-secretariat
AMERICAN GAS ASSOCIATION

Effective date: January 1, 2000
First edition approved by AWWA Board of Directors Jan. 26, 1975.
This edition approved June 20, 1999.
Approved by American National Standards Institute October 26, 1999.

AMERICAN WATER WORKS ASSOCIATION

6666 West Quincy Avenue, Denver, Colorado 80235

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 11 W. 42nd St., New York, NY 10036; (212) 642-4900.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 1999 American Water Works Association
Printed in USA

Committee Personnel

Subcommittee 1, Pipe, which developed this standard, had the following personnel at the time:

Philip A. Selig, *Chair*
Troy F. Stroud, *Vice-Chair*

Consumer Members

T.E. Coughran, City of Santa Ana, Santa Ana, Calif.	(AWWA)
A.J. DeBoy, Indiana-American Water Company, Greenwood, Ind.	(AWWA)
E.T. Knudsen Jr., St. Petersburg Engineering Dept., St. Petersburg, Fla.	(AWWA)
J.D. Larson, St. Louis County Water Company, St. Louis, Mo.	(AWWA)
G.L. Meyer, City of Sioux Falls, Sioux Falls, S.D.	(AWWA)

General Interest Members

K.M. Bell, Underwriters Laboratories Inc., Northbrook, Ill.	(AWWA)
M.G. Hoover, HYA, Pasadena, Calif.	(AWWA)
M.B. Horsley, Black & Veatch LLP, Overland Park, Kan.	(AWWA)
P.I. McGrath Jr., Birmingham, Ala.	(AWWA)
W.H. Smith, Flora, Ill.	(AWWA)
K.E. Wilson, Post, Buckley, Schuh, Jernigan, Tampa, Fla.	(AWWA)
L.C. Yates, McGoodwin, William & Yates, Fayetteville, Ark.	(AWWA)

Producer Members

D.R. Charko, Atlantic States Cast Iron Pipe, Phillipsburg, N.J.	(AWWA)
J.C. Delk, McWane Cast Iron Pipe Company, Birmingham, Ala.	(AWWA)
L.R. Dunn, U.S. Pipe & Foundry Company, Birmingham, Ala.	(AWWA)
Harold Kennedy Jr., Suiken & Kennedy LLP, Cary, N.C.	(AWWA)
C.W. McCauley, Griffin Pipe Products Company, Lynchburg, Va.	(AWWA)
T.J. Muntz, Fab Pipe Inc., Rogers, Minn.	(AWWA)
P.A. Selig, American Cast Iron Pipe Company, Birmingham, Ala.	(AWWA)
T.F. Stroud, Ductile Iron Pipe Research Association, Birmingham, Ala.	(AWWA)

The AWWA Standards Committee A21, Ductile-Iron Pipe and Fittings, which reviewed and approved this standard, had the following personnel at the time of approval:

Robert L. Scarpa, *Chair*
Larry R. Dunn, *Vice-Chair*

Consumer Members

D.T. Bradley, City of Santa Ana, Santa Ana, Calif.	(AWWA)
T.E. Coughran, City of Santa Ana, Santa Ana, Calif.	(AWWA)
A.J. DeBoy, Indiana-American Water Company, Greenwood, Ind.	(AWWA)

R.R. Goold, Kansas City Water Services Department, Kansas City, Mo.	(AWWA)
J.D. Larson, St. Louis County Water Company, St. Louis, Mo.	(AWWA)
G.L. Meyer, City of Sioux Falls, Sioux Falls, S.D.	(AWWA)
T.C. Moreno, Bexar Metropolitan Water District, San Antonio, Texas	(AWWA)
C.R. Schwenker, Fairfax County Water Authority, Merrifield, Va.	(AWWA)
R.L. Worden, Macon Water Authority, Macon, Ga.	(AWWA)
R.D. Zwygart, Tampa Water Department, Tampa, Fla.	(AWWA)

General Interest Members

K.M. Bell, Underwriters Laboratories Inc., Northbrook, Ill.	(UL)
Vance Forsgren, Forsgren Associates, Rexburg, Idaho	(AWWA)
Joseph Goss,* Delon, Hampton & Associates, Rockville, Md.	(NEWWA)
K.W. Henderson, Malcolm Pirnie Inc., White Plains, N.Y.	(AWWA)
M.G. Hoover, HYA Consulting Engineers, Pasadena, Calif.	(AWWA)
M.B. Horsley, Black & Veatch LLP, Overland Park, Kan.	(AWWA)
W.B. Jeffcoat, CH2M Hill Inc., Montgomery, Ala.	(AWWA)
J.L. Lane,† Missouri Department of Natural Resources, Jefferson City, Mo.	(AWWA)
E.W. Misichko,* Underwriters Laboratories Inc., Northbrook, Ill.	(UL)
J.R. Plattsmeir, Montgomery-Watson, Henderson, Nev.	(AWWA)
R.L. Scarpa, Metcalf & Eddy Inc., Austin, Texas	(NEWWA)
W.H. Smith, W.H. Smith & Associates, Flora, Ill.	(AWWA)
J.H. Wilber,† Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
L.C. Yates, McGoodwin Williams & Yates, Fayetteville, Ark.	(AWWA)

Producer Members

Bill Bliss, Tyler Pipe, Tyler, Texas	(AWWA)
J.C. Delk, McWane Cast Iron Pipe Company, Birmingham, Ala.	(AWWA)
L.R. Dunn, U.S. Pipe & Foundry Company, Birmingham, Ala.	(AWWA)
Harold Kennedy Jr., Suiken & Kennedy LLP, Cary, N.C.	(AWWA)
C.W. McCauley, Griffin Pipe Products Company, Lynchburg, Va.	(AWWA)
G.L. Oliver,* American Cast Iron Pipe Company, Birmingham, Ala.	(DIPRA)
P.L. Robertson, Specification Rubber Products, Alabaster, Ala.	(AWWA)
P.A. Selig, American Cast Iron Pipe Company, Birmingham, Ala.	(DIPRA)
Dennis Shumard, EBAA Iron Inc., Eastland, Texas	(AWWA)
T.F. Stroud, Ductile-Iron Pipe Research Association, Birmingham, Ala.	(DIPRA)

* Alternate

† Liaison, nonvoting

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		5	Verification
I	Introduction..... vi	5.1	Quality Control and Inspection..... 7
I.A	Background..... vi	5.2	Inspection by Purchaser 7
I.B	History vi	6	Delivery 7
I.C	Acceptance..... vi	Appendixes	
II	Special Issues..... vii	A	Bolts, Gaskets, and Installation..... 9
II.A	Flange Material Properties vii	B	Typical Pipe/Flange Thread
II.B	Special Service Requirements..... viii		Construction 11
II.C	Advisory Information..... viii	C	Wall Pipe 12
III	Use of This Standard..... ix	Figures	
III.A	Purchaser Options and	F.1	Comparison of Flange Dimensions ix
	Alternatives..... ix	1	Solid Flange Details 4
III.B	Modification of Standard..... x	2	Hollow-Back Flange Details 5
IV	Major Revisions..... x	B.1	Typical Pipe and Flange Thread
V	Comments..... x		Construction 11
Standard		C.1	Typical Flanged Wall Pipe
1	General		Installations 13
1.1	Scope 1	Tables	
1.2	Purpose 1	1	Ductile-Iron Pipe for Use
1.3	Application..... 1		With Threaded Flanges 2
2	References 2	2	Solid Gray- or Ductile-Iron
3	Definitions 3		Flange Dimensions..... 4
4	Requirements	3	Hollow-Back Ductile-Iron
4.1	Pipe Barrel 3		Flange Dimensions..... 5
4.2	Flanges..... 3	A.1	Flange Gasket Details..... 10
4.3	Fabrication 6	C.1	Collar Dimensions 12
4.4	Coatings and Linings..... 6	C.2	Suggested Minimum "Face to
4.5	Marking 7		Wall" Dimensions..... 13

Foreword

This foreword is for information only and is not part of ANSI/AWWA C115/A21.15.

I. Introduction.

I.A. Background. American National Standards Institute (ANSI) Committee A21 on Cast-Iron Pipe and Fittings was organized in 1926 and sponsored by the American Gas Association (AGA), the American Society for Testing and Materials (ASTM), AWWA, and the New England Water Works Association (NEWWA). Between 1972 and 1984, the co-secretariats were AGA, AWWA, and NEWWA, with AWWA serving as administrative secretariat. In 1984 the committee became an AWWA committee named AWWA Standards Committee A21 on Ductile-Iron Pipe and Fittings. Committee A21 develops standards and manuals addressing ductile-iron pressure pipe for water and other liquids; and ductile-iron and gray-iron fittings for use with this type of pipe. These standards and manuals include design, dimensions, materials, coatings, linings, joints, accessories, and methods of inspection and testing.

The work of Committee A21 is conducted by subcommittees. The scope of Subcommittee 1, Pipe, includes the periodic review of all current Committee A21 standards for pipe; the preparation of revisions and new standards; and other matters pertaining to pipe standards.

I.B. History. Flanged fittings sizes 3 in. through 48 in. (76 mm through 1,219 mm) are described in ANSI/AWWA C110/A21.10, American National Standard for Ductile-Iron and Gray-Iron Fittings, 3 In. Through 48 In. (76 mm Through 1,219 mm), for Water. Flanged fittings sizes 54 In. Through 64 In. (1,400 mm Through 1,600 mm) are covered in ANSI/AWWA C153/A21.53, American National Standard for Ductile-Iron Compact Fittings, 3 In. Through 24 In. (76 mm Through 610 mm) and 54 In. Through 64 In. (1,400 mm Through 1,600 mm), for Water Service. The flanged pipe used with these fittings has been purchased for many years in accordance with users', manufacturers', and fabricators' standards. An ANSI standard was needed for flanged pipe. Consequently, Subcommittee 1 submitted a proposed standard for flanged pipe to Committee A21 in 1974. The first edition of the standard was adopted in 1975, with subsequent editions published in 1983, 1988, and 1994. Subcommittee 1 reviewed the 1994 edition and submitted a proposed revision to Committee A21 in 1999. This edition was approved on June 20, 1999.

I.C. Acceptance. In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for all direct and indirect drinking water additives. Other members of the original consortium included the American Water Works Association Research Foundation (AWWARF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate

*Persons in Canada, Mexico, and non-North American countries should contact the appropriate authority having jurisdiction

the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state or local agency.
3. Two standards developed under the direction of NSF, ANSI^{*}/NSF[†] 60, Drinking Water Treatment Chemicals—Health Effects, and ANSI/NSF 61, Drinking Water System Components—Health Effects.
4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,[‡] and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with ANSI/NSF 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Appendix A, "Toxicology Review and Evaluation Procedures," to ANSI/NSF 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of "unregulated contaminants" are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Appendix A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C115/A21.15 does not address additives requirements. Therefore, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements including applicable standards.
2. Determine the status of certifications by all parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues.

II.A. *Flange Material Properties.* Because this standard requires the material properties of gray-iron and ductile-iron flanges to comply with ANSI/AWWA C110/A21.10, the following material properties specified in ANSI/AWWA C110/A21.10 are listed below for information purposes.

1. Gray-iron flanges, in accordance with ANSI/AWWA C110/A21.10, shall be manufactured of the following minimum tensile-strength iron.

Nominal Size [*] <i>in.</i> [†]	Minimum Tensile Strength	
	<i>psi</i>	<i>(kPa)</i>
3-12	25,000	(172,000)
14-24	30,000	(207,000)

^{*} Purchasers of gray-iron flanges greater than 24 in. should contact the manufacturer or fabricator for strength requirements.

[†] To convert inches to millimetres, multiply by 25.4.

^{*} American National Standards Institute, 11 W. 42nd St., New York, NY 10036.

[†] NSF International, 3475 Plymouth Rd., Ann Arbor, MI, 48106.

[‡] Both publications available from National Academy of Sciences, 2102 Constitution Ave. N.W., Washington, DC 20418.