

American Water Works Association

ANSI/AWWA C207-94

(Revision of ANSI/AWWA C207-86)



AWWA STANDARD
FOR
**STEEL PIPE FLANGES FOR WATERWORKS
SERVICE – SIZES 4 IN. THROUGH 144 IN.
(100 mm THROUGH 3,600 mm)**



Effective date: Nov. 1, 1994.

First edition approved by AWWA Board of Directors June 17, 1955.

This edition approved Jan. 30, 1994.

Approved by American National Standards Institute Aug. 18, 1994.

AMERICAN WATER WORKS ASSOCIATION

6666 West Quincy Avenue, Denver, Colorado 80235

Copyright (C) 1998 American Water Works Association, All Rights Reserved.

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 11 W. 42nd St., New York, NY 10036; (212) 642-4900.

Copyright © 1994 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Task Group on Steel Pipe Flanges, which developed this standard, had the following personnel at the time:

Bruce Vanderploeg, <i>Chair</i>	
H.H. Bardakjian	Gary Robb
D.Y. Bridges	R.N. Satyarthi
R.J. Card	K.L. Shaddix
J.R. Davenport	J.C. Taylor
Ned Gribben	M.A. Vanderbosch
John Luka	

The AWWA Standards Committee on Steel Pipe, which reviewed and approved this standard, had the following personnel at the time of approval:

George J. Tupac, *Chair*
 John H. Bambei Jr., *Vice-Chair*
 Dennis Dechant, *Secretary*

Consumer Members

G.A. Andersen, New York City Bureau of Water Supply, Corona, N.Y.	(AWWA)
Ergun Bakall, San Diego County Water Authority, San Diego, Calif.	(AWWA)
J.H. Bambei Jr., Denver Water, Denver, Colo.	(AWWA)
D.J. Cowling, US Bureau of Reclamation, Denver, Colo.	(USBR)
J.L. Doane, Portland Water Bureau, Portland, Ore.	(AWWA)
W.M. Kremkau, Washington Suburban Sanitary Commission, Hyattsville, Md.	(AWWA)
R.T. Menlove, Los Angeles Department of Water & Power, Los Angeles, Calif.	(AWWA)
K.F. Olson, Tacoma Public Utilities, Tacoma, Wash.	(AWWA)
G.M. Snyder, Metropolitan Water District of Southern California, Los Angeles, Calif.	(AWWA)
M.L. Young, East Bay Municipal Utility District, Stockton, Calif.	(AWWA)

General Interest Members

G.E. Block Jr., Rizzo Associates Inc., Natick, Mass.	(NEWWA)
W.R. Brunzell, Brunzell Associates Ltd., Skokie, Ill.	(AWWA)
R.L. Coffey, R.W. Beck and Associates, Seattle, Wash.	(AWWA)
E.A. Cooney,* Council Liaison, Whitman & Howard Inc., Wellesley, Mass.	(AWWA)
B.R. Elms,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
L.J. Farr, CH2M Hill Inc., Redding, Calif.	(AWWA)

*Liaison, nonvoting

K.D. Henrichsen, HDR Engineering Inc., Denver, Colo.	(AWWA)
G.K. Hickox, Engineering Consultant, Houston, Texas	(AWS)
J.K. Jeyapalan, American Ventures Inc., Redmond, Wash.	(AWWA)
R.Y. Konyalian, Boyle Engineering Corporation, Newport Beach, Calif.	(AWWA)
L.T. Schaper, Black & Veatch, Kansas City, Mo.	(AWWA)
Earl Smock,* Montgomery Watson, Walnut Creek, Calif.	(AWWA)
Richard Sohns, Espey Huston & Associates Inc., Austin, Texas	(AWWA)
R.V. Stokes, J.M. Montgomery Engineers, Los Angeles, Calif.	(AWWA)
H.R. Stoner, Henry R. Stoner Associates Inc., North Plainfield, N.J.	(AWWA)
Chris Sundberg,* CH2M Hill, Bellevue, Wash.	(AWWA)
G.J. Tupac, G.J. Tupac & Associates, Pittsburgh, Pa.	(AWWA)
L.W. Warren, KCM Inc., Seattle, Wash.	(AWWA)
W.R. Whidden, Post Buckley Schuh and Jernigan, Winter Park, Fla.	(AWWA)
R.E. Young, Robert E. Young Engineers, Sacramento, Calif.	(AWWA)

Producer Members

H.H. Bardakjian, Ameron Pipe Products Group, Rancho Cucamonga, Calif.	(AWWA)
T.R. Brown, Smith-Blair Inc., Uniontown, Pa.	(AWWA)
J.H. Burton, Baker Coupling Company Inc., Los Angeles, Calif.	(SPFA)
R.J. Card, Thompson Pipe and Steel, Denver, Colo.	(AWWA)
J.R. Davenport, California Steel Pressure Pipe, Riverside, Calif.	(AWWA)
Dennis Dechant, Northwest Pipe & Casing Company, Portland, Ore.	(AWWA)
G.M. Harris, Tapecoat Company, Longboat Key, Fla.	(AWWA)
J.R. Pegues, American Cast Iron Pipe Company, Birmingham, Ala.	(MSS)
Bruce Vanderploeg,* Northwest Pipe & Casing Company, Portland, Ore.	(AWWA)
J.A. Wise, Canus Industries Inc., Vancouver, B.C.	(AWWA)

*Alternate

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		5 Verification	
I	Introduction..... vi	5.1	Inspection by the Purchaser..... 8
I.A	Background vi	5.2	Mill Test Reports..... 8
I.B	History of Standard..... vii	6 Delivery	
I.C	Acceptance..... vii	6.1	Markings 8
II	Special Issues..... viii	Appendix	
III	Use of Standard viii	A Bibliography..... 15	
III.A	Purchaser Options and Alternatives viii	Figures	
III.B	Modification to Standard ix	1	Attachment of Flange 7
IV	Major Revisions ix	2	Draft or Layback Measurement 7
V	Comments ix	Tables	
Standard		1 Flange Gasket Materials, Type and Thickness 5	
1 General		2 AWWA Standard Steel-Ring Flanges, Class B (86 psi) and Class D (175–150 psi)..... 9	
1.1	Scope..... 1	3 AWWA Standard Steel-Hub Flanges, Class B (86 psi) and Class D (175–150 psi)..... 10	
1.2	Purpose..... 1	4 AWWA Standard Steel-Hub Flanges, Class E (275 psi)..... 11	
1.3	Application 2	5 AWWA Standard Steel-Ring Flanges, Class E (275 psi)..... 12	
2 References..... 2		6 AWWA Standard Steel-Ring Flanges, Class F (300 psi)..... 13	
3 Definitions 4		7 AWWA Blind-Flange Thickness..... 14	
4 Requirements			
4.1	Material..... 4		
4.2	Fabrication 5		
4.3	Method of Attachment of Flanges.... 6		
4.4	Protective Coating 8		

Foreword

This foreword is for information only and is not a part of AWWA C207.

I. Introduction

I.A. *Background.* Steel flanges have been used with steel pipe in the waterworks field since the first riveted, steel water-supply lines were installed with flanges attached by riveting. Flanges manufactured according to unofficial flange standards, such as the riveted-pipe manufacturer's standards, were in common use for 50 years or more before the advent of AWWA C207. Steel-plate ring flanges and rolled-angle flanges, to match the drilling of existing cast valves and cast fittings, were also used extensively.

The greatly increased usage of steel pipe for waterworks service during the 1930s made standardization of flanges desirable. The first step toward standardization was taken in 1942 when a paper* proposing standards for slip-on, steel-ring flanges for welding to steel water pipe was presented at the annual conference of the American Water Works Association.

In 1945, at the request of the American Society of Mechanical Engineers (ASME), a committee having representatives from both ASME and the American Water Works Association (AWWA) was formed. The ASME/AWWA committee was charged with establishing standards for steel flanges having dimensions and pressure ratings commensurate with the pressures commonly used in waterworks service. The standards were necessary because the lowest pressure ratings for steel flanges at that time were those having cold-water pressure ratings of 275 psi (1,896 kPa) (ANSI†/ASME‡ B16.5, Pipe Flanges and Flanged Fittings) (150-psi [1,034-kPa] primary pressure rating). The ratings were far higher than those ordinarily needed for water service.

The generally accepted rules for the design of bolted, flanged connections embraced all fields of usage and a wide range of pressure and temperature applications. In waterworks practice it is not necessary, within the scope of this standard, to deal with temperatures greater than the atmospheric range, and it is possible to restrict consideration to joints with softer gaskets and to flanges that are flat faced. The designs were prepared in conformity with these limitations.

The ASME/AWWA committee gave careful consideration to the following: (1) the effect of new standards on existing equipment; (2) the fact that cast valves and fittings will always have flanges of large outside diameter, which cannot be reduced because of the wall thickness of such equipment; (3) the need for interchangeability of equipment through the medium of common drilling templates; and (4) the fact that standards could be based on the successful usage and good service records of existing installations.

A survey of water utility users indicated that it was desirable to maintain the outside diameter and drilling of flanged fittings and valves given in ANSI/AWWA C500, Standard for Gate Valves for Water and Sewage Systems; and ANSI/ASME

*Hill, H.O., et al. 1944. Fabricated Steel Ring Flanges for Water Pipe Service for Low Pressure and Low Temperatures. *Jour. AWWA*, 36(9):968 (September 1944).

†American National Standards Institute, 11 W. 42nd St., New York, NY 10036.

‡American Society of Mechanical Engineers, 345 E. 47th St., New York, NY 10017.

B16.1, Cast Iron Pipe Flanges and Flanged Fittings (for classes 25, 125, 250, and 800). The committee decided to follow this practice for sizes 6 in. (150 mm) through 48 in. (1,200 mm).

In its extensive deliberations, the ASME/AWWA committee had available the results of special research and testing conducted by Armco Steel Corporation, Bethlehem Steel Company, and Taylor Forge and Pipe Works. The various design methods and test results are given in "Steel Ring Flanges for Steel Pipe," Bulletin 47-A (1947), from the American Rolling Mill Company, Middletown, Ohio. The design of flanges for waterworks service, with the results of the preceding report, was published in *Journal AWWA* in October 1950, pp. 931–944. A discussion in the paper by Taylor Forge, participants in the ASME/AWWA committee, states the reasons why a waterworks flange is not an ASME/Taylor Forge flange. Concern about high secondary stresses at the attachment, e.g., thick material to thin wall pipe, is covered here along with the published "Design of Wye Branches." (See *Journal AWWA*, June 1955, Appendix C, pp. 581–630.)

I.B. *History of Standard.* The report of the ASME/AWWA committee was approved in 1951, and the first edition of this standard, designated C207-52T, was published under the title "Tentative Standard Specifications For Steel Pipe Flanges" in 1952. That edition covered diameters from 6 in. to 48 in. (150 mm to 1,200 mm) and pressures through 150 psi (1,034 kPa). In 1954, a committee composed of Taylor Forge, Armco, Bethlehem, and consulting engineers revised the existing standard to include diameters through 96 in. (2,400 mm) and pressures to 275 psi (1,896 kPa). This revision was published under designation AWWA C207-55, Standard Specifications/Standard For Steel Pipe Flanges. The standard was further revised and the next edition published in 1978 as AWWA C207-78, Standard For Steel Pipe Flanges For Waterworks Service — Sizes 4 In. Through 144 In. The next edition, designated AWWA C207-86 with the same title, was published in 1986 and revised the maximum test pressure to 125 percent of the flange rating, added segmentation of flanges, blind flanges, class E ring flanges, class F ring and hub flanges, and tolerances for flange draft or layback.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for all direct and indirect drinking water additives. Other members of the consortium included the American Water Works Association Research Foundation (AWWARF), the Conference of State Health and Environmental Managers (COSHEM), the American Water Works Association (AWWA), and the Association of State Drinking Water Administrators (ASDWA). The consortium is responsible for the cooperative effort of manufacturers, regulators, product users, and other interested parties that develop and maintain the NSF standards.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate

*Persons in Canada, Mexico, and non-North American countries should contact the appropriate authority having jurisdiction.

the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. An advisory program formerly administered by USEPA, Office of Drinking Water, discontinued on Apr. 7, 1990.
2. Specific policies of the state or local agency.
3. Two standards developed under the direction of NSF, ANSI*/NSF† 60, Drinking Water Treatment Chemicals — Health Effects, and ANSI/NSF 61, Drinking Water System Components — Health Effects.
4. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,‡ and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with ANSI/NSF 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Appendix A, “Toxicology Review and Evaluation Procedures,” to ANSI/NSF 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Appendix A procedures may not always be identical, depending on the certifier.

AWWA C207-94 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by all parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues. It should be noted that thickness and dimensional designs of ring and hub flanges have been based on references given in the background section of this foreword, as well as industry standard and other empirical data. Thickness design of the blind flanges has been based on the ASME Code Design Method.

III. Use of Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. Purchaser Options and Alternatives. When purchasing steel flanges for steel water pipe, the purchaser shall make specific statements in the specifications regarding the following:

1. Standard used — that is, AWWA C207-94, Standard for Steel Pipe Flanges for Waterworks Service — Sizes 4 In. Through 144 In. (100 mm Through 3,600 mm).
2. Type of flanges required — ring or hub type (Sec. 1.1).
3. Pressure rating required (Tables 2 through 7).

*American National Standards Institute, 11 W. 42nd St., New York, NY 10036.

†NSF International, 3475 Plymouth Rd., Ann Arbor, MI 48106.

‡Both publications available from National Academy of Sciences, 2102 Constitution Ave. N.W., Washington, DC 20418.

4. Class of flange required (Tables 2 through 7).
5. Inside diameter of flanges (Tables 2 through 7).
6. Gaskets — rubber or nonasbestos (Sec. 4.1.3) and gasket thickness for diameters up to and including 24 in. (610 mm)

III.B. *Modification to Standard.* Any modification of the provisions, definitions, or terminology in this standard must be provided in the purchaser's specifications.

IV. Major Revisions. Major changes made in this edition of the standard are as follows:

1. The standard was edited and reformatted throughout.
2. Sec. 4.1.1.2, Steel plate or bar (old Sec. 2.1.2), was revised to add carbon restrictions and the minimum yield strength was increased to 32,000 psi (220.6 MPa), representative of materials commonly used today.
3. Sec. 4.1.2, Bolting (old Sec. 2.2), was revised to delete ASTM* A307 grade A for class B and D flanges and add ASTM A193 grade B7 for class E and F flanges.
4. Sec. 4.1.3, Gaskets (old Sec. 2.3), was revised and new Table 1, Flange Gasket Materials, Type and Thickness, was added.
5. Sec. 4.2.5, Blind Flanges (old Sec. 3.5), was revised, reducing the maximum size of flat-plate blind flanges from 60 in. to 48 in. (1,500 mm to 1,200 mm).
6. Tables previously numbered 1–5 were renumbered Tables 2–6, respectively.
7. Bolt diameters for class B flanges in Tables 2 and 3 (new) were revised to match class D bolts.
8. Thicknesses of some flanges were changed in Tables 2 and 6 (new).
9. A tolerance on the diameter of the flange bore was added to Tables 2 and 3 (new) to prevent overboring hub flanges.
10. Hub flanges greater than 96 in. (2,400 mm) were deleted from Tables 3 and 4 (new).
11. Old Table 6, AWWA Standard Steel Hub Flanges, Class F (300 psi [2,068 kPa]), was deleted since these flanges are identical to ANSI/ASME B16.5, and new Table 7, AWWA Blind-Flange Thickness, was added.

V. Comments. If you have any comments or questions about this standard, please call the AWWA Standards Department, (303) 794-7711 ext. 2201, FAX (303) 795-1440, or write to the department at 6666 W. Quincy Ave., Denver, CO 80235.

*American Society for Testing and Materials, 1916 Race St., Philadelphia, PA 19103.