



**American Water Works
Association**

The Authoritative Resource on Safe Water®

ANSI/AWWA C208-07
(Revision of ANSI/AWWA C208-01)

AWWA Standard

Dimensions for Fabricated Steel Water Pipe Fittings



Effective date: May 1, 2008.
First edition approved by AWWA Board of Directors Jan. 26, 1959.
This edition approved June 24, 2007.
Approved by American National Standards Institute Jan. 16, 2008.

6666 West Quincy Avenue
Denver, CO 80235-3098
T 800.926.7337
www.awwa.org

Advocacy
Communications
Conferences
Education and Training
Science and Technology
Sections

 **Documents**
Document Sharing Hub

AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the classified advertising section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2008 by American Water Works Association
Printed in USA

Committee Personnel

The Steel Water Pipe-Manufacturers Technical Advisory Committee (SWPMTAC) Task Group on C208, which developed this revision, had the following personnel at the time:

John L. Luka, *Chair*

K. Beul, Price Brothers, Dayton, Ohio	(AWWA)
R.J. Card, Victaulic, Atlanta, Ga.	(AWWA)
R.R. Collins, JCM Industries, Nash, Texas	(AWWA)
B.D. Keil, Continental Pipe Manufacturing Company, Pleasant Grove, Utah	(AWWA)
J.L. Luka, American Spiral Weld Pipe Company, Columbia, S.C.	(AWWA)
G.C. Robb, Ameron Concrete & Steel Pipe, Fontana, Calif.	(AWWA)
R.N. Satyarthi, Baker Coupling Company Inc., Los Angeles, Calif.	(AWWA)
K.L. Shaddix, Smith-Blair Inc., Texarkana, Texas	(AWWA)
B. Terrell, RTLC Piping Products Inc., Kosse, Texas	(AWWA)
B.F. Vanderploeg, Northwest Pipe Company, Portland, Ore.	(AWWA)
D.R. Wagner, DRW/Consultant, St. Louis, Mo.	(AWWA)

The Standards Committee on Steel Pipe, which developed this standard, had the following personnel at the time of approval:

John H. Bambei Jr., *Chair*

George J. Tupac, *Vice-Chair*

Dennis Dechant, *Secretary*

General Interest Members

J.B. Allen,* Standards Engineer Liaison, AWWA, Denver, Colo.	(AWWA)
W.R. Brunzell, Brunzell Associates Ltd., Skokie, Ill.	(AWWA)
R.L. Coffey, Kirkham Michael & Associates, Omaha, Neb.	(AWWA)
H.E. Dunham, MWH Inc., Bothell, Wash.	(AWWA)
S.N. Foellmi, Black & Veatch Corporation, Irvine, Calif.	(AWWA)
J.W. Green, McDonough Associates Inc., Chicago, Ill.	(AWWA)
M.B. Horsley,† Black & Veatch Corporation, Kansas City, Mo.	(AWWA)

* Liaison, nonvoting

† Alternate

J.K. Jeyapalan, Pipeline Consultant, New Milford, Conn.	(AWWA)
J.L. Mattson, Corrosion Control Technologies, Sandy, Utah	(AWWA)
W.J. Moncrief,* HDR Engineering Inc., San Diego, Calif.	(AWWA)
R. Ortega, Lockwood Andrews & Newnam, Houston, Texas	(AWWA)
A.E. Romer, Boyle Engineering Corporation, Newport Beach, Calif.	(AWWA)
H.R. Stoner, Consultant, North Plainfield, N.J.	(AWWA)
C.C. Sundberg, CH2M Hill, Issaquah, Wash.	(AWWA)
G.J. Tupac, G.J. Tupac & Associates Inc., Pittsburgh, Pa.	(AWWA)
W.R. Whidden, Post Buckley Schuh & Jernigan, Orlando, Fla.	(AWWA)
K.E. Wilson,† Standards Council Liaison, Post Buckley Schuh & Jernigan, Inc., Tampa, Fla.	(AWWA)

Producer Members

S.A. Arnaout, Hanson Pressure Pipe Inc., Dallas, Texas	(AWWA)
H.H. Bardakjian, Ameron International, Rancho Cucamonga, Calif.	(AWWA)
M. Bauer, Tnemec Company Inc., Kansas City, Mo.	(AWWA)
R.J. Card, Victaulic, Atlanta, Ga.	(AWWA)
R.R. Carpenter, American Cast Iron Pipe Company, Birmingham, Ala.	(MSS)
D. Dechant, Northwest Pipe Company, Denver, Colo.	(AWWA)
B.D. Keil, Continental Pipe Manufacturing Company, Pleasant Grove, Utah	(SPEA)
J.L. Luka,* American SpiralWeld Pipe Company, Columbia, S.C.	(AWWA)
B.F. Vanderploeg,* Northwest Pipe Company, Portland, Ore.	(AWWA)
J.A. Wise, Canus International Sales Inc., Surrey, B.C.	(AWWA)

User Members

G.A. Andersen, New York City Bureau of Water Supply, Little Neck, N.Y.	(AWWA)
J.H. Bambei Jr., Denver Water, Denver, Colo.	(AWWA)
D.W. Coppes, Massachusetts Water Resources Authority, Southborough, Mass.	(NEWWA)
R.V. Frisz, US Bureau of Reclamation, Denver, Colo.	(USBR)
G. George, Tacoma Water, Water Supply Section, Tacoma, Wash.	(AWWA)
T.J. Jordan, Metropolitan Water District of Southern California, LaVerne, Calif.	(AWWA)
M. McReynolds,* La Mirada, Calif.	(AWWA)

* Alternate

† Liaison, nonvoting

G. Oljaca, Greater Vancouver Regional District, Burnaby, B.C.	(AWWA)
V.B. Soto, Los Angeles Department of Water & Power, Los Angeles, Calif.	(AWWA)
G.P. Stine, San Diego County Water Authority, Escondido, Calif.	(AWWA)
J.V. Young, City of Richmond, Richmond, B.C.	(AWWA)

This page intentionally blank.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword			
I	Introduction	ix	
I.A	Background	ix	
I.B	History	ix	
I.C	Acceptance	x	
II	Special Issues	x	
III	Use of This Standard	x	
III.A	Purchaser Options and Alternatives	x	
III.B	Modification to Standard	x	
IV	Major Revisions	x	
V	Comments	xi	
Standard			
1	General		
1.1	Scope	1	
1.2	Purpose	2	
1.3	Application	2	
2	References	2	
3	Definitions	2	
4	Requirements		
4.1	Fittings	2	
5	Verification	9	
6	Delivery	10	
Figures			
1A–1F	Recommended Dimensions for Water Pipe Fittings (Except Elbows)	12	
2A–2B	Recommended Dimensions for Water Pipe Elbows	13	
2C–2D	Recommended Dimensions for Water Pipe Elbows	14	
2E–2F	Recommended Dimensions for Water Pipe Elbows	15	
3	Tangent-type Outlet	16	
4	Lateral Less Than 30°	17	
5	Reducing Elbow	18	
Table			
1	Dimensions of Steel Water Pipe Fittings	11	

This page intentionally blank.

Foreword

This foreword is for information only and is not a part of ANSI/AWWA C208.

I. Introduction.

I.A. *Background.* Steel pipe has been used for waterlines in the United States since the 1850s. With the development of the Bessemer process in 1855 and the open-hearth process in 1861, steel, the strongest and most versatile refinement of iron, became available for water pipe.

Available records disclose installations of steel water pipe as early as 1858. The pipe was first manufactured by rolling steel sheets or plates into shape and riveting the seams. This method of fabrication continued with improvements into the 1930s. In 1905, lock-bar pipe was introduced and, by 1930, had nearly supplanted riveted pipe. By the early 1930s, both riveted and lock-bar methods were gradually phased out and welding dominated the pipe-making process. As welding became more universal in pipeline construction and manufacturing, varying steel shapes able to accommodate pipeline hydraulics and locations became more prevalent. Over the years, rigid specifications have been developed and new product developments and improvements in manufacturing techniques and processes have been established to ensure the purchaser a product of high standards.

I.B. *History.* This standard was first proposed in 1955 to provide standard dimensions for steel water pipe fittings. It was approved as a “tentative” standard on July 14, 1955. Revisions in the text were approved on Dec. 31, 1957, and were incorporated in the fourth and later printings. The revisions consisted of the addition of an explanatory paragraph, changes in the table for fittings for service in transmission and distribution mains, and clarification of the figures detailing the various fittings. The standard was approved without further revision on Jan. 26, 1959.

Revisions to the text were approved on June 21, 1983, and incorporated in the sixth and later printings. These revisions include the following:

1. Addition of a foreword to provide the history of a standard and major revisions.
2. Revision of Table 1, deleting 4-in. pipe size and extending pipe sizes to 144 in.
3. Revision of Table 2.
4. Expansion of Figure 3 to include sizes to 144 in.
5. Deletion of Table 4.
6. Deletion of alternate Table 3.
7. Deletion of Table 5.
8. Addition of reducing tees and deletion of smooth 90° elbow category from Figure 1 and Table 1.

The information in Table 1 was changed from a tabular format to a formula format in order

to ascertain dimensions for tees, crosses, wyes, laterals, and reducers. A factor, f , was introduced in the new Table 1 to facilitate the use of formulas for computing fitting dimensions and provided formulas for elbow layout to facilitate the design of elbows not tabulated.

Addendum C208-84 was approved on June 4, 1984. The addendum added a note of caution to Tables 2A through 2D concerning hoop tension concentration in elbows with a radius of less than $2.5D$. ANSI/AWWA C208-83, including ANSI/AWWA C208-84, was reaffirmed without revision on June 18, 1989. ANSI/AWWA C208-96 was approved by the Board of Directors on June 23, 1996. The major revision was to clarify that the standard is a dimensional guide only and that design of fittings should be in accordance with applicable sections of AWWA Manual M11. Table 2 was deleted from the standard. ANSI/AWWA C208-01 was approved on June 17, 2001. This edition of ANSI/AWWA C208 was approved on June 24, 2007.

I.C. Acceptance. This standard has no applicable information for this section.

II. Special Issues. This standard has no applicable information for this section.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. Purchaser Options and Alternatives. The following items should be covered by the purchaser:

1. Standard used—that is, ANSI/AWWA C208, Dimensions for Fabricated Steel Water Pipe Fittings, of latest revision.
2. Type of fitting required (i.e., elbow, tee, reducer, wye, lateral, etc.).
3. Radius of elbows (i.e., $1D$, $1.5D$, $2.5D$, or other).
4. Number of pieces or segments for elbows.
5. Design pressure and specifications for pipe to which the steel fitting will connect (i.e., ANSI/AWWA C200, AWWA M11).
6. Type of end connection required (i.e., plain, beveled end for field butt welding, bell or spigot for field lap welding, bell or spigot O-ring, and flanged or mechanical coupling).
7. Submittal of shop detail and assembly drawings.
8. Special handling, inspection, or testing requirements.
9. Lining and coating required.

III.B. Modification to Standard. Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Major revisions made to this standard in this edition include the following:

1. Several symbols have been added to Sec. 4.1.2.